



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	06-17-02	Interpretation #	02-008 <b>Amended</b>
Topic	Day Care at School Facilities		
Code Section(s)	Table 10-A, California Building Code (1998)		
Requested by	<b>Terrence Finch, Fire Marshal</b> <b>San Diego Fire Department</b> <b>1010 2<sup>nd</sup> Ave #300</b> <b>San Diego, CA 92101</b>  <b>James Pettigrew, Fire Prevention Inspector</b> <b>Ontario Fire Department</b> <b>415 East "B" St</b> <b>Ontario, CA 91764</b>		

*Are buildings and rooms in an E-1 occupancy, used exclusively for day care purposes, required to have two exits?*

Yes. Buildings and rooms located on school grounds that are used exclusively for day care purposes for seven or more children must be classified as a Group E, Division 3 occupancy and shall have two exits.