



California State Fire Marshal
CODE INTERPRETATION

Date Issued	06-17-02	Interpretation #	02-028
Topic	Area Increase for Relocatable Classrooms		
Code Section(s)	Table 5-B, California Building Code (1998)		
Requested by	Norcliff W. Wiley, Fire Marshal Salinas Fire Department 65 West Alisal St Salinas, CA 93901		

Is it the intent of the State Fire Marshal to allow relocatable classrooms to be grouped together beyond the limitation of 9,100 square feet when the side yard(s) and/or the sprinkler system provisions within Section 505 of the California Building Code are met?

Yes. School buildings and relocatable classrooms are allowed area increases in accordance with Sections 504 and 505 of the California Building Code.