



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	02-06-04	Interpretation #	02-030	<b>REVISED</b>
Topic	Smoke Barriers in Group I, Division 1.1 Occupancies			
Code Section(s)	Section 308.2.2.1, California Building Code (1998 ed)			
Requested by	Kenneth J. Oh, P.E. Rolf Jensen and Associates 7676 Hazard Center Drive, 5 <sup>th</sup> Floor San Diego, CA 92108-4508			

***Is it the interpretation of the State Fire Marshal that only cross-corridor doors and mechanical duct penetration openings are permitted in the smoke barrier walls of a Group I, Division 1.1. occupancy as specified in Section 308.2.2.1?***

No. In addition to duct openings and cross-corridor doors, the code permits other openings in a smoke barrier wall including doors and through-penetrations that comply with Chapters 7 and 9 and are fire-rated and smoke tight.