



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	12-05-02	Interpretation #	02-049
Topic	Relays for Fire Alarm Control Panels		
Code Section(s)			
Requested by	Greg Cortina Radionics 3119 Seville Avenue Palmdale, CA 93551		

*When a relay used by the fire alarm control panel to control such events as damper closing, elevator recall, fan shutdown, door holders and such, would this relay need to be specifically listed with CSFM/UL for that purpose and/or would it need to be listed for “releasing service”?*

Yes. The relay must be listed by SFM for releasing service. The relay may be a component of a specifically listed Fire Alarm Control Panel or may be separately listed for use with various fire alarm control panels.