



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	10-21-03	Interpretation #	03-037
Topic	Escape/Rescue Windows for Hotels		
Code Section(s)	§310.4, California Building Code (2001 ed)		
Requested by	Daniel Nolan TBP Architecture 2300 Newport Blvd Newport Beach, CA 92663		

Does Exception #2 of §310.4 apply only to Group R, Division 1 hotel occupancies or does the exception apply to all Group R, Division 1 occupancies?

Exception #2 applies only to hotels.