



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	8/14/09	Interpretation	09-028
Topic	Corridor vs. Room		
Code Section(s)	2007 CBC Section 1002 and 442.2.2		
Requested by	Donald Rice Architect, AIA, APEC, CSI NCARB, LEED AP Senior Associate WLC Architects, Inc. 8163 Rochester Avenue, Suite 100 Rancho Cucamonga, CA 91730-0729		

**Is a Corridor, as defined in the 2007 CBC Section 1002, to be considered as a Room under the provisions of the 2007 CBC, Section 442.2?**

No. The 2007 CBC Section 1002 defines a corridor as an enclosed exit access component that defines and provides a path of egress travel to an exit. It is not considered a room.