



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	June 8, 2010	Interpretation	10-022
Topic	Power-limited Fire alarm cabling installation		
Code Section(s)	2007 California Electrical Code Articles 760.52(B)(1) & 760.61(A0, (B) & (C)		
Requested by	Interface Engineering Joseph Ripp 708 SW Third Avenue, Suite 400 Portland, OR 97204 (503)382-2266 (503)382-2262 fax joer@interfaceeng.com		

Is fire alarm cabling allowed to be installed exposed per Sections 760.52(B)(1) and 760.61(A), (B) and (C) of the 2007 CEC, provided a raceway system is not required by another code or standard, i.e., 2007 CFC Section 909.12.1 for smoke control system detection and control wiring?

Yes. Unless specifically required by other codes or standards.