



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	June 8, 2010	Interpretation	10-028
Topic	Elevator Lobbies in Group I-2 occupancies		
Code Section(s)	January 1, 2009 supplement to the 2007 California Building Code section 403.6 & 707.14.1		
Requested by	The Code Consortium Rick Thornberry, PE 2724 Elks Way Napa, CA 94558 (707) 253-2633 (707) 253-2639 (fax) THECODEINC@AOL.COM		

Where 1-hour fire-resistance rated enclosed elevator lobbies are required by Section 707.14.1 of the 2007 California Building Code including the January 1, 2009 Supplement, can Exceptions 3, 5, and 7 to that section be used in lieu of the 1-hour fire-resistance rated enclosed elevator lobbies in Group I-2 (hospital) occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access?

Yes