

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

					ROAD STANDARDS FOR FIRE EQUIPMENT ACCESS:																	STANDARDS FOR SIGNING STREETS, ROADS, BLDGS.																						
Code Adoptions and References	Local Source	Notes / Response	AB 337 Mandate Status	Width	Surface	Grades	Horizontal Inside Radius	Vertical Curves	Turn-arounds	Hammer-head/T	Turnouts	Roadway Structures (Bridges)	Bridge Signage	One-way Roads	Dead-end Roads	<1 acre parcels	1-4.99 acre parcels	5-19.99 acre parcels	20+ acre parcels	Driveways	If >150' but <800'	If >800'	If >300'	Gate Entrances	If one-way	Sign Symbols	Visibility	Height	Names /Numbers	Intersections														
<b>Local Jurisdiction</b>				Two 9' lanes, 13' 6" vertical clearance	40,000 lb. Load	Not to exceed 16%	No less than 50'	100'	Required, 40' from center	Top of "T" 60' long	10' x 30'	25' taper each end	Load & clearance per VCS 35550, 35250	Load, clearance, one-way, single lane	One 10' lane	Must connect to 2 lanes at each end	Serve no more than 10 dwellings	Not to exceed 2640'	Turnout at midpoint	Not to exceed:	800'	1320'	2640' with turnaround at 1320'	5280' w/ turnaround at 1320' intervals	10' wide, 15' vertical clearance	Turnout at midpoint	Every 400'	Turnaround w/in 50' of all building sites	2' wider than lane	30' from roadway	40' turning radius	3" letter height	3/8" stroke	ReflectORIZED	Contrasting color	100' both directions	Uniform	Required	Signs required					
Adelanto	UFC 1991	Ordinances 179 & 247	ME	Meets	Sufficient fire apparatus load	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	Meets					Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief					
Agoura Hills **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required						Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief				
Alameda		Verbal	Nothing to mail	No zone																																								
Alameda County	UFC 1994	Verbal	Nothing to mail	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	12' wide 13' 6" vertical					Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief		
Albany	UFC, UBC, NFPA-72, 299, 1141	Ch. XI, Fire Prevention	Empty lots subject to VMP	EX	Meets	Meets	As approved by Chief	Meets	Meets	As approved by Chief	40' minimum	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	12' wide 15' vertical	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		
Alpine County	Title 14	Fire Safe Regs for SRA Ch. 15.12														Turnaround required	Turnaround required	Turnaround required	Turnaround required																									
Alto-Richardson Bay	UFC 1994, H&SC 17922, NFPA 13 & 74			ME	Meets	Meets	18% Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnaround @ 300' intervals	Turnaround @ 300' intervals	Turnaround @ 300' intervals	Turnaround @ 300' intervals	12' wide 13' 6" vertical	Turnaround @ 300' intervals	Turnaround @ 300' intervals	Turnaround @ 300' intervals		Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	
Alturas	UFC 1994, UBC	Article III - Nuisance abatement	Under revision	No zone																																								
Amador FPD	PRC 4290-1, T-14, NFPA 1231, ISO 8, UFC, Fire Safe Guide	Ordinance 1437	Ordinance only for new construction		County Code Sect. 12.08.030	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	As required by Chief	
American River FPD		Verbal	Metexceed prior to Bates	120																																								
Anderson	UFC/UBC per Chief	Ordinance 629 and Verbal		120	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets
Angel's Camp	Section 3203, Title 14, UFC 1988	Ordinance 342	VMP pending, UFC 1997 too	120																																								
Apple Valley	UFC 1991	Ordinance 30		ME	Meets	Sufficient fire apparatus load	12%	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	Meets					Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	
Aptos / La Selva		Verbal	ID'd zone has been chanoed	120																																								
Arbuckle-Coll City	UFC 1994, PRC 4290, Title 14	Verbal		No zone	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	12' wide 13' 6" vertical					Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
Arcadia				120																																								
Arcata	UBC, UFC - versions?	Verbal	Nothing to mail	No zone																																								
Artesia **				No zone																																								
Atascadero	UFC 1991, NFPA 299 & 1141	Fire Code Ch. 8, Ordinance 337		ME	Meets	Meets	20% or per Chief	28' inside 48' outside	Meets	Meets	40' long	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	12' wide 15' vertical	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets
Atwater		Verbal	Nothing to mail	No zone																																								
Auburn		Verbal	Zone not adopted	120																																								
Avalon			Catalina Island	120																																								
Azusa **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required						Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
Bakersfield		Hillside Ordinance DRAFT Article IX of City Code & Special Res. No. 1993-01	Triggerred by 8% slope or oreater	No zone	Exceeds		7%				30' inside, 45' outside radius	Meets	Meets	Meets	Meets	Turnaround if >150' long	Turnaround if >150' long	Turnaround if >150' long	Turnaround if >150' long	12' wide 13' 6" vertical	Turnarounds required	Turnarounds required	Turnarounds required				As required by Chief																	
Banning	UBC Section 6 02.01			120																																								
Barstow	UFC 1991	Verbal		ME																																								
Bell Gardens **				No zone																																								
Bellflower **				No zone																																								
Berkeley	UFC 1994, UBC	Ordinance 6128-N.S. and Verbal	Fire History main criteria	EX	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief
Beverly Hills		Red Flag Engine Program outline	Verbal	120																																								
Bolinas	PRC 4291 UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required						Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
Bradbury **	UFC, UBC 1994	Letter dated 9/22/98		120	Meets	Meets	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief
Brea		Verbal		120																																								
Brisbane				120																																								
Burbank				120																																								
Butte County	PRC 4290	Verbal	No VHFHSZ in countv	No zone																																								

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

														FUEL MODIFICATION STANDARDS:										INFORMATION ON PLANS AND SPECIFICATIONS:										STRUCTURAL STAN		
Code Adoptions and References	Local Source	Notes / Response	Access Limit Signage	Sign Installation	Addresses	Address Symbols	Address Installation	Visibility				Hydrant/Fire Valve		Clearance (Structure)	Additional Clearance	Trees	Dead or Dying Wood	Ac-cumulated Vegetation	Chimney & Stovepipe	Setback if >1 acre	if <1 acre	Disposal	Greenbelts	Vicinity Plan	Fire Protection Info in VHFHSZ (GC 51178)					Eaves						
<b>Local Jurisdiction</b>			Nearest intersection or 100' before limit	Prior to acceptance	Required	3' letter height	3/8" stroke	Contrasting color	Permanent posting required at times	Both directions, even if one-way	Multiple addresses on one post	If industrial site, post at intersection	Must meet min. flow as set forth in latest UFC/UBC for new construction	30' each side or to property line	30'-100' when needed	10' from chimney	Remove if overhanging structure	Clear roof	Screen <1/2" 30'	Same practical effect	Prior to acceptance	Locate strategically - must be approved	No less than 1"-100'	300' radius showing all street widths	300' radius hydrant plan / min. flow	Location, occupancy class & use of abutting properties	Preliminary fuel modification plan	300' radius showing all street widths	300' radius hydrant plan / min. flow	Location, occupancy class & use of abutting properties	Preliminary fuel modification plan	Final fuel modification plan	1 hour fire resistant, enclosed	Fascias required, must be backed by 1 hour or 2" lumber		
Adelanto	UFC 1991	Ordinances 179 & 247		As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets	Meets		Appendix III-A	Meets											Access plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.						
Agoura Hills **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets				200' minimum	Meets		200' minimum	Meets	Meets	Meets	Meets	
Alameda		Verbal	Nothing to mail																						Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.						
Alameda County	UFC 1994	Verbal	UFC 1997 pending - zones not yet adopted	As required by Chief	As required by Chief	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.						
Albany	UFC, UBC, NFPA-72, 299, 1141	Ch. XI, Fire Prevention	Empty lots subject to VMP	Meets	Meets	Meets	4" height	1/2" stroke	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Access plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.				1/2" min. - enclosed		
Alpine County	Title 14	Fire Safe Regs for SRA Ch. 15.12																																		
Alto-Richardson Bay	UFC 1994, H&SC 17922, NFPA 13 & 74			As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.						
Alturas	UFC 1994, UBC	Article III - Nuisance abatement	Under revision																																	
Amador FPD	PRC 4290-1, T-14, NFPA 1231, ISO 8, UFC, Fire Safe Guide	Ordinance 1437	Ordinance only for new construction	As required by Chief	As required by Chief	Meets	County Code Ch. 12.40	County Code Ch. 12.40	Meets	Meets	Meets	County Code Ch. 12.40	County Code Ch. 12.40	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Fire mgmt. Plan req'd	Fire mgmt. Plan req'd	Fire mgmt. Plan req'd	Fire mgmt. Plan req'd	Fire mgmt. Plan req'd	Fire mgmt. Plan req'd	Fire mgmt. Plan req'd	Fire mgmt. Plan req'd	Fire mgmt. Plan req'd	Fire mgmt. Plan req'd	Fire mgmt. Plan req'd	Fire mgmt. Plan req'd
American River FPD		Verbal	Metexceed prior to Bates																																	
Anderson	UFC/UBC per Chief	Ordinance 629 and Verbal		As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.						
Angel's Camp	Section 3203, Title 14, UFC 1988	Ordinance 342	VMP pending, UFC 1997 too																																	
Apple Valley	UFC 1991	Ordinance 30		As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets	Meets		Table A-III-A-1 as amended	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Access plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.						
Aptos / La Selva		Verbal	ID'd zone has been chanoed																																	
Arbuckle-Coll City	UFC 1994, PRC 4290, Title 14	Verbal		As required by Chief	As required by Chief	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.						
Arcadia																																				
Arcata	UBC, UFC - versions?	Verbal	Nothing to mail																																	
Artesia **																																				
Atascadero	UFC 1991, NFPA 299 & 1141	Fire Code Ch. 8, Ordinance 337		Meets	Meets	Meets	4" height	12" stroke	Meets	Meets	Meets		As approved by Chief	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Submit plan before constr.	Submit plan before constr.		Submit plan before constr.						1/2" min. Enclosed		
Atwater		Verbal	Nothing to mail																																	
Auburn		Verbal	Zone not adopted Catalina Island																																	
Avalon																																				
Azusa **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets			200' minimum	Meets		200' minimum	Meets	Meets	Meets	Meets	
Bakersfield		Hillside Ordinance DRAFT Article IX of City Code & Special Res. No. 1993-01	Triggered by 8% slope or oreater			Meets		Meets	Meets	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets			Meets	Meets		Meets	Meets	Meets	Meets	Meets	Class 1 ignition resistant		
Banning	UBC Section 6 02.01	Verbal																																		
Barstow	UFC 1991	Verbal																																		
Bell Gardens **																																				
Bellflower **																																				
Berkeley	UFC 1994, UBC	Ordinance 6128-N.S. and Verbal	Fire History main criteria	As required by Chief	As required by Chief	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.				Meets		
Beverly Hills		Red Flag Engine Program outline																																		
Bolinas		Verbal																																		
Bradbury **	PRC 4291 UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets			200' minimum	Meets		200' minimum	Meets	Meets	Meets	Meets	
Brea	UFC, UBC 1994	Letter dated 9/22/98		As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.						
Brisbane		Verbal																																		
Burbank																																				
Butte County	PRC 4290	Verbal	No VHFHSZ in countv										Sprinklers required																							

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

DARDS															MISCELLANEOUS REQUIREMENTS							
Code Adoptions and References	Local Source	Notes / Response	Roofs	Underfloor Areas	Exception	Unenclosed Accessory Structures	Exception	Underfloor Areas (Attached Structure)	Windows	Doors	Attic Openings	Walls	Underfloor Areas (Detached Structure)	Adoption of Zone	Description of Zone	Topography	Fuels	Accessibility	Evacuation	Rubbish Removal		
			Class B or better	Enclosed to ground	If exposed materials are 1 hour rated	Non-combustible or 1 hour rated	If 100' defensible space, patio roofs > 2"x4" or open lattice > 2"x2" is OK	If over a descending slope, enclose within 6" of ground	Tempered or multi-layered glass	Non-combustible or solid core > 1-3/4"	Not to exceed 144 square inches	Non-combustible corrosion-resistant mesh < 1/4" holes	Not to be in soffits, eave overhangs, etc.	Gable/dormer vents 10' from property line	Any habitable space must be 1 hour rated	If over a descending slope, enclose within 6" of ground	Government Codes 51175-51178	Climatic conditions			Required-all types	
<b>Local Jurisdiction</b>																						
Adelanto	UFC 1991	Ordinances 179 & 247		No wood																	No zone per letter dated 6/29/94	Meets
Agoura Hills **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets
Alameda	Verbal		Nothing to mail																		Weed Abatement	
Alameda County	UFC 1994	Verbal	UFC 1997 pending-zones not yet adopted	Class A																	Meets	
Albany	UFC, UBC, NFPA-72, 299, 1141	Ch. XI, Fire Prevention	Empty lots subject to VMP		Meets			Meets						1/2" min. sheathing							Meets	
Alpine County	Title 14	Fire Safe Regs for SRA Ch. 15.12																				
Alto-Richardson Bay	UFC 1994, H&SC 17922, NFPA 13 & 74															Areas defined	Meets	Meets	Meets	Meets	Meets	Meets
Alturas	UFC 1994, UBC	Article III - Nuisance abatement	Under revision																		Meets	
Amador FPD	PRC 4290-1, T-14, NFPA 1231, ISO 8, UFC, Fire Safe Guide	Ordinance 1437	Ordinance only for new construction																		Adopted per PRC 4291.5	Meets
American River FPD	Verbal		Metexceed prior to Bates																			
Anderson	UFC/UBC per Chief	Ordinance 629 and Verbal														Zone defined and mapped						Meets
Angel's Camp	Section 3203, Title 14, UFC 1988	Ordinance 342	VMP pending, UFC 1997 too	Class A																	Adopted per Section 3203, Title 24	
Apple Valley	UFC 1991	Ordinance 30		No wood																		Meets
Aptos / La Selva	Verbal		ID'd zone has been changed	Class B																		
Arbuckle-Coll City	UFC 1994, PRC 4290, Title 14	Verbal																				Meets
Arcadia	UBC, UFC - versions?	Verbal	Nothing to mail																			
Arcata	UFC 1991, NFPA 299 & 1141	Fire Code Ch. 8, Ordinance 337		Class C	Meets			Meets						1/2" min. Sheathing							Meets	
Atwater	Verbal		Nothing to mail																			Weed Abatement
Auburn	Verbal		Zone not adopted Catalina Island																			
Avalon	UFC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets		Meets
Azusa **	UFC 1991, NFPA 299 & 1141	Fire Code Ch. 8, Ordinance 337		Class C	Meets			Meets						1/2" min. Sheathing							Meets	
Bakersfield	UFC 1994, LACFC 1996 (UFC 1994), NFPA	Hillside Ordinance DRAFT Article IX of	Triggered by 8% slope or greater	Class A										Class 1 ignition resistant								
Banning	UBC Section 02.01	City Code & Special Res. No. 1993-01	Verbal	Class B or A No Wood																		Meets
Barstow	UFC 1991	Verbal																				
Bell Gardens **	UFC 1994, UBC	Ordinance 6128-N.S. and Verbal	Fire History main criteria	Class A			Meets							1 hour rated assembly								Meets
Bellflower **	UFC 1994, UBC	Red Flag Engine Program outline	Verbal																			
Berkeley	UFC 1994, UBC	Ordinance 6128-N.S. and Verbal	Fire History main criteria	Class A			Meets							1 hour rated assembly								Meets
Beverly Hills	UFC 1994, UBC	Red Flag Engine Program outline	Verbal																			
Bolinas	PRC 4291	Verbal																				
Bradbury **	UFC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets		Meets
Brea	UFC, UBC 1994	Letter dated 9/22/98		Class B or A																		Meets
Brisbane	Verbal																					
Burbank	Verbal																					
Butte County	PRC 4290	Verbal	No VHFHSZ in county																			

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

					ROAD STANDARDS FOR FIRE EQUIPMENT ACCESS:														STANDARDS FOR SIGNING STREETS, ROADS, BLDGS.																							
Code Adoptions and References	Local Source	Notes / Response	AB 337 Mandate Status	Width	Surface	Grades	Horizontal Inside Radius	Vertical Curves	Turn-arounds	Hammer-head/T	Turnouts	Roadway Structures (Bridges)	Bridge Signage	One-way Roads	Dead-end Roads	<1 acre parcels	1-4.99 acre parcels	5-19.99 acre parcels	20+ acre parcels	Driveways	If >150' but <800'	If >800'	If >300'	Gate Entrances	If one-way	Sign Symbols	Visibility	Height	Names /Numbers	Intersections												
<b>Local Jurisdiction</b>				Two 9' lanes, 13' 6" vertical clearance	40,000 lb. Load	Not to exceed 16%	No less than 50'	100'	Required, 40' from center	Top of "T" 60' long	10' x 30'	25' taper each end	Load & clearance per VCS 35550, 35750, 35250	Load, clearance, one-way, single lane	One 10' lane	Must connect to 2 lanes at each end	Serve no more than 10 dwellings	Not to exceed 2640'	Turnout at midpoint	Not to exceed:	800'	1320'	2640' with turnaround at 1320'	5280' w/ turnaround at 1320' intervals	10' wide, 15' vertical clearance	Turnout at midpoint	Every 400'	Turnaround w/in 50' of all building sites	2' wider than lane	30' from roadway	40' turning radius	3" letter height	3/8" stroke	Reflectorized	Contrasting color	100' both directions	Uniform	Required	Signs required			
Calabasas **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required						Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief			
Calaveras County	PRC 4290-1, NFPA, T-14, PUC 103, ISO and FS Guide	Ordinance 2226 & Resolution 93-11	Ordinance only for new construction		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	
Carlsbad	UFC 1991			ME	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	Meets				Meets	Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	
Carmel-by-the-Sea Carpinteria / Summerland Carson **	Verbal	Roofing ord. Pendino		120																																						
Cerritos **			No zone																																							
Chester FPD	UFC-version?	Verbal	No zone																																							
Chico	Title IV	Chapter 8.20	Weed abatement only	No zone																																						
Chino Hills	UFC 1991	Ordinances 44 & 92-02 and Article 2		ME	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	Meets	Not to exceed 150'	Not to exceed 150'		Meets	Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	
Chino Valley FPD		Resolution 96-11 Agmt A95-84 & Chapter 9.47	Combined with Chino Hills	ME	20' wide	Sufficient fire apparatus load	14%									350' - 600'	350' - 600'	May exceed 600' if all criteria met	May exceed 600' if all criteria met	12' wide	Not to exceed 150'	Not to exceed 150'				As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	
Chula Vista	Weed abate, UBC	Verbal		ME																																						
Claremont **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required						Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
Clearlake Oaks	Fire Safe Guide	Verbal	Nothing to mail	No zone																																						
Clovis	Verbal	All metropolitan	No zone																																							
Colton	UFC 1991	Ordinances 0-18-90 and 0-15-92		ME	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	Meets				Meets	Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
Colusa	CBC - version?, PRC 4290-SRA	Verbal		No zone																																						
Commerce **			No zone																																							
Contra Costa County	Ordinance 96-8	Zone adoption only	120																																							
Corte Madera	UFC 1994, UBC 1994			ME	Meets	Meets	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	12' wide 13' 6" vertical					Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
Covelo	Verbal	Nothing to mail	No zone																																							
Covina **			No zone																																							
Cudahy **			No zone																																							
Culver City **	CFC 1995, UBC, UCADB, UHC, UMC, UPC, NEC, et al 1991	Ordinances 93-008 and 97-014	Zone not adopted	120	Meets	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	13' 6" vertical					Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
Daly City	UFC, UBC, UHC, UCADB, UMC, UPC, NEC 1991	Ordinance 1157 and City Code		120	Meets	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	12' wide, 13' 6" vertical					Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
Diamond Bar **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required						Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
Dougherty Reg.			Dept. not in directorv	EX																																						
Duarte **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required						Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
Dunsmuir	Verbal	Weed Abatement		120																																						
Ebbetts Pass	UFC 1995, PRC 4117, H&SC 17958, NFPA, County Ordin. #2226	Fire Ordinance 95-1			Meets	Meets	Exceeds	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	
El Cajon	Letter dated 8/23/94			EX																																						
El Cerrito	Ordinance 95-1, Article 14 & VMP																																									
El Dorado County FPD	Sections 8.4-1 through 8.4-8, Weeds	Weed abatement	120																																							
El Dorado Hills	UBC 1991, UFC 1994	Ordinance 30 and Verbal		120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required						Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
El Medio	Verbal	Maps pending	No zone																																							
El Monte **			No zone																																							
Emeryville	Verbal	Nothing to mail		EX																																						
Escondido	Verbal	Map on file, need ordinance		ME																																						
Eureka	UFC 1994, UBC 1994	Verbal	Strike team defense	No zone																																						



**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

DARDS															MISCELLANEOUS REQUIREMENTS									
Code Adoptions and References	Local Source	Notes / Response	Roofs	Underfloor Areas	Exception	Unenclosed Accessory Structures	Exception	Underfloor Areas (Attached Structure)	Windows	Doors	Attic Openings		Walls	Underfloor Areas (Detached Structure)	Adoption of Zone	Description of Zone			Rubbish Removal					
			Class B or better	Enclosed to ground	If exposed materials are 1 hour rated	Non-combustible or 1 hour rated	If 100' defensible space, patio roofs > 2"x4" or open lattice > 2"x2" is OK	If over a descending slope, enclose within 6" of ground	Tempered or multi-layered glass	Non-combustible or solid core > 1-3/4"	Not to exceed 144 square inches	Non-combustible corrosion-resistant mesh < 1/4" holes	Not to be in soffits, eave overhangs, etc.	Gable/dormer vents 10' from property line	Any habitable space must be 1 hour rated	If over a descending slope, enclose within 6" of ground	Government Codes 51175-51178	Climatic conditions	Topography	Fuels	Accessibility	Evacuation	Required-all types	
<b>Local Jurisdiction</b>																								
Calabasas **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets	Fire zone 4 #27	Meets	Meets	Meets			Meets	
Calaveras County	PRC 4290-1, NFPA, T-14, PUC 103, ISO and FS Guide	Ordinance 2226 & Resolution 93-11	Ordinance only for new construction														All non-incorporated areas zoned							
Carlsbad	UFC 1991																No zone per letter dated 12/9/94						Meets	
Carmel-by-the-Sea Carpinteria / Summerland Carson ** Cerritos ** Chester FPD	Verbal	Verbal	Roofing ord. Pendino	Class A													Zone defined							
Chico	UFC-version?	Verbal	Weed abatement onlv	Class B																				
Chino Hills	Title IV	Chapter 8.20		Class A			Ordinances 44 & 92-02 and Article 2				1 1/2" wood				Meets			Meets	Meets	Meets			Meets	
Chino Valley FPD	UFC 1991	Resolution 96-1 Agmt A95-84 & Chapter 9.47	Combined with Chino Hills	Class A					Dual-paned glass	Meets			Meets	Meets			Fire Safety Overlay Districts FR1 & FR2						Meets	
Chula Vista	Weed abate, UBC	Verbal		Class C													Withdraw per letter dated 12/1/94						Meets	
Claremont **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets	Fire zone 4 #28	Meets	Meets	Meets			Meets	
Clearlake Oaks	Fire Safe Guide	Verbal	Nothing to mail																					
Clovis	Verbal		All metropolitan																					
Colton	UFC 1991	Ordinances 0-18-90 and 0-15-92	Fire-retardant no wood (Reche Canyon)																					Meets
Colusa	CBC - version?, PRC 4290-SRA	Verbal																						
Commerce ** Contra Costa County	Ordinance 96-8		Zone adoption only														Areas defined by ordinance - 3 zones							
Corte Madera	UFC 1994, UBC 1994			Class A														Meets	Meets	Meets			Meets	
Covelo Covina ** Cudahy **	Verbal		Nothing to mail																					
Culver City **	CFC 1995, UBC, UCADB, UHC, UMC, UPC, NEC, et al 1991	Ordinances 93-008 and 97-014	Zone not adopted	Class B														Fire zone 4 #29-30						Meets
Daly City	UFC, UBC, UHC, UCADB, UMC, UPC, NEC 1991	Ordinance 1157 and City Code		Class B														Zone adopted Southern Hills						Meets
Diamond Bar **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets	Fire zone 4 #31	Meets	Meets	Meets			Meets	
Dougherty Reg.			Dept. not in directorv																					
Duarte **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets	Fire zone 4 #32	Meets	Meets	Meets			Meets	
Dunsmuir	Verbal		Weed Abatement															Zone not adooted						
Ebbetts Pass	UFC 1995, PRC 4117, H&SC 17958, NFPA, County Ordin. #2226	Fire Ordinance 95-1		Class B	Meets			Meets						1/2" min. sheathing				State Responsibility Area- Meets	Meets	Meets				Meets
El Cajon		Letter dated 8/23/94																No zone per CDF letter dated 9/20/94						
El Cerrito		Ordinance 95-1, Article 14 & VMP Sections 8.4.1 through 8.4-8, Weeds		Class B														Areas defined and mapped	Meets	Meets				Meets
El Dorado County FPD			Weed abatement															All SRA except Placerville						Meets
El Dorado Hills	UBC 1991, UFC 1994	Ordinance 30 and Verbal		Class A-residential Class B-commercial																				
El Medio El Monte ** Emeryville	Verbal		Maps pending																					
Escondido	Verbal		Nothing to mail																					
Eureka	UFC 1994, UBC 1994	Verbal	Map on file, need ordinance Strike team defense																					



**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

														FUEL MODIFICATION STANDARDS:										INFORMATION ON PLANS AND SPECIFICATIONS:										STRUCTURAL STAN					
Code Adoptions and References	Local Source	Notes / Response	Access Limit Signage	Sign Installation	Addresses	Address Symbols	Address Installation	Visibility			Hydrant/Fire Valve			Clearance (Structure)	Additional Clearance	Trees	Dead or Dying Wood	Ac-cumulated Vegetation	Chimney & Stovepipe	Setback if >1 acre	if <1 acre	Disposal	Greenbelts	Vicinity Plan	Fire Protection Info in VHFHSZ (GC 51178)					Eaves									
			Nearest intersection or 100' before limit	Prior to acceptance	Required	3' letter height	3/8" stroke	Contrasting color	Permanent posting required at all times	Both directions, even if one-way	Multiple addresses on one post	If industrial site, post at intersection	Must meet min. flow as set forth in latest UFC/UBC for new construction	ID per latest NFPA requirements	30' each side or to property line	30'-100' when needed	10' from chimney	Remove if overhanging structure	Clear roof	Screen <1/2" 30'	Same practical effect	Prior to acceptance	Locate strategically- must be approved	No less than 1"-100'	300' radius showing all street widths	300' radius hydrant plan / min. flow	Location, occupancy class & use of abutting properties	Preliminary fuel modification plan	300' radius showing all street widths	300' radius hydrant plan / min. flow	Location, occupancy class & use of abutting properties	Preliminary fuel modification plan	Final fuel modification plan	1 hour fire resistant, enclosed	Fascias required, must be backed by 1 hour or 2" lumber				
<b>Local Jurisdiction</b>																																							
Folsom	UFC 1994	Weed abatement Ordinance 848	Roofing per UBC	As required by Chief	As required by Chief	Meets		Meets	Meets	Meets		Appendix III-A	As approved by Chief	Meets	Meets	Meets	Meets	Meets	Meets																				
Fontana	UFC 1988	City Code Sec. 5-318 & SBC Ord. 3381		As required by Chief	As required by Chief	Meets		Meets	Meets	Meets				Meets	Meets	Meets	Meets	Meets	Meets																				
Fremont	UFC 1995, UBC 1995	Wildfire Protection brochure		As required by Chief	As required by Chief	Meets		Meets	Meets	Meets				Meets	Meets	Meets	Meets	Meets	Exceeds	Exceeds	Exceeds	Meets																	
Fresno		Verbal	All metropolitan																																				
Galt		Verbal	All SRA/BLM																																				
Garden Valley		Verbal	All SRA																																				
Georgetown		Verbal	Landscape & Hillside Development Guidelines																																				
Glendale		Res. 22.820-1																																					
Glendora **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets		Meets	Meets	Meets				Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets																	
Grass Valley		Verbal	Ordinance pending																																				
Hanford		Verbal	50-60 miles from threat																																				
Hawaiian Gardens **																																							
Hawthorn **																																							
Hayward	UFC 1994, UBC 1994	Interface Guidelines & Resolution 93-037		As required by Chief	As required by Chief	Meets		Meets	Meets	Meets				Meets	Meets	Meets	Meets	Meets	1/4" holes	Meets	Meets	Meets	Recommended																
Healdsburg	UFC 1994	Specific Plan for Area A, Ord. 916 and Verbal		As required by Chief	Meets	Meets		Meets	Meets	Meets				Exceeds	Meets	Meets	Meets	Meets	Meets																				
Hemet		Ordinance 1453	Ordinance for new and existing											Meets	Meets																							Fire resistant	
Hidden Hills **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets		Meets	Meets	Meets				Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets																	
Highland	UFC 1988	Development Code and Ordinance 104		As required by Chief	As required by Chief	Meets		Meets	Meets	Meets				Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets																	
Hillsborough	UFC 1994	Verbal		As required by Chief	Meets	Meets		As required by Chief	As required by Chief	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets																	
Humboldt County		Verbal	Nothing to mail																																				
Huntington Park **																																							
Industry **		Verbal																																					
Irwindale **																																							
Janesville	PRC 4291	Janesville Fire-Safe Plan				Meets		Meets	Meets	Meets				Meets	Meets	Meets	Meets	Meets	Meets																				
Kelseyville		Ordinance 12	Response time											Meets	Meets																								
Kensington		Ordinance 95-1 & VMP												Meets	Meets	Meets	Meets	Meets	Meets																				
Kentfield	UFC 1994, Fire Safe Marin	Verbal	VMP																																				
Kingsburg		Verbal	All metro and farm																																				
La Canada / Flintridge **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets		Meets	Meets	Meets				Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets																	
La Habra Heights		Inspection sheet	Zone not adopted											Meets	30-200' clearance	Meets	Meets	Meets	Meets																				
La Mirada **																																							
La Puente **																																							
La Verne	UFC 1994, LACBC 1996, GC 51178, H&SC 17958.5-7	Chapter 18.68 and Ord. 930	Ordinance passed-will mail	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	300' around new developments																									
Lafayette																																							
Laguna Beach	UFC 1994, UBC, NFPA, Title 14, USC 1994	Verbal		Meets	Meets	Meets		4" height	1/2" stroke	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets																				
Lake County		Verbal																																					
Lake Valley	PRC 4291-SRA	Verbal																																					
Lakeport		Verbal																																					
Lakeshore FPD	UFC 1994	Verbal																																					
Lakeside FPD		Verbal																																					
Lakewood			3 zones per Bates review																																				
Lancaster **																																							
Larkspur	Ch. 14.10		Firebreaks via county open space											Abatement required	Determined by Chief	Meets	Meets			Required																			
Lassen County	PRC 4291	Ordinances 502-B, C, D	New developments		Meets	Meets	Meets	Meets	Meets																														
Lawndale **																																							

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

DARDS														MISCELLANEOUS REQUIREMENTS							
Code Adoptions and References	Local Source	Notes / Response	Roofs	Underfloor Areas	Exception	Unenclosed Accessory Structures	Exception	Underfloor Areas (Attached Structure)	Windows	Doors	Attic Openings	Walls	Underfloor Areas (Detached Structure)	Adoption of Zone	Description of Zone	Topography	Fuels	Accessibility	Evacuation	Rubbish Removal	
			Class B or better	Enclosed to ground	If exposed materials are 1 hour rated	Non-combustible or 1 hour rated	If 100' defensible space, patio roofs > 2"x4" or open lattice > 2"x2" is OK	If over a descending slope, enclose within 6" of ground	Tempered or multi-layered glass	Non-combustible or solid core > 1-3/4"	Not to exceed 144 square inches	Non-combustible corrosion-resistant mesh < 1/4" holes	Not to be in soffits, eave overhangs, etc.	Gable/dormer vents 10' from property line	Any habitable space must be 1 hour rated	If over a descending slope, enclose within 6" of ground	Government Codes 51175-51178	Climatic conditions			Required-all types
<b>Local Jurisdiction</b>																					
Folsom	UFC 1994	Weed abatement Ordinance 848	Roofing per UBC																		Meets
Fontana	UFC 1988	City Code Sec. 5-318 & SBC Ord. 3381	Class A																		Meets
Fremont	UFC 1995, UBC 1995	Wildfire Protection brochure	Fire retardant, no wood																		Meets
Fresno		Verbal	All metropolitan	Class C																	
Galt		Verbal	All SRA/BLM	Class C																	
Garden Valley		Verbal	All SRA	Class C																	
Georgetown		Verbal	Landscape & Hillside Development Guidelines	Class A										Meets							
Glendale		Res. 22.820-1	Hillside Development Guidelines	Class A										Meets							Fire zone 4 #33-35
Glendora **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets
Grass Valley		Verbal	Ordinance pending																		
Hanford		Verbal	50-60 miles from threat																		
Hawaiian Gardens **																					
Hawthorn **																					
Hayward	UFC 1994, UBC 1994	Interface Guidelines & Resolution 93-037	Specific Plan for Area A, Ord. 916 and Verbal	Class A	Meets			Meets	Double pane					Meets	Meets						Area defined, II Categories
Healdsburg	UFC 1994			Class A																	Meets
Hemet		Ordinance 1453	Ordinance for new and existing	Class A	Meets			Meets						Meets	Meets						Fire resistive material
Hidden Hills **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets
Highland	UFC 1988	Development Code and Ordinance 104		Class A		Meets		Meets	Dual-Pane	Solid core				Meets							Meets
Hillsborough	UFC 1994	Verbal																			Meets
Humboldt County		Verbal	Nothing to mail																		
Huntington Park **																					
Industry **		Verbal																			No wood
Irwindale **																					
Janesville	PRC 4291	Janesville Fire-Safe Plan																			Meets
Kelseyville		Ordinance 12	Response time																		
Kensington		Ordinance 95-1 & VMP		Class B																	Meets
Kentfield	UFC 1994, Fire Safe Marin	Verbal	VMP	Class A																	Meets
Kingsburg		Verbal	All metro and farm																		
La Canada / Flintridge **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets
La Habra Heights		Inspection sheet	Zone not adopted																		Meets
La Mirada **																					
La Puente **																					
La Verne	UFC 1994, LACBC 1996, GC 51178, H&SC 17958.5-7	Chapter 18.68 and Ord. 930	Ordinance passed-will mail	Class A or B, 25% replace	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	5' from property line	Meets	Meets	Meets	Meets	Meets
Lafayette																					
Laguna Beach	UFC 1994, UBC, NFPA, Title 14, USC 1994	Ordinance 1310, 1311, Inspection sheet		Class A	Meets			Meets						1/2" min. sheathing							Meets
Lake County		Verbal		Class B																	
Lake Valley	PRC 4291-SRA	Verbal																			
Lakeport		Verbal																			
Lakeshore FPD	UFC 1994	Verbal																			
Lakeside FPD		Verbal	3 zones per Bates review																		
Lakewood																					
Lancaster **																					
Larkspur		Ch. 14.10	Firebreaks via county open space																		
Lassen County	PRC 4291	Ordinances 502-B, C, D	New development	No new wood																	Meets
Lawndale **																					

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

					ROAD STANDARDS FOR FIRE EQUIPMENT ACCESS:															STANDARDS FOR SIGNING STREETS, ROADS, BLDGS.																							
Code Adoptions and References	Local Source	Notes / Response	AB 337 Mandate Status	Width	Surface	Grades	Horizontal Inside Radius	Vertical Curves	Turn-arounds	Hammer-head/"T"	Turnouts	Roadway Structures (Bridges)	Bridge Signage	One-way Roads	Dead-end Roads	<1 acre parcels	1-4.99 acre parcels	5-19.99 acre parcels	20+ acre parcels	Driveways	If >150' but <800'	If >800'	If >300'	Gate Entrances	If one-way	Sign Symbols	Visibility	Height	Names /Numbers	Intersections													
<b>Local Jurisdiction</b>				Two 9' lanes, 13' 6" vertical clearance	40,000 lb. Load	Not to exceed 16%	No less than 50'	100'	Required, 40' from center	Top of "T" 60' long	10' x 30'	25' taper each end	Load & clearance per VCS 35550, 35750, 35250	Load, clearance, one-way, single lane	One 10' lane	Must connect to 2 lanes at each end	Serve no more than 10 dwellings	Not to exceed 2640'	Turnout at midpoint	Not to exceed:	800'	1320'	2640' with turnaround at 1320'	5280' w/ turnaround at 1320' intervals	10' wide, 15' vertical clearance	Turnout at midpoint	Every 400'	Turnaround w/in 50' of all building sites	2' wider than lane	30' from roadway	40' turning radius	3" letter height	3/8" stroke	Reflector-ized	Contrast in color	100' both directions	Uniform	Required	Signs required				
Livermore/Pleasanton	UBC, NFPA-299	Sections 20.08.040 - 20.08.050	EX	24' wide, 15' vertical	Meets	As approved by Chief	Meets	Meets	Meets	40' long			Meets							Turnouts as required	Turnouts as required	Turnouts as required	Turnouts as required	12' wide 15' vertical	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets				
Lomita **			No zone																																								
Los Angeles	LACBC 1996, UFC 1994	MC 57 21.01-07, Ord. 171551, Res. 550 & 561	120																																								
Los Angeles County **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	Title 26 & Fuel modification plan guidelines	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	Every 1/2 mile	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets																												
Madera County		See Merced County - CDF																																									
Malibu **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets																													
Mammoth Lakes	UBC Section 3204		USFS team effort for def. space	120																																							
Mammoth Lakes FPD		Building Code		120																																							
Marin County	UBC, UFC 1994, PRC 4290-4291	County Building Code, UFC (Ch. 16-16)	EX	Meets	Meets	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets																													
Mariposa County		Verbal	All Wildland-SRA?	No zone																																							
Maywood **				No zone																																							
Merced		Verbal		No zone	Meets																																						
Merced County	UFC 1994-App IIA, PRC 4290	Merced Vision 2015, Verbal		No zone																																							
Mill Valley	UFC 1994	Municipal Code 15-2	60' wide, 4 mile long fire break	ME	Meets	Meets	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets																												
Modoc County		Fire Safe Regs for SRA	Ordinance only for new development	No zone	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets
Mono County	PRC 4290, GC 51178-51189, HSC 13108.5, 13132.7	Chapter 19.26		No zone																																							
Monrovia	UFC 1994, UBC, NFPA-299	Sections 1115 and 26		120	Meets	Meets	Meets	Meets	Meets	40' per NFPA 299	Meets	As approved by Chief	Sufficient fire apparatus load	Meets																													
Montecito	UFC 1994, Title 19, PRC 4291	VMP Standard 93-1	Inmate crews in SRA	ME	Meets	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets																													
Monterey	Title 24-25, H&SC 17958, UFC 1994, UBC 1994 and others			120	Meets	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets																													
Monterey County	PRC 4117, 4290	Ordinance 3600, 1241	Ordinance for SRA	No zone	Meets	Sufficient Fire apparatus load	Exceeds	Meets	Meets	Meets	Meets	Exceeds	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets
Moraga-Orinda	UFC, UBC - versions?	Bates Bill Notice on website and Ord. 97-3 Ch 8.24 & Ordinance 095	No high hazard, just threat area	No zone																																							
Napa				No zone																																							
Napa County	UFC, UBC 1994, PRC 4291	Verbal		No zone																																							
Nevada City	UFC 1994	See Nevada County		No zone	Meets	Meets	Meets	Meets	Meets	Meets	As approved by Chief	As approved by Chief	20 ton load	Meets																													
Nevada County	UFC 1994, PRC 4291	Verbal and VMP Program outline		No zone	Meets	Meets	Meets	Meets	Meets	Meets	As approved by Chief	As approved by Chief	20 ton load	Meets																													
Newark			All metropolitan	EX																																							
No. County FPD	UFC 1991, NFPA 13, D, 13-R	Ordinance 92-1		ME	Exceeds	Meets	15-20%	As approved by Chief	As approved by Chief	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	Meets																												
North Tahoe FPD		Verbal		120																																							
Norwalk **		Verbal	Evaluating CA Fire Plan	ME																																							
Novato				No zone																																							
Oakland	Title 24, UBC 1988, UPC, UMC 1979	Ordinances 11485 and 10798		EX																																							
Orange	UFC 1991	Ordinances 87 & 14-92		ME	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets																													
Orange County				120																																							
Oroville		Ordinance 1575	No zone ID'd	ME																																							
Pacific Grove		Verbal		120																																							
Pacifica		Verbal	New hillside development not allowed	120																																							
Palmdale **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets																													

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

														FUEL MODIFICATION STANDARDS:										INFORMATION ON PLANS AND SPECIFICATIONS:										STRUCTURAL STAN					
Code Adoptions and References	Local Source	Notes / Response	Access Limit Signage	Sign Installation	Addresses	Address Symbols	Address Installation	Visibility				Hydrant/Fire Valve		Clearance (Structure)	Additional Clearance	Trees	Dead or Dying Wood	Accumulated Vegetation	Chimney & Stovepipe	Setback if >1 acre	If <1 acre	Disposal	Greenbelts	Vicinity Plan	Fire Protection Info in VHFHSZ (GC 51178)					Eaves									
			Nearest intersection or 100' before limit	Prior to acceptance	Required	3' letter height	3/8" stroke	Contrasting color	Permanent posting required at all times	Both directions, even if one-way	Multiple addresses on one post	If industrial site, post at intersection	Must meet min. flow as set forth in latest UFG/UBC for new construction	ID per latest NFPA requirements	30' each side or to property line	30'-100' when needed	10' from chimney	Remove if overhanging structure	Clear roof	Screen <1/2" 30'	Same practical effect	Prior to acceptance	Locate strategically - must be approved	No less than 1"=100'	300' radius showing all street widths	300' radius hydrant plan / min. flow	Location, occupancy class & use of abutting properties	Preliminary fuel modification plan	300' radius showing all street widths	300' radius hydrant plan / min. flow	Location, occupancy class & use of abutting properties	Preliminary fuel modification plan	Final fuel modification plan	1 hour fire resistant, enclosed	Fascias required, must be backed by 1 hour or 2" lumber				
<b>Local Jurisdiction</b>																																							
Livermore/Pleasanton	UBC, NFPA-299	Sections 20.08.040 - 20.08.050		Meets	Meets	Meets	4" height	1/2" stroke	Meets	Meets	Meets		Sprinklers required	Meets																							1/2" min. Enclosed		
Lomita **																																							
Los Angeles	LACBC 1996, UFC 1994	MC 57.21.01-07, Ord. 171551, Res. 550 & 561												Exceeds	Exceeds (up to 200')	Meets	Meets	Meets							Meets														
Los Angeles County **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	Title 26 & Fuel modification plan guidelines	Ordinance only for new construction	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Exceeds	Exceeds = 200'	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	200' minimum	Meets									Meets	Meets		
Madera County		See Merced County - CDF																																					
Malibu **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	200' minimum	Meets										Meets	Meets		
Mammoth Lakes	UBC Section 3204		USFS team effort for def. space																																				
Mammoth Lakes FPD		Building Code																																					
Marin County	UBC, UFC 1994, PRC 4290-4291	County Building Code, UFC (Ch. 16-16)		As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.									
Mariposa County		Verbal	All Wildland-SRA?																																				
Maywood **																																							
Merced County	UFC 1994-App IIA, PRC 4290	Merced Vision 2015, Verbal																																					
Mill Valley	UFC 1994	Municipal Code 15-2	60' wide, 4 mile long fire break	As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.									
Modoc County		Fire Safe Regs for SRA	Ordinance only for new development	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets			Submit plan before constr.												
Mono County	PRC 4290, GC 51178-51189, HSC 13108.5, 13132.7	Chapter 19.26																																					
Monrovia	UFC 1994, UBC, NFPA-299	Sections 1115 and 26		Meets	Meets	Meets	4" height	1/2" stroke	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Exceeds	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets													1/2" min. Enclosed		
Montecito	UFC 1994, Title 19, PRC 4291	VMP Standard 93-1	Inmate crews in SRA	As required by Chief	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets			Submit plan before constr.	Submit plan before constr.											
Monterey	Title 24-25, H&SC 17958, UFC 1994, UBC 1994 and others			Meets	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets															
Monterey County	PRC 4117, 4290	Ordinance 3600, 1241	Ordinance for SRA	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets															
Moraga-Orinda	UFC, UBC - versions?	Bates Bill Notice on website and Ord. 97-3 Ch 8.24 & Ordinance 095	No high hazard, just threat area																																				
Napa		095																																					
Napa County	UFC, UBC 1994, PRC 4291	Verbal												Meets																									
Nevada City	UFC 1994	See Nevada County		As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	
Nevada County	UFC 1994, PRC 4291	Verbal and VMP Program outline		As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	County land use rules	
Newark			All metropolitan																																				
No. County FPD	UFC 1991, NFPA 13, D, 13-R	13- Ordinance 92-1		As required by Chief	Meets	Meets	Meets	As required by Chief	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Access plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.									
North Tahoe FPD		Verbal																																					
Norwalk **																																							
Novato		Verbal	Evaluating CA Fire Plan																																				
Oakland	Title 24, UBC 1988, UPC, UMC 1979	Ordinances 11485 and 10798			Meets	Meets	2"		Meets	Meets			Meets																										Meets
Orange	UFC 1991	Ordinances 87 & 14-92		As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets		Appendix III-A	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Access plan before constr.	Submit plan before constr.	Submit plan before constr.		Grading permit requirement				Grading permit requirement	Building permit requirement					
Orange County																																							
Oroville		Ordinance 1575	No zone ID'd																																				
Pacific Grove		Verbal																																					
Pacifica		Verbal	New hillside development not allowed																																				
Palmdale **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets														Meets	Meets

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

DARDS														MISCELLANEOUS REQUIREMENTS										
Code Adoptions and References	Local Source	Notes / Response	Roofs	Underfloor Areas	Exception	Unenclosed Accessory Structures	Exception	Underfloor Areas (Attached Structure)	Windows	Doors	Attic Openings	Walls	Underfloor Areas (Detached Structure)	Adoption of Zone	Description of Zone	Topography	Fuels	Accessibility	Evacuation	Rubbish Removal				
			Class B or better	Enclosed to ground	If exposed materials are 1 hour rated	Non-combustible or 1 hour rated	If 100' defensible space, patios, roofs > 2"x4" or open lattice > 2"x2" is OK	If over a descending slope, enclose within 6" of ground	Tempered or multi-layered glass	Non-combustible or solid core > 1-3/4"	Not to exceed 144 square inches	Non-combustible corrosion-resistant mesh < 1/4" holes	Not to be in soffits, eave overhangs, etc.	Gable/dormer vents 10' from property line	Any habitable space must be 1 hour rated	If over a descending slope, enclose within 6" of ground	Government Codes 51175-51178	Climatic conditions	Topography	Fuels	Accessibility	Evacuation	Required-all types	
<b>Local Jurisdiction</b>																								
Livermore/Pleasanton	UBC, NFPA-299	Sections 20.08.040 - 20.08.050		Meets				Meets						1/2" min. Sheathing										Areas defined
Lomita **																								Mountain & Buffer Fire District
Los Angeles	LACBC 1996, UFC 1994	MC 57.21.01-07, Ord. 171551, Res. 550 & 561	No wood																					Fire zone 4 #1-17 - Very High pending (uninc only)
Los Angeles County **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	Title 26 & Fuel modification plan guidelines	Class A	Meets	Meets	Meets	Exceeds	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	
Madera County		See Merced County - CDF																						
Malibu **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets									Fire zone 4 #42
Mammoth Lakes	UBC Section 3204		Class A																					
Mammoth Lakes FPD		Building Code	Class A																					
Marin County	UBC, UFC 1994, PRC 4290-4291	County Building Code, UFC (Ch. 16.16)	Class A																					Areas per CDF recommendations
Mariposa County		Verbal																						
Maywood **			Non-combustible																					
Merced		Verbal																						
Merced County	UFC 1994-App IIA, PRC 4290	Merced Vision 2015, Verbal																						
Mill Valley	UFC 1994	Municipal Code 15-2	Class A																					
Modoc County		Fire Safe Regs for SRA	Class A no wood																					SRA area only
Mono County	PRC 4290, GC 51178-51189, HSC 13108.5, 13132.7	Chapter 19.26																						
Monrovia	UFC 1994, UBC, NFPA-299	Sections 1115 and 26	Fire retardant	Meets				Meets						1/2" min. sheathing										Fire Zone 4 #43
Montecito	UFC 1994, Title 19, PRC 4291	VMP Standard 93-1																						
Monterey	UFC 1994, H&SC 17958, UFC 1994, UBC 1994 and others	Title 24-25, VMP Program	Class A											Meets										Zone not adopted
Monterey County	PRC 4117, 4290	Ordinance 3600, 1241																						
Moraga-Orinda	UFC, UBC - versions?	Bates Bill Notice on website and Ord. 97-3 Ch 8.24 & Ordinance 095	Class A																					Zone adopted and defined
Napa		095 No high hazard, just clearing standards	Class B																					
Napa County	UFC, UBC 1994, PRC 4291	Verbal	Class B																					
Nevada City	UFC 1994	See Nevada County																						
Nevada County	UFC 1994, PRC 4291	Verbal and VMP Program outline																						
Newark																								Weed Abatement
No. County FPD	UFC 1991, NFPA 13, D, 13-R	Ordinance 92-1	Class B																					Withdraw per letter dated 12/6/94
North Tahoe FPD		Verbal	Class A																					?
Norwalk **																								
Novato		Verbal																						
Oakland	Title 24, UBC 1988, UPC, UMC 1979	Ordinances 11485 and 10798				Meets																		
Orange	UFC 1991	Ordinances 87 & 14-92	Class A	Meets	Meets	Meets		Meets																
Orange County																								
Oroville		Ordinance 1575																						
Pacific Grove		Verbal																						
Pacifica		Verbal																						
Palmdale **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets									Fire zone 4 #44-49 (zone reclass pending)

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

					ROAD STANDARDS FOR FIRE EQUIPMENT ACCESS:																	STANDARDS FOR SIGNING STREETS, ROADS, BLDGS.																				
Code Adoptions and References	Local Source	Notes / Response	AB 337 Mandate Status	Width	Surface	Grades	Horizontal Inside Radius	Vertical Curves	Turn-arounds	Hammer-head/"T"	Turnouts	Roadway Structures (Bridges)	Bridge Signage	One-way Roads	Dead-end Roads	<1 acre parcels	1-4.99 acre parcels	5-19.99 acre parcels	20+ acre parcels	Driveways	If >150' but <800'	If >800'	If >300'	Gate Entrances	If one-way	Sign Symbols	Visibility	Height	Names /Numbers	Intersections												
<b>Local Jurisdiction</b>				Two 9' lanes, 13' 6" vertical clearance	40,000 lb. Load	Not to exceed 16%	No less than 50'	100'	Required, 40' from center	Top of "T" 60' long	10' x 30'	25' taper each end	Load & clearance per VCS 35550, 35750, 35250	Load, clearance, one-way, single lane	One 10' lane	Must connect to 2 lanes at each end	Serve no more than 10 dwellings	Not to exceed 2640'	Turnout at midpoint	Not to exceed:	800'	1320'	2640' with turnaround at 1320'	5280' w/ turnaround at 1320' intervals	10' wide, 15' vertical clearance	Turnout at midpoint	Every 400'	Turnaround w/in 50' of all building sites	2' wider than lane	30' from roadway	40' turning radius	3" letter height	3/8" stroke	Reflector-ized	Contrasting color	100' both directions	Uniform	Required	Signs required			
<b>Palmdale **</b>	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required						Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief			
<b>Palos Verdes Estates **</b>				120																																						
<b>Paradise</b>		Verbal		ME																																						
<b>Paramount **</b>		Verbal		No zone																																						
<b>Peninsula FPD</b>				No zone																																						
<b>Petaluma</b>	UFC 1991, UFC 1994 App. IIA	Municipal Code and UFC adoption	UFC 1997 pending	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	Meets				Meets	Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief		
<b>Pico Rivera **</b>				No zone																																						
<b>Piedmont</b>	City Code, UFC 1994+	Ch. 8 - Fire Prevention	New construction only	EX	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required					Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	
<b>Pinole</b>		Verbal		EX																																						
<b>Pioneer</b>	PRC 4290-SRA	Verbal	All SRA	No zone																																						
<b>Placer County</b>			1997 UFC pending	No zone																																						
<b>Plumas County</b>				No zone																																						
<b>Pomona **</b>	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required					Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	
<b>Poway</b>	Weed abate, UBC 1991	Weed Abatement notice		ME																																						
<b>Quincy</b>		Verbal	Planning in process	No zone																																						
<b>Rancho Cucamonga</b>	UFC 1991,	Hillside Development & Ord. 22		ME	26' wide, 14' 6" vertical	70,000 lb.	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Not to exceed 600'	Turnouts Required	Turnouts Required	Turnouts Required	Meets				Meets	Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	Meets	As required by Chief										
<b>Rancho Palos Verdes **</b>				120																																						
<b>Redding</b>	UFC App IIA, UBC-Versions? 2148	Ordinance		120																																						
<b>Redlands</b>	UFC 1991, UBC 1991, UAC, UHC, UCADB	Ordinances 2188 & 2194		ME	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	Meets				Meets	Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	
<b>Rescue FPD</b>		Verbal	All SRA	No zone																																						
<b>Richmond</b>		Ordinance 16-98, Res. 192-95		120																																						
<b>Riverside County</b>	PRC 4290	Verbal		EX																																						
<b>Riverview</b>				EX																																						
<b>Rocklin</b>	UFC 1994	Verbal		No zone																																						
<b>Rodeo-Hercules</b>	PRC 4290-SRA, HSC Title 5	Verbal		EX																																						
<b>Rolling Hills **</b>				120																																						
<b>Rolling Hills Estates **</b>				120																																						
<b>Rosemead **</b>				No zone																																						
<b>Roseville</b>		Verbal		No zone																																						
<b>Ross Valley</b>	UFC 1994	Verbal		ME																																						
<b>Sacramento County</b>	UFC 1994, UBC 1994	Building Code Ch. 16.04, 17.04		120	Meets	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	13' 6" vertical				Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
<b>Salinas</b>		Verbal	Nothing to mail	No zone																																						
<b>Salinas Rural</b>	UFC 1994, UBC, NFPA 291, H&SC 13132, County Ord. #3600			120	Meets	Meets	Meets	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600	Monterey Co. Ordin. 3600		
<b>Samoa Peninsula</b>		Verbal		No zone																																						
<b>San Benito County</b>		Verbal		No zone																																						
<b>San Bernardino</b>	UFC 1991, NFPA 13	Ord. MC-882 & FF District Chapter 19.15		ME	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required	Meets				Meets	Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	
<b>San Bernardino County</b>	UBC, UFC 1988	Article 2 & Ord. 3381		ME	Exceeds	Meets	Exceeds	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		350-600'	350-600'	Turnouts required	Turnouts required				Not to exceed 150'				As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
<b>San Diego County</b>	UFC 1988	Verbal		No zone	Exceeds	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets									See road standards				As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
<b>San Dimas **</b>	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	120	Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets		Turnouts required	Turnouts required	Turnouts required	Turnouts required					Per UBC		As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief
<b>San Marcos</b>	UBC 1991	Ordinance 94-964		ME			</																																			

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

													FUEL MODIFICATION STANDARDS:										INFORMATION ON PLANS AND SPECIFICATIONS:										STRUCTURAL STANDARDS:							
Code Adoptions and References	Local Source	Notes / Response	Access Limit Signage	Sign Installation	Addresses	Address Symbols	Address Installation	Visibility		Hydrant/Fire Valve			Clearance (Structure)	Additional Clearance	Trees	Dead or Dying Wood	Accumulated Vegetation	Chimney & Stovepipe	Setback if >1 acre	if <1 acre	Disposal	Greenbelts	Vicinity Plan	Fire Protection Info in VHFHSZ (GC 51178)					Eaves											
			Nearest intersection or 100' before limit	Prior to acceptance	Required	3' letter height	3/8" stroke	Contrasting color	Permanent posting required at all times	Both directions, even if one-way	Multiple addresses on one post	If industrial site, post at intersection	Must meet min. flow as set forth in latest UFC/UBC for new construction	ID per latest NFPA requirements	30' each side or to property line	30'-100' when needed	10' from chimney	Remove if overhanging structure	Clear roof	Screen <1/2" 30'	Same practical effect	Prior to acceptance	Locate strategically - must be approved	No less than 1"-100'	300' radius showing all street widths	300' radius hydrant plan / min. flow	Location, occupancy class & use of abutting properties	Preliminary fuel modification plan	300' radius showing all street widths	300' radius hydrant plan / min. flow	Location, occupancy class & use of abutting properties	Preliminary fuel modification plan	Final fuel modification plan	1 hour fire resistant, enclosed	Fascias required, must be backed by 1 hour or 2" lumber					
<b>Local Jurisdiction</b>																																								
Palmdale **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets													Meets	Meets			
Palos Verdes Estates **		Verbal																																						
Paradise		Verbal																																						
Paramount **		Verbal																																						
Peninsula FPD		Verbal																																						
Petaluma	UFC 1991, UFC 1994 App. IIA	Municipal Code and UFC adoption	UFC 1997 pending	As required by Chief	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.												
Pico Rivera **																																								
Piedmont	City Code, UFC 1994+	Ch. 8 - Fire Prevention	New construction only	As required by Chief	As required by Chief	Meets		Meets	Meets	Meets			Meets	Per UFC	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.												
Pinole		Verbal																																						
Pioneer	PRC 4290-SRA	Verbal	All SRA																																					
Placer County																																								
Plumas County																																								
Pomona **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets																	
Poway	Weed abate, UBC 1991	Weed Abatement notice																																						
Poway	Weed abate, UBC 1991	Weed Abatement notice																																						
Quincy		Verbal	Planning in process																																					
Rancho Cucamonga	UFC 1991,	Hillside Development & Ord. 22		As required by Chief	Meets	Meets		As required by Chief	As required by Chief	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Access plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.										Meets		
Rancho Palos Verdes **																																								
Redding	UFC App IIA, UBC-Versions? 2148	Ordinance																																						
Redlands	UFC 1991, UAC, UHC, UCADB	Ordinances 2188 & 2194		As required by Chief	Meets	Meets		As required by Chief	As required by Chief	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Access plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.												
Rescue FPD		Verbal	All SRA																																					
Richmond		Ordinance 16-96, Res. 192-95																																						
Riverside County	PRC 4290	Verbal																																						
Riverview																																								
Rocklin	UFC 1994	Verbal																																						
Rodeo-Hercules	PRC 4290-SRA, HSC Title 5	Verbal																																						
Rolling Hills **																																								
Rolling Hills Estates **																																								
Rosemead **																																								
Roseville		Verbal																																						
Ross Valley	UFC 1994	Verbal																																						
Sacramento County	UFC 1994, UBC 1994	Building Code Ch. 16.04, 17.04		As required by Chief	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets																		
Salinas		Verbal	Nothing to mail																																					
Salinas Rural	UFC 1994, UBC, NFPA 291, H&SC 13132, County Ordin. #3600			Meets	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets																		
Samoa Peninsula		Verbal																																						
San Benito County		Verbal																																						
San Bernardino	UFC 1991, NFPA 13	Ord. MC-882 & FF District Chapter 19.15		As required by Chief	Meets	Meets		As required by Chief	As required by Chief	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Access plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.											Meets	
San Bernardino County	UBC, UFC 1988	Article 2 & Ord. 3381		As required by Chief	As required by Chief	Meets		Meets	Meets	Meets			Appendix III-A	As approved by Chief	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	1"=200'																Meets	Meets
San Diego County	UFC 1988	Verbal		As required by Chief	As required by Chief	Meets		Meets	Meets	Meets			Table 10.301h	As approved by Chief	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets																		
San Dimas **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets																	
San Marcos	UBC 1991	Ordinance 94-964																																						
San Marino	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets		Meets	Meets	Meets			Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets																	
San Miguel		Verbal																																						
San Rafael	UFC 1994, Fire Safe Marin	Ordinance 1682	No annual program	As required by Chief	Meets	Meets		As required by Chief	As required by Chief	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.												
Sanger		Verbal																																						

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

DARDS																	MISCELLANEOUS REQUIREMENTS						
Code Adoptions and References	Local Source	Notes / Response	Roofs	Underfloor Areas	Exception	Unenclosed Accessory Structures	Exception	Underfloor Areas (Attached Structure)	Windows	Doors	Attic Openings		Walls	Underfloor Areas (Detached Structure)	Adoption of Zone	Description of Zone	Topography	Fuels	Accessibility	Evacuation	Rubbish Removal		
			Class B or better	Enclosed to ground	If exposed materials are 1 hour rated	Non-combustible or 1 hour rated	If 100' defensible space, patio roofs > 2"x4" or open lattice > 2"x2" is OK	If over a descending slope, enclose within 6" of ground	Tempered or multi-layered glass	Non-combustible or solid core > 1-3/4"	Not to exceed 144 square inches	Non-combustible corrosion-resistant mesh < 1/4" holes	Not to be in soffits, eave overhangs, etc.	Gable/dormer vents 10' from property line	Any habitable space must be 1 hour rated	If over a descending slope, enclose within 6" of ground	Government Codes 51175-51178	Climatic conditions				Required-all types	
<b>Local Jurisdiction</b>																							
Palmdale **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets	??	Meets	Meets	Meets	Meets	Meets	
Palos Verdes Estates **		Verbal															Fire zone 4 #50						
Paradise		Verbal		Class A																			
Paramount **		Verbal		Class B													Areas defined and mapped					Meets	
Peninsula FPD																							
Petaluma	UFC 1991, UFC 1994 App. IIA	Municipal Code and UFC adoption	UFC 1997 pending	Class B																			
Pico Rivera **																							
Piedmont	City Code, UFC 1994+	Ch. 8 - Fire Prevention	New construction only														Threat Zone					Meets	
Pinole		Verbal		No wood																		Weed Abatement	
Pioneer	PRC 4290-SRA	Verbal	All SRA																				
Placer County																							
Plumas County																							
Pomona **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets	Fire zone 4 #53	Meets	Meets	Meets	Meets	Meets	
Poway	Weed abate, UBC 1991	Weed Abatement notice		Class A													Withdraw per letter dated 10/3/94					Meets	
Quincy		Verbal	Planning in process																				
Rancho Cucamonga	UFC 1991,	Hillside Development & Ord. 22		Non-combustible materials	Meets									Non-combustible								Meets	
Rancho Palos Verdes **																	Fire zone 4 #54						
Redding	UFC App IIA, UBC-Versions? 2148	Ordinance 2148		Class A and Certificate													Meets						
Redlands	UFC 1991, UBC 1991, UAC, UHC, UCADB	Ordinances 2188 & 2194																Meets	Meets			Meets	
Rescue FPD		Verbal	All SRA																				
Richmond		Ordinance 16-96, Res. 192-95		Class B, no wood													Meets					Meets	
Riverside County	PRC 4290	Verbal		Class A																			
Riverview																							
Rocklin	UFC 1994	Verbal		Class C																			
Rodeo-Hercules	PRC 4290-SRA, HSC Title 5	Verbal		Class A	Meets	Meets	Meets															Weed Abatement	
Rolling Hills **																	Fire zone 4 #55						
Rolling Hills Estates **																	Fire zone 5 #56-57						
Rosemead **																							
Roseville		Verbal															High Hazard areas defined					Weed abatement	
Ross Valley	UFC 1994	Verbal																					
Sacramento County	UFC 1994, UBC 1994	Building Code Ch. 16.04, 17.04		Class A													Meets	Meets	Meets	Meets	Meets	Meets	
Salinas		Verbal	Nothing to mail																				
Salinas Rural	UFC 1994, UBC, NFPA 291, H&SC 13132, County Ordin. #3600			Class B														Meets	Meets	Meets		Meets	
Samoa Peninsula		Verbal																				Weed abatement	
San Benito County		Verbal															High hazard areas mapped						
San Bernardino	UFC 1991, NFPA 13	Ord. MC-882 & FF District Chapter 19.15		Non-combustible, no wood	Meets	Meets	Meets	Encased non-combustible	Meets				Meets	Not to face wildland	Meets							Meets	
San Bernardino County	UBC, UFC 1988	Article 2 & Ord. 3381		Class A	Meets	Meets											Fire Safety Overlay Dist.		Meets			Meets	
San Diego County	UFC 1988	Verbal															Zone adopted		Meets	Meets		Meets	
San Dimas **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets	Fire zone 4 #58-59	Meets	Meets	Meets	Meets	Meets	
San Marcos	UBC 1991	Ordinance 94-964		Class C													Withdraw per letter dated 7/27/94						
San Marino	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets	Fire zone 4 #62	Meets	Meets	Meets	Meets	Meets	
San Miguel		Verbal																					
San Rafael	UFC 1994, Fire Safe Marin	Ordinance 1682	No annual program	Class A													Areas defined and mapped	Meets	Meets	Meets	Meets	Meets	
Sanger		Verbal																				Some weed abatement	



**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

														FUEL MODIFICATION STANDARDS:										INFORMATION ON PLANS AND SPECIFICATIONS:										STRUCTURAL STAN				
Code Adoptions and References	Local Source	Notes / Response	Access Limit Signage	Sign Installation	Addresses	Address Symbols	Address Installation	Visibility			Hydrant/Fire Valve			Clearance (Structure)	Additional Clearance	Trees	Dead or Dying Wood	Accumulated Vegetation	Chimney & Stovepipe	Setback if >1 acre	if <1 acre	Disposal	Greenbelts	Vicinity Plan	Fire Protection Info in VHFHSZ (GC 51178)					Eaves								
			Nearest intersection or 100' before limit	Prior to acceptance	Required	3' letter height	3/8" stroke	Contrasting color	Permanent posting required at all times	Both directions, even if one-way	Multiple addresses on one post	If industrial site, post at intersection	Must meet min. flow as set forth in latest UFC/UBC for new construction	ID per latest NFPA requirements	30' each side or to property line	30'-100' when needed	10' from chimney	Remove if overhanging structure	Clear roof	Screen <1/2" 30'	Same practical effect	Prior to acceptance	Locate strategically - must be approved	No less than 1"=100'	300' radius showing all street widths	300' radius hydrant plan / min. flow	Location, occupancy class & use of abutting properties	Preliminary fuel modification plan	300' radius showing all street widths	300' radius hydrant plan / min. flow	Location, occupancy class & use of abutting properties	Preliminary fuel modification plan	Final fuel modification plan	1 hour fire resistant, enclosed	Fascias required, must be backed by 1 hour or 2" lumber			
<b>Local Jurisdiction</b>																																						
Santa Barbara County	UFC 1988, UBC 1985, NFPA 24 & 13-D	Dev. Reg. 1, Standards 2A, 2 B, 3, 3A, 5		County Code Ch. 35	County Code Ch. 35	Meets	Meets	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets			300' radius showing all street widths												
Santa Clarita **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets			200' minimum	Meets		200' minimum	Meets	Meets	Meets	Meets	Meets	Meets		
Santa Rosa		Pamphlet & Section 1503.4	VMP via self-inspection									2500 GPM or residential sprinkler		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets															
Santee	Fire Safe Guide 1980, USFS Field Guide 1980, UBC 1988	Ordinance 275																																				
Sausalito	NFPA 13-D, UFC 1995	Section 8.04-8.42		As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.								
Seaside		Verbal	Nothing to mail																																			
Selma		Verbal	All metropolitan																																			
Shasta County	PRC 4290, 4291													Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets															
Shasta Lake FPD	UFC 1994	Ordinance 97-1		Meets	Meets	Meets	Exceeds	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets
Sierra Madre	UBC 1991	Ch. 15.04												Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets														Meets	
Signal Hill **																																						
Solana Beach		Letter dated 10/25/94																																				
Sonoma County			Fire Safe Sonoma																																			
South County		Verbal	Listed in error as VHFHSZ																																			
South El Monte **																																						
South Gate **																																						
South Lake Tahoe		Verbal	No ordinance																																			
South Pasadena	UFC 1994, UBC	Ordinance 2040		Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets	Per UFC	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.						Meets	Meets	
South Placer	H&SC 13146, Title 24	Ordinance #1-1995-6																																				
Susanville		Verbal	Nothing to mail																																			
Taft	UFC 1994 Sect. 1103.2	FD Policies & Procedures																																				
Tamalpais	PRC 4291-SRA	Verbal																																				
Temple City **																																						
Tiburon		Verbal	No threat Zone ID'd in error																																			
Torrance																																						
Truckee	Title 24, H&SC 13146	Res. 1-94, Ord. 1-96	Inspection Checklist											Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets															
Ukiah City	PRC 4290	Inspection Checklist	VMP only											Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets															
Universal	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets		200' minimum	Meets		200' minimum	Meets	Meets	Meets	Meets	Meets	Meets	Meets	
Upland	UFC 1991, UBC 1988	Public Safety Sec. 3100 & Article VIII		As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Access plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.								
Ventura County	UFC 1994, HSC 13869, Div. 12, CBC 1995	Ordinance 22, "Wildland Fire Unit"		As required by Chief	Meets	Meets	Meets	Meets	Meets	Meets		Meets, Spinklers req'd @ >5 miles from station	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Submit plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.								
Victorville	UFC 1991, UBC 1991, UCADB 1991	Ordinances 1581 & 1585		As required by Chief	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Appendix III-A	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Access plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.								
Vista	UFC 1991, NFPA 13-D, 13-R, SRA Fire Safe Regs, USFS 1980 Guide	Ch. 8.60, 16.40		As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Access plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.								
Walnut **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets		200' minimum	Meets		200' minimum	Meets	Meets	Meets	Meets	Meets	Meets		
West Covina	Engineering Department Standards	Division 2 - Zoning																		25' from slope	25' from slope				Plan required	Show roads	Structures in open space	Show landscape	Show roads	Structures in open space	Show landscape	Meets						
West Hollywood **																																						
Westlake Village **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets		200' minimum	Meets		200' minimum	Meets	Meets	Meets	Meets	Meets	Meets		
Westwood	UFC 1994, UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets		200' minimum	Meets		200' minimum	Meets	Meets	Meets	Meets	Meets	Meets		
Whittier **	UFC 1994, UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Ordinance only for new construction	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets		Meets		200' minimum	Meets		200' minimum	Meets	Meets	Meets	Meets	Meets	Meets		
Yreka	UBC 1994	Ordinance 708, UBC 1502-1504																																				

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

DARDS														MISCELLANEOUS REQUIREMENTS										
Code Adoptions and References	Local Source	Notes / Response	Roofs	Underfloor Areas	Exception	Unenclosed Accessory Structures	Exception	Underfloor Areas (Attached Structure)	Windows	Doors	Attic Openings	Walls	Underfloor Areas (Detached Structure)	Adoption of Zone	Description of Zone	Rubbish Removal								
			Class B or better	Enclosed to ground	If exposed materials are 1 hour rated	Non-combustible or 1 hour rated	If 100' defensible space, patio roofs > 2"x4" or open lattice > 2"x2" is OK	If over a descending slope, enclose within 6" of ground	Tempered or multi-layered glass	Non-combustible or solid core > 1-3/4"	Not to exceed 144 square inches	Non-combustible corrosion-resistant mesh < 1/4" holes	Not to be in soffits, eave overhangs, etc.	Gable/dormer vents 10' from property line	Any habitable space must be 1 hour rated	If over a descending slope, enclose within 6" of ground	Government Codes 51175-51178	Climatic conditions	Topography	Fuels	Accessibility	Evacuation	Required-all types	
<b>Local Jurisdiction</b>																								
Santa Barbara County	UFC 1988, UBC 1985, NFPA 24 & 13-D	Dev. Reg. 1, Standards 2A, 2 B, 3, 3A, 5							Double glazed		Meets	1/2" holes	Meets	Meets										Meets
Santa Clarita **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets		Fire zone 4 #60	Meets	Meets	Meets	Meets		Meets	
Santa Rosa	Fire Safe Guide 1980, USFS Field Guide 1980, UBC 1988	Pamphlet & Section 1503.4	Class A														Zones mapped							
Santee	NFPA 13-D, CFC 1995	Section 8.04-8.42	Class A														Withdraw per letter dated 9/22/94							
Sausalito	Verbal		Class A														Meets	Meets	Meets	Meets			Meets	
Seaside	Verbal																							
Selma	Verbal																							
Shasta County	PRC 4290, 4291																							
Shasta Lake FPD	UFC 1994	Ordinance 97-1	Class A																					
Sierra Madre	UBC 1991	Ch. 15.04	Class A	Meets	Meets	Meets		Meets	Double-glazed					Meets	Meets		Zone adopted - Fire Zone 4 #61						Meets	
Signal Hill **		Letter dated 10/25/94	Class B														No zone per letter dated 10/25/94							
Solana Beach																								
Sonoma County																								
South County	Verbal																							
South El Monte **																								
South Gate **																								
South Lake Tahoe	Verbal																							
South Pasadena	UFC 1994, UBC	Ordinance 2040	Class A		Meets	Meets		Meets						Meets	Meets		Areas defined - Fire zone 4 #63							Meets
South Placer	H&SC 13146, Title 24	Ordinance #1-1995-6																						
Susanville	Verbal																							
Taft	UFC 1994 Sect. 1103.2	FD Policies & Procedures																						As required by Chief
Tamalpais	PRC 4291-SRA	Verbal																						
Temple City **	Verbal																							
Tiburon		No threat Zone ID'd in error																						
Torrance																								
Truckee	Title 24, H&SC 13146	Res. 1-94, Ord. 1-96																						
Ukiah City	PRC 4290	Inspection Checklist																						
Universal	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets		Fire zone 4 #65	Meets	Meets	Meets	Meets		Meets	
Upland	UFC 1991, UBC 1988	Public Safety Sec. 3100 & Article VIII	Class B											Meets										Meets
Ventura County	UFC 1994, HSC 13869, Div. 12, CBC 1995	Ordinance 22, "Wildland Fire Unit"	Class B														Zone defined and mapped	Meets	Meets	Meets	Meets			Meets
Victorville	UFC 1991, UBC 1991, UCADB 1991	Ordinances 1581 & 1585	No wood																					Meets
Vista	UFC 1991, NFPA 13-D, 13-R, SRA Fire Safe Regs, USFS 1980 Guide	Ch. 8.60, 16.40																						Meets
Walnut **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets		Fire zone 4 #66	Meets	Meets	Meets				Meets
West Covina	UBC, Engineering Department Standards	Division 2 - Zoning	UBC Non-combustible					Hill overhang prohibited							Hill overhang prohibited		San Jose Hills "H" Overlay - Fire zone 4 #67		Meets		Meets			
West Hollywood **																								
Westlake Village **	UBC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets		Fire zone 4 #68	Meets	Meets	Meets				Meets
Westwood	UFC 1994, UBC 1994, LACFC 1996 (UFC 1994), NFPA	Verbal																						Meets
Whittier **	UFC 1994, LACFC 1996 (UFC 1994), NFPA	See LA County	Class A	Meets	Meets	Meets	Meets	Meets	Meets	1 3/8" thick	Meets	Meets		Meets	Meets		VHFHSZ	Meets	Meets	Meets				Meets
Yreka	UBC 1994	Ordinance 708, UBC 1502-1504	Class B																					

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

					ROAD STANDARDS FOR FIRE EQUIPMENT ACCESS:														STANDARDS FOR SIGNING STREETS, ROADS, BLDGS.																					
Code Adoptions and References	Local Source	Notes / Response	AB 337 Mandate Status		Width	Surface	Grades	Horizontal Inside Radius	Vertical Curves	Turn-arounds	Hammer-head/T	Turnouts		Roadway Structures (Bridges)	Bridge Signage	One-way Roads		Dead-end Roads	<1 acre parcels	1-4.99 acre parcels	5-19.99 acre parcels	20+ acre parcels	Driveways	If >150' but <800'	If >800'	If >300'	Gate Entrances	If one-way	Sign Symbols	Visibility	Height	Names /Numbers	Intersections							
<b>Local Jurisdiction</b>					Two 9' lanes, 13' 6" vertical clearance	40,000 lb. Load	Not to exceed 16%	No less than 50'	100'	Required, 40' from center	Top of "T" 60' long	10' x 30'	25' taper each end	Load & clearance per VCS 35550, 35750, 35250	Load, clearance, one-way, single lane	One 10' lane	Must connect to 2 lanes at each end	Serve no more than 10 dwellings	Not to exceed 2640'	Turnout at midpoint	Not to exceed:	800'	1320'	2640' with turnaround at 1320'	5280' w/ turnaround at 1320' intervals	10' wide, 15' vertical clearance	Turnout at midpoint	Every 400'	Turnaround w/in 50' of all building sites	2' wider than lane	30' from roadway	40' turning radius	3" letter height	3/8" stroke	Reflector-ized	Contrast in color	100' both directions	Uniform	Required	Signs required
<b>Yucaipa</b>	UFC 1988	Article 1, SBC Ord. 3381 & City Ord. 24	ME		Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets				Turnouts required	Turnouts required	Turnouts required	Turnouts required	Meets			Meets	Per UBC	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief		
<b>Yucca Valley</b>	UFC 1991, UBC 1991, NEC 1990, UAC, UMC, UPC, etc.	Ordinances 10 & 15 and Article 2	ME		Meets	Meets	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	As approved by Chief	Sufficient fire apparatus load	Meets				Turnouts required	Turnouts required	Turnouts required	Turnouts required	Meets			Meets	Per UBC	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief	As required by Chief		

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

														FUEL MODIFICATION STANDARDS:										INFORMATION ON PLANS AND SPECIFICATIONS:										STRUCTURAL STANDARDS:				
Code Adoptions and References	Local Source	Notes / Response	Access Limit Signage	Sign Installation	Addresses	Address Symbols	Address Installation	Visibility			Hydrant/Fire Valve			Clearance (Structure)	Additional Clearance	Trees	Dead or Dying Wood	Ac-cumulated Vegetation	Chimney & Stovepipe	Setback # >1 acre	# <1 acre	Disposal	Greenbelts	Vicinity Plan	Fire Protection Info in VHFHSZ (GC 51178)					Eaves								
			Nearest intersection or 100' before limit	Prior to acceptance	Required	3' letter height	3/8" stroke	Contrasting color	Permanent posting required at all times	Both directions even if one-way	Multiple addresses on one post	If industrial site, post at intersection	Must meet min. flow as set forth in latest UFC/UBC for new construction	ID per latest NFPA requirements	30' each side or to property line	30'-100' when needed	10' from chimney	Remove if overhanging structure	Clear roof	Screen <1/2" holes	30'	Same practical effect	Prior to acceptance	Locate strategically- must be approved	No less than 1"-100'	300' radius showing all street widths	300' radius hydrant plan / min. flow	Location, occupancy class & use of abutting properties	Preliminary fuel modification plan	300' radius showing all street widths	300' radius hydrant plan / min. flow	Location, occupancy class & use of abutting properties	Preliminary fuel modification plan	Final fuel modification plan	1 hour fire resistant, enclosed	Fascias required, must be backed by 1 hour or 2" lumber		
<b>Local Jurisdiction</b>																																						
Yucaipa	UFC 1988	Article 1, SBC Ord. 3381 & City Ord. 24	As required by Chief	As required by Chief	Meets			Meets	Meets	Meets		Appendix III-A	As approved by Chief	Meets	Meets	Meets	Meets	Meets	Meets																			
Yucca Valley	UFC 1991, UBC 1991, NEC 1990, UAC, UMC, UPC, etc.	Ordinances 10 & 15 and Article 2	As required by Chief	Meets	Meets	As required by Chief	As required by Chief	Meets	Meets	Meets		Meets	Meets	Meets	Meets	Meets	Meets	Meets	Meets						Access plan before constr.	Submit plan before constr.	Submit plan before constr.		Submit plan before constr.	Submit plan before constr.								

**FIRE HAZARD ZONING AND MITIGATION CODE ADOPTION  
EVALUATION OF COMPLIANCE AT THE LOCAL LEVEL**

DARDS														MISCELLANEOUS REQUIREMENTS											
Code Adoptions and References	Local Source	Notes / Response	Roofs	Underfloor Areas	Exception	Unenclosed Accessory Structures	Exception	Underfloor Areas (Attached Structure)	Windows	Doors	Attic Openings	Walls	Underfloor Areas (Detached Structure)	Adoption of Zone	Description of Zone	Rubbish Removal									
<b>Local Jurisdiction</b>			Class B or better	Enclosed to ground	If exposed materials are 1 hour rated	Non-combustible or 1 hour rated	If 100' defensible space, patio roofs > 2"x4" or open lattice > 2"x2" is OK	If over a descending slope, enclose within 6" of ground	Tempered or multi-layered glass	Non-combustible or solid core > 1-3/4"	Not to exceed 144 square inches	Non-combustible corrosion-resistant mesh < 1/4" holes	Not to be in soffits, eave overhangs, etc.	Gable/dormer vents 10' from property line	Any habitable space must be 1 hour rated	If over a descending slope, enclose within 6" of ground	Government Codes 51175-51178	Climatic conditions	Topography	Fuels	Accessibility	Evacuation	Required-all types		
<b>Yucaipa</b>	UFC 1988	Article 1, SBC Ord. 3381 & City Ord. 24	Class A														Areas defined and mapped-FR 1 and 2							Meets	
<b>Yucca Valley</b>	UFC 1991, UBC 1991, NEC 1990, UAC, UMC, UPC, etc.	Ordinances 10 & 15 and Article 2	Class A																						Meets