



# CALIFORNIA BUILDING CODE (2006 IBC) PUBLIC PROPOSAL FORM

*PLEASE SEE REVERSE FOR INSTRUCTIONS ON SUBMITTING PUBLIC PROPOSALS. PROPOSALS MUST COMPLY WITH THESE INSTRUCTIONS.*

1) Indicate the format in which you would like to receive your Public Proposals Monograph (PPM), Report of the Hearing (ROH) and Final Action Agenda (FAA):

- Paper     \* CD     \*Download from ICC Website

(\*Note: A paper copy will not be sent to you if you have chosen the CD or Download format.)

2) PLEASE TYPE OR PRINT CLEARLY: FORMS WILL BE RETURNED if they contain unreadable information.

Name:	Rick Thornberry, P.E.	Date:	12-23-05
Jurisdiction/Company:	The Code Consortium, Inc.		
Submitted on Behalf of:	Alliance for Fire and Smoke Containment and Control (AFSCC)		
Address:	2724 Elks Way		
City:	Napa	State:	CA
		Zip +4:	94558-3500
Phone:	(707) 253-2633	Ext:	
		Fax:	(707) 253-2639
e-mail:	<a href="mailto:thecodeinc@aol.com">thecodeinc@aol.com</a>		

3) \*Signature: \_\_\_\_\_  Signature on File (see over)

*\* I hereby grant and assign to ICC all nonexclusive rights in copyright I may have in any authorship contributions I make to ICC in connection with this proposal. I understand that I will have no rights in any ICC publications that use such contributions in the form submitted by me or another similar form and certify that such contributions are not protected by the copyright of any other person or entity.*

4) Cost Impact: Indicate if this Proposal:  will  will not increase the cost of construction.

5) Indicate appropriate International Code(s) associated with this Public Proposal – Please use Acronym: IBC

If you have also submitted a separate coordination change to another I-Code, please indicate the code: \_\_\_\_\_  
(See back of this form for list of names and acronyms for the International Codes).

6) Revision to:  Section 507.9  Table \_\_\_\_\_  Figure \_\_\_\_\_

7) PROPOSAL Please check appropriate box:

- Revise as follows:     Add new text as follows     Delete and substitute as follows:     Delete without Substitution(s):

Show the proposed NEW, REVISED or DELETED TEXT in legislative format: ~~Line through text to be deleted.~~ Underline text to be added.

**507.9 Motion picture theaters.** In buildings of Type I or II construction, the area of one story motion picture theaters shall be not limited when the building is provided with an automatic sprinkler system throughout in accordance with Section 903.3.1.1 and is surrounded and adjoined by public ways or yards not less than 60 feet (18 288 mm) in width.

PROPOSAL *Continued* (Attach additional sheets as necessary)

8) SUPPORTING INFORMATION (State purpose and reason, and provide substantiation to support proposed change):

This proposed amendment deletes motion picture theaters from being allowed to be an unlimited area one story building. This is entirely consistent with Section 505.2 of the 1997 UBC which does not allow any Group A assembly occupancy to be of unlimited area based on these provisions of complete automatic sprinkler system protection and open space of at least 60 ft. in width around the entire building.

SUPPORTING INFORMATION *Continued* (Attach additional sheets as necessary)