

**AMCA Proposed Code Amendments
California Building Code**

2006 IBC

12/22/2005

Section	Section Title/Brief Description of Amendment
407.3	Corridor Walls Correlates with revisions to 1016.1 / Table 1016.1 for Group I-2. See below.
710.7	Ducts and Air Transfer Openings Adds ducts to requirement for smoke dampers in smoke partitions.
716.5.2	Fire Barriers Requires smoke dampers in addition to fire dampers in charging paragraph. Deletes Exception 3.
716.5.3.1	Penetrations of Shaft Enclosures Deletes exceptions for parking garages.
716.5.4	Fire Partitions Adds air transfer openings and deletes automatic sprinkler system exception for corridor walls.
716.5.4.1	Corridors Clarifies requirements / exceptions for smoke dampers in fire resistive corridors.
1016.1 Table 1016.1	Construction / Corridor Fire-Resistance Rating Reinstates 1-hour corridor ratings and UBC exceptions.