

**INITIAL STATEMENT OF REASONS
FOR
PROPOSED BUILDING STANDARDS
OF THE
OFFICE OF THE STATE FIRE MARSHAL (SFM)
REGARDING THE ADOPTION BY REFERENCE OF THE
2006 EDITION OF THE INTERNATIONAL FIRE CODE
WITH AMENDMENTS INTO THE 2007 CALIFORNIA FIRE CODE
CALIFORNIA CODE OF REGULATIONS TITLE 24, PART 9.**

The Administrative Procedure Act requires that an Initial Statement of Reasons be available to the public upon request when rulemaking action is being undertaken. The following are the reasons for proposing this particular rulemaking action:

STATEMENT OF SPECIFIC PURPOSE AND RATIONALE

The specific purpose of this rulemaking effort by the Office of the State Fire Marshal (SFM) is to act accordance with Health and Safety Code section 18928, which requires all proposed regulations to specifically comply with this section in regards to the adoption by reference with amendments to a model code within one year after it's publication.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies addressed in the 2006 International Fire Code and published as the 2007 California Fire Code.

The general purpose of this proposed action is principally intended to update and codify a new edition of the California Fire Code (California Code of Regulations, Title 24, Part 9) based upon a more current edition of a model code. The current California Fire Code in effect is the 2001 California Fire Code which is based upon the 2000 Uniform Fire Code of the Western Fire Chiefs Association. This proposed action:

- Repeal the 2000 Uniform Fire Code of the Western Fire Chiefs Association and incorporate and adopt in its place the 2006 International Fire Code of the International Code Council for application and effectiveness in the 2007 California Fire Code pursuant to Health and Safety Code 18928. Health and Safety Code 18928 requires any state agency adopting model codes to adopt the most recent edition.
- Repeal amendments to the 2000 Uniform Fire Code and/or California Building Standards not addressed by the model code that are no longer necessary nor justified pursuant with Health and Safety Code 18930(a)(7).
- Adopt and implement additional necessary amendments to the 2006 International Fire Code that address inadequacies of the 2006 International Fire Code as they pertain to California laws.
- Bring forward previously existing California amendments, which represent no change in their effect from the 2001 Triennial California Building Standards Code. Some of the existing California amendments will be amended as follows:
 - Renumbering in order to fit into the newly adopted text of the 2006 International Fire Code.
 - Adding or changing the references to the application authority of SFM.
 - Language changes for clarification of existing law.
 - Not adopting into the text of the 2006 edition of the International Fire Code.
- Codify non-substantive editorial and formatting amendments from the format based upon the 2000 Uniform Fire Code to the format of the 2006 International Fire Code.

The specific purpose and rationale of each adoption, amendment, or repeal is as follows:

CHAPTER 1 – GENERAL CODE PROVISIONS

SFM is proposing to adopt only those Sections in Chapter 1 listed in the matrix adoption table.

Chapter 1, Section 101, was provided by the California Building Standards Commission (CBSC).

SFM proposes to not adopt Chapter 1 of the 2006 International Fire Code (IFC). SFM is proposing that Chapter 1 of the 2006 IFC be relocated in its entirety to a newly created Appendix Chapter 1 for the 2007 California Fire Code. SFM is proposing the adoption of a newly developed Chapter 1 with sections specific to the needs of California and each state agency. The intent of this new chapter will promote uniform enforcement throughout the state and ensure local enforcement agencies are provided accurate statutory information regarding the enforcement of building standards in the State of California.

Amendments that previously existed in Chapter 1 of the 2001 California Fire Code have either been repealed, reformatted, or relocated and are shown appropriately throughout this rulemaking package.

The intent of the proposed adoption of the new California Chapter 1, including the text of Section 101 which was provided by the CBSC, is consistent with the format guidance given by the CBSC and the 2006 IFC.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 2 – DEFINITIONS

The SFM is proposing to adopt this entire Chapter, with amendments.

201.3

SFM is proposing this amendment to delete the term “International” and to replace it with “California” as mandated by building standard statute. SFM is also proposing this amendment to delete reference to the International Fuel Gas Code. SFM is not adopting the International Fuel Gas Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

SECTION 202 GENERAL DEFINITIONS

- [B] AGED HOME OR INSTITUTION**
- [B] ASSEMBLY**
- [B] BEDRIDDEN PERSON**
- [B] BUILDING**
- [B] CARE AND SUPERVISION**
- [B] CATASTROPHICALLY INJURED**
- [B] CELL**
- [B] CELL COMPLEX**
- [B] CELL TIERS**
- [B] CHILD-CARE CENTER**
- [B] CHILD OR CHILDREN**

- [B] CHRONICALLY ILL**
- [B] CONGREGATE LIVING HEALTH FACILITY (CLHF)**
- [B] CONGREGATE RESIDENCE**
- [B] DAY CARE**
- [B] DAY-CARE HOME, LARGE FAMILY**
- [B] DAY-CARE HOME, SMALL FAMILY**
- [B] DAY ROOM**
- [B] ENFORCING AGENCY**
- [B] FIRE APPLIANCE**
- [B] FIRE-RETARDANT TREATED WOOD**
- [B] FIXED GUIDEWAY TRANSFIT SYSTEMS**
- [B] FULL-TIME CARE**
- [B] HIGH-RISE BUILDING**
- [B] HOLDING FACILITY**
- [B] HOUSING UNIT**
- [B] INFANT**
- [B] LODGING HOUSE**
- [B] MENTALLY RETARDED PERSONS, PROFOUNDLY OR SEVERELY**

SFM is correlating these amendments which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] MODERIZATION PROJECT (214, 2201 CFC)

SFM is proposing to bring forth this existing SFM amendment to define school modernization projects. This definition is necessary to outline the scope of projects. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] NEW PUBLIC SCHOOL CAMPUS (215, 2001 CFC)

SFM is proposing to bring forth this existing SFM amendment to define new public school campuses. This definition is necessary to outline the scope of projects. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] NON-ACCESSIBLE AREA (215, 2001 CFC)

SFM is proposing to bring forth this amendment to define non-accessible area. This definition is needed for clarification for areas protected by fire alarm and fire sprinklers. This amendment is consistent with the previous

requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] NON-AMBULATORY PERSONS

[B] NON-COMBUSTIBLE

SFM is correlating these amendments which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] OCUPANCY CLASSIFICATION

SFM is proposing these amendments to correlate with the amendments which is derived from the amendments proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] PERMANENT PORTABLE BUILDING (904.2.4.4.1.2, 2001 CBC) (moved)

SFM is proposing to bring forth the existing SFM amendment defining permanent portable building for school campuses.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] PHOTOLUMNESCENT

SFM is proposing these amendments to correlate with the amendments which is derived from the amendments proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and

published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] PORTABLE BUILDING (217, 2001 CFC) (moved)

SFM is proposing to bring forth this amendment to define portable buildings on school campuses. This definition is necessary to outline the scope of projects. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] PROTECTIVE SOCIAL CARE

SFM is proposing to bring forth this amendment to define portable buildings on school campuses. This definition is necessary to outline the scope of projects. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] RESIDENTIAL CARE FACILITY FOR THE CHRONICALLY ILL (RCF/CI)

Proposed inclusion of definitions some of which may need to be located to other sections of this code. Recommend omitting struck out definitions in lieu use of current CBC definition and use of nonambulatory designation. Carry over CBC 310.1.4 as applicable to RCFE facilities. Carry over of CBC 310.1.4 as applicable to RF facilities. This proposal identifies CBC 310.1.2 not permitting restraint in Group R2 occupancies.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] RESIDENTIAL CARE FACILITY FOR THE ELDERLY (RCFE)

Proposed inclusion of definitions some of which may need to be located to other sections of this code. Recommend omitting struck out definitions in lieu use of current CBC definition and use of nonambulatory designation. Carry over CBC 310.1.4 as applicable to RCFE facilities. Carry over of CBC 310.1.4 as applicable to RF facilities. This proposal identifies CBC 310.1.2 not permitting restraint in Group R2 occupancies.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] RESIDENTIAL FACILITY (RF)

Proposed inclusion of definitions some of which may need to be located to other sections of this code. Recommend omitting struck out definitions in lieu use of current CBC definition and use of nonambulatory designation. Carry over CBC 310.1.4 as applicable to RCFE facilities. Carry over of CBC 310.1.4 as applicable to RF facilities. This proposal identifies CBC 310.1.2 not permitting restraint in Group R2 occupancies.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] RESTRAINT

Proposed inclusion of definitions some of which may need to be located to other sections of this code. Recommend omitting struck out definitions in lieu use of current CBC definition and use of nonambulatory designation. Carry over CBC 310.1.4 as applicable to RCFE facilities. Carry over of CBC 310.1.4 as applicable to RF facilities. This proposal identifies CBC 310.1.2 not permitting restraint in Group R2 occupancies.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] SELF-ILUMINOUS

SFM is proposing to bring forth this amendment to define portable buildings on school campuses. This definition is necessary to outline the scope of projects. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] TERMINALLY ILL

Proposed inclusion of definitions some of which may need to be located to other sections of this code. Recommend omitting struck out definitions in lieu use of current CBC definition and use of nonambulatory designation. Carry over CBC 310.1.4 as applicable to RCFE facilities. Carry over of CBC 310.1.4 as applicable to RF facilities. This proposal identifies CBC 310.1.2 not permitting restraint in Group R2 occupancies.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] WINERY CAVES

SFM is proposing to bring forward these SFM amendments, which are found in the building code, to the fire code. This is consistent with the format established by the model code. The purpose of the amendments is to insert these definitions to the winery caves occupancy not currently found in the IBC and to refer the code user to Section 4XX for winery cave regulations.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 3 – GENERAL PRECAUTIONS AGAINST FIRE

The SFM is proposing to adopt only those sections listed in the matrix adoption table.

308.3.9

SFM is proposing this amendment to included Groups I, R-3.1, R-4 or any licensed care facility. The purpose for this action is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in SFM regulated occupancies. This amendment is consistent with the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 4 – EMERGENCY PLANNING AND PREPAREDNESS

The SFM is proposing to not adopt this entire Chapter.

CHAPTER 5 – FIRE SERVICE FEATURES

The SFM is proposing to adopt only those sections listed in the matrix adoption table.

503.5.2

SFM is proposing this amendment that is derived from an existing SFM amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

508.3

SFM is proposing this amendment to reference Fire Code Appendix B for fire flow. The IFC does not currently direct the code user to Appendix B. This amendment provides the fire official an alternate method for determining an acceptable fire flow.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

508.5

SFM is proposing this amendment to reference Fire Code Appendix C for fire hydrant placement. The IFC does not currently direct the code user to Appendix C. This amendment provides the fire official an alternate method for determining an acceptable fire hydrant placement.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

508.5.3

SFM is proposing this amendment to delete the reference to NFPA 25 and reference Title 19, CCR, Chapter 5. Title 19, CCR addresses the maintenance of private fire service mains and water tanks. This amendment is consistent with the requirements contained in Title 19, CCR. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

509.1 (403.6.2 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment to address storage and equipment placed in fire command centers. SFM is proposing this amendment to delete the term "International" and to replace it with "California" as mandated by building standard statute. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 6 – BUILDING SERVICES AND SYSTEMS

The SFM is proposing to adopt this entire Chapter, with amendments.

603.1

SFM is proposing this amendment to change the term International to California. In addition, SFM is proposing to delete the reference to the International Fuel Gas Code and reference the California Mechanical Code instead. The International Fuel Gas Code is not being adopted in California. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

603.1.2

SFM is proposing this amendment to change the term International to California. In addition, SFM is proposing to delete the reference to the International Fuel Gas Code and reference the California Mechanical Code instead. The International Fuel Gas Code is not being adopted in California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

603.2, 603.3, 603.3.2, 603.6.1, 604.1, 604.2.9, 604.2.15.1, 604.2.15.1.3, 604.2.16, 604.2.16.1.1, 604.2.17, 605.4, 606.1, 606.2, 606.3, 606.4, 606.7, 606.8, 608.4, 608.6.1, 608.8, 609.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

603.5.2

SFM is proposing this amendment to change the terms International and ICC to California. In addition, SFM is proposing to delete the reference to the International Fuel Gas Code and reference the California Mechanical Code instead. The International Fuel Gas Code is not being adopted in California. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

603.8

SFM is proposing this amendment to change the term International to California. In addition, SFM is proposing to delete the reference to the International Fuel Gas Code and reference the California Mechanical Code instead. The International Fuel Gas Code is not being adopted in California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

604.2.16.1, 604.2.16.2, 605.1, 605.3, 605.9,

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

606.16

SFM is proposing this amendment to change the terms International and ICC to California. In addition, SFM is proposing to delete reference to specific section in the IMC and instead make a general reference to the CMC. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Sections 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 7 FIRE-RESISTANCE-RATED CONSTRUCTION

The SFM is proposing to adopt this entire Chapter, with amendments.

701.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Sections 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

TABLE 704.1

SFM is proposing this amendment to add Group I occupancies to the table for the escalator opening exclusion. This is needed to eliminate open shafts in Group I occupancies which is consistent with the IBC. Protected openings must be consistent between the IBC and IFC. This change per the escalator openings in Table 704.1 has been added to maintain this consistency between the IBC and IFC. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Sections 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 8 – INTERIOR FINISH, DECORATIVE MATERIALS AND FURNISHINGS

The SFM is proposing to adopt this entire Chapter, with amendments.

803.1, 803.7.1, 803.7.2, 805.3.1.2, 807.1.2

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Sections 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

Table 803.3 (Appendix Chapter 3A 2001 CBC)

SFM is proposing these amendments to correlate with the amendments which is derived from the amendments proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments. Additionally SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

804.1

SFM is proposing this amendment to modify requirements for interior trim to reflect current Group I-3 requirements. Due to the restricted movement of individuals within Group I-3 Occupancies it is imperative that additional safeguards be provided for interior trim. Group I-3 occupancies follow a "defend in place" procedure is followed. For Group I-3 Occupancies, evacuation of the entire incarcerated population is not always advisable for security reasons and may not be possible in a short period of time. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

807.4.2.4, 807.4.2.4.1, 807.4.5, and 807.4.5.1 (Relocated from 2001 CFC, Article 40)

SFM is proposing to bring forward these existing SFM requirements for Motion Picture and Television Production facilities. These facilities are not specifically addressed the IFC and are necessary to maintain a reasonable degree. These amendments are consistent with the previous requirements contained in the 2001 California Fire Code, which will maintain the fire and life safety policy of the SFM. These amendments do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 9 – FIRE PROTECTION SYSTEMS

SFM is proposing to adopt the entire chapter with amendments.

901.4.1

SFM is proposing this amendment to change the term International to California

901.6.1

SFM is proposing this amendment to add a reference to Title 19, CCR Chapters 3 and 5. This amendment is necessary due to the SFM maintenance requirements that are statutorily mandated. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

Table 901.6.1

SFM is proposing this amendment to add a reference to Title 19, CCR Chapters 3 and 5 and to reference the amendments to NFPA 72 in Chapter 45. These amendments are necessary due to the SFM maintenance requirements that are statutorily mandated. These amendments do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and

published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

902.1

FIRE APPLIANCE.

SFM is proposing this amendment that is derived from an existing SFM amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.2 (414A.4.1, 2001 CBC)

SFM is proposing this amendment to bring forth the automatic fire sprinkler existing SFM requirements for fixed guideway transit systems. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.2.2, 903.2.2.1, 903.2.2.1.1, 903.2.2.1.2, 903.2.2.1.3

SFM is proposing to bring forth an existing SFM amendment addressing fire resistive substitution for sprinklers on a new public school campus and the sprinklering of school structures. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect. SFM is also proposing to add an amendment requiring fire sprinklers in school classrooms or areas with special hazards such as laboratories, vocational shops or where hazardous materials are stored or used. Laboratories, vocational shops and similar areas pose a potential risk to students due to the use of these rooms and nature of the materials contained, which include flammable liquids and hazardous materials.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.2.4.2

SFM is proposing this amendment to change the term International to California

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.2.5

SFM is deleting the reference to NFPA 13D sprinkler systems for I-1 occupancies. This amendment is necessary

due to the SFM mandates for care facilities. SFM modifications to the definition/uses for I-1 facilities in the IBC expand I-1 occupancies beyond the design scope of a NFPA 13D system. Limitations for NFPA 13R systems are necessary as a result of these same modifications to allow an increase in the number of non-ambulatory and bedridden patients. SFM is proposing further amendments that exempt Group I occupancies as specified Section 407.5 of the CBC and brings forth additional exemption as mandated by the California Health and Safety Code 13113. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.2.5.1 (329A,1)

SFM is proposing to bring forth this existing SFM amendment to allow buildings to be considered sprinkler throughout with exceptions. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.2.7 (904.2.10, 2001 CBC)

SFM is proposing the amendment of this section to incorporate critical elements of the International Residential Code (IRC). During this rulemaking the Department of Housing and Community Development (HCD) was not able to propose adoption of the IRC as originally planned. The IRC and the International Building Code (IBC) contain conflicting requirements in some areas as they relate to one and two family dwellings and Group U private garages accessory to them. In an effort to transition from the IBC to a future adoption of the IRC, SFM is incorporating amendments to correlate some of the more critical conflicts into this rulemaking.

The 2006 IRC does not require fire sprinkler systems in detached one- and two- family dwellings. The scope provisions contained in Section 101.2 of the 2006 IBC specify that one- and two- family dwellings comply with the provisions of the IRC. This amendment aligns the requirement contained in the IRC with those of the IBC by specifying that one- and two family dwellings may be constructed without fire sprinklers unless required by other sections of the code. The requirement for fire sprinklers in one- and two- family dwellings is most common in licensed care occupancy groups regulated by SFM.

In addition SFM is proposing to bring forth these requirements and amendments regarding Group R occupancies. this amendment will exempt fire sprinklers under certain conditions. This amendment does not create a change in regulatory effect.

This amendment is also consistent with the previous requirements contained in the 2001 Triennial California Building Standards Code. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.2.8.1, 903.2.9, 903.2.12.1

SFM is proposing this amendment to change the term International to California

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

TABLE 903.2.13

SFM is proposing this amendment to provide referenced sections for the automatic fire sprinkler requirements for horse racing stables, public libraries, pet kennels.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.2.14, 903.2.14.1, 903.2.14.2 (relocated from 2001 CFC 4005)

SFM is proposing these amendments to bring forth existing SFM amendments regarding motion picture and television production studios sound stages and approved production facilities. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.2.15

SFM is proposing to bring forth the existing SFM amendment requiring a sprinkler system in existing high-rise buildings of Type II-B, Type III-B or Type V-B construction. The amendment is mandated by California Health and Safety Code 13143 and 18984. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.2.15.1

SFM is proposing to bring forth the existing SFM amendment which requires a sprinkler water-flow indicator for existing Group R-1 and 2 occupancies located in high-rise buildings. The amendment is mandated by California Health and Safety Code 13143 and 18984. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.2.16 (904.2.6.4, 2001 CBC)

SFM is proposing to bring forth an existing SFM amendment addressing automatic fire sprinkler requirements for Group L Occupancies. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.2.17 through 903.2.17.2.6 (414A, 2001 CBC)

SFM is proposing to bring forth these existing SFM amendments that bring forth regulatory language in the CBC that is not addressed in the IBC for fixed guideway transit systems. These amendments are consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. These amendments do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.3.1.1.1

SFM is proposing to bring forth the existing amendment mandated by California Health and Safety Code, Section 13113, that requires a fire sprinkler system throughout institutional occupancies which include Group I-2, I-1.21 and I-3 occupancies. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.3.2, 903.3.5.2, 903.6

SFM is proposing this amendment to change the term International to California

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

903.3.5

SFM is proposing this amendment to change the term International Plumbing Code to the California Health and Safety Code. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

904.2.1

SFM is proposing this change due to incorrect code section cite in the IFC.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

904.3.1

SFM is proposing this amendment to change the term International to California

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and

published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

904.5, 904.6, 904.7, 904.8, 904.9, 904.10

SFM is proposing this amendment to provide the code user with the added reference to Title-19, CCR, Chapter 5. This amendment does not create a change in regulatory effect. SFM is proposing to bring forth these existing amendments mandated by California Health and Safety Code, Section 13195.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

904.7.1

SFM is proposing this amendment to provide the code user with the correct reference to Title-19, CCR, Chapter 5 and delete the reference to NFPA 25. This amendment does not create a change in regulatory effect. SFM is proposing to bring forth these existing amendments mandated by California Health and Safety Code, Section 13195.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

904.11

SFM is proposing this amendment due to the changes in commercial cooking mediums and appliance efficiency, and due to the fact that state and national fire loss data has shown the fire hazards associated with commercial cooking areas. These changes necessitated a change in Underwriters Laboratory (UL) testing standards in 1994. Recognizing that the revised testing criterion that has existed has been existing for almost 10-years, many existing locations are protected by non-compliant fire extinguishing systems. The SFM has determined that it IS NOT in the public interest to continue to service and certify these fire suppression systems that currently do not meet the requirements of UL-300.

The SFM, under Health and Safety Code Section 13195, and 13195.5, (Automatic Fire Extinguishing Systems) the regulations and building standards established by the SFM for servicing, testing, and maintaining automatic fire extinguishing systems shall consider requirements from applicable standards. In addition this amendment deletes language, within the exception, referencing the International Mechanical Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

904.11.5

SFM is proposing this amendment to provide the code user with the correct reference to Title-19, CCR, (Public Safety, Chapter 3 – Fire Extinguishers and addressed in the 2006 International Fire Code (IFC) and published as the 2007 CFC pursuant to Health and Safety Code Section 13160, and Government Code Section 11340 pf Part 1 of Division 3 of Title-2, Chapter 3.5. The SFM deems necessary for the protection and preservation of life and property to control the servicing, including testing, or all portable fire extinguishers for controlling and extinguishing fires, and for controlling the sale and marketing of all such devices with respect to conformance with standards of their use, capacity, and effectiveness. In adopting these regulations, the SFM shall consider the standards of the NFPA. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and

published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143, 13195, 13160 and 17921

904.11.5.2

SFM is proposing this amendment to provide the code user with the correct reference to Title-19, CCR, (Public Safety, Chapter 3 – Fire Extinguishers and addressed in the 2006 International Fire Code (IFC) and published as the 2007 CFC pursuant to Health and Safety Code Section 13160, and Government Code Section 11340 pf Part 1 of Division 3 of Title-2, Chapter 3.5. The SFM deems necessary for the protection and preservation of life and property to control the servicing, including testing, or all portable fire extinguishers for controlling and extinguishing fires, and for controlling the sale and marketing of all such devices with respect to conformance with standards of their use, capacity, and effectiveness. In adopting these regulations, the SFM shall consider the standards of the NFPA. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143, 13195, 13160 and 17921

904.11.6

SFM is proposing this amendment to add reference to Chapter 5, Title 19 CCR. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143, 13195, 13160 and 17921

905.3

SFM is proposing this amendment to include the referenced sections for the standpipe requirements for fixed guideway transit systems, smokeproof enclosures, and Group I-3 Occupancies.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

905.3.8

SFM is proposing this amendment to point the user to the California Building Code for smokeproof enclosures.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

905.3.9

SFM is proposing to bring forth the existing SFM amendment into the fire code requiring standpipes in I-3 facilities with 50 or more inmates. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

905.3.10 & 905.3.10.1 (414A.4.3, 2001 CBC)

SFM is proposing to bring forth the current standpipe regulations for fixed guideway transit system stations into the IFC. Also making editorial changes to define the intent and language of this section. The amendments do not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

905.5

SFM is proposing to bring forth the existing SFM amendment, Section 904.5.1 requiring a listed variable stream fog nozzle. A straight stream nozzle without a shut-off creates a safety hazard and contributes to greater water damage. In addition local fire departments utilize variable stream fog nozzles as standard operating procedures. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 13195 and 17921.

906.1 (310.15.4, 2001 CBC)

SFM is proposing to delete the section regarding the placement of Fire Extinguishers in Group A, B and E Occupancies. Placement of fire extinguishers is under the authority of the local enforcement agency per state statute. In addition SFM proposes to add Fire Extinguisher requirements for Large Family Day Cares. This amendment does not create a change in regulatory effect.

Health and Safety Code 13160. Regulations and standards; administration. With the advice of the State Fire Advisory Board, the State Fire Marshal shall adopt, in accordance with the provisions of Chapter 3.5 (commencing with Section 11340) of Part 1 of Division 3 of Title 2 of the Government Code, and administer regulations and standards as he or she may deem necessary for the protection and preservation of life and property to control the servicing, including charging, and testing, of all portable fire extinguishers for controlling and extinguishing fires, and for controlling the sale and marketing of all such devices with respect to conformance with standards of their use, capacity, and effectiveness. In adopting the regulations, the State Fire Marshal shall consider the standards of the National Fire Protection Association.

13161. Legislative intention. It is the legislative intention in enacting this chapter that the provisions of this chapter and the regulations and standards adopted by the State Fire Marshal pursuant to this chapter shall apply uniformly throughout the State of California and no county, city, city or county or district shall adopt or enforce any ordinance or rule or regulation regarding portable fire extinguishers which is inconsistent with the provisions of this chapter or the regulations and standards adopted by the State Fire Marshal pursuant to this chapter.

Health and Safety Code 13160 requires regulations be written in accordance with Government Code Section 11340 this section establish the Office of Administrative Law and they establish Title 19 California Code of Regulation, for the State Fire Marshal that is why our regulations must be in Title 19.

IFC Section

Title 19 Section

906.1 Exception

Not consistent with existing requirements of Title 19

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 13195 and 17921.

906.2

SFM is proposing to omit the IBC 3 year maintenance requirements for fire extinguishers that are electronically monitored. This requirement is contrary to the requirements contained in CCR, Title 19 and NFPA 72 as adopted and amended by SFM and would in turn invalidate warranties on fire extinguishers. Further more these amendments coordinate with the SFM Title 19 California Code of Regulations.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 13195 and 17921.

907.1.2

SFM is proposing to bring forth this existing amendment mandated by Health and Safety Code 13114 (b), requiring the California State Fire Marshal to list and approve all fire alarm equipment and devices marketed, distributed, offered for sale or installed in this state. This amendment is consistent with the previous requirements contained in the 2001 California Building Code. The amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 13195 and 17921.

907.1.3

SFM is proposing this amendment for clarification where fire walls are installed. Without the amendment the code may be misinterpreted as not requiring a fire alarm system based on the reduced area or number of occupants in the individual areas created by the fire walls. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 13195 and 17921.

907.1.4.

SFM is proposing this amendment for clarification of the use of fire alarm systems. The model code requirement is being modified and to allow the use for Mass Notification. The NFPA 72 Committees have approved the use of fire alarm systems for Mass Notification at the request of the United States Air Force for the 2007 edition. The Mass Notification provisions of NFPA 72 which are supplementary only at the request of the owner are designed alert employees and the public of other types of emergencies including bomb threats & terrorist attacks. It is imperative we allow building owners and government the option of installing this potential life-saving fire alarm feature without having to wait for the adoption of 2007 edition of NFPA 72. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.2

SFM is proposing this amendment for clarification that approval by the authority having jurisdiction is required where alternate types of automatic fire detection are used. SFM is also proposing to add a new paragraph to correlate with the current requirements of NFPA 72 (2002), Section 6.8.5.1.2 which requires a minimum of one fire alarm box to be installed for each fire alarm system. This single manual station will ensure a contingency method for activating the fire

alarm signal for occupant notification should the sprinkler water-flow switch be inoperable, and will also allow building staff the option of activating the fire alarm signal prior to sprinkler activation such as fires in the incipient stage, where heavy smoke may be produced without the heat required to activate the sprinkler heads (fire sprinkler heads are generally 165 degrees and 200 degrees).

Exception 1 in the proposed amendment will exempt fire alarm systems which are dedicated to elevator recall, supervisory service and sprinkler monitoring only. This exception will help correlate with NFPA 72 (2002) which already allows the exception for fire alarm systems dedicated to elevator recall and supervisory service. This addition exception for fire sprinkler monitoring only will reduce the added cost for the installation of a manual device. Where previously installed for fire sprinkler monitoring only, the single manual box has resulted in little fire and life safety benefit and is difficult and confusing to enforce.

The second exception, in the proposed amendment will permit the local enforcement authority to waive the requirement of a single manual fire alarm box.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.2.1.1

SFM is purposing an amendment to direct the code user to 2006 CBC/CFC Section 907.12.1.1.1 where Group A occupancies have an occupant load of 10,000 or more. This amendment is predicated by SFM existing amendment California Building Code Section 303.10 requiring a public address system in assembly occupancies intended for 10,000 or more occupants, as mandated by CA Health and Safety Code Section 13108.9. This amendment is consistent with the previous requirements contained in the 2001 California Building Code. The amendment does not create a change in regulatory effect.

907.2.1.3 (303.10, 2001 CBC)

SFM is purposing to bring forth the existing SFM amendment California Building Code Section 303.10 requiring a public address system in assembly occupancies intended for 10,000 or more occupants as mandated by CA Health and Safety Code. For clarification purposes this amendment replicates CA Health and Safety Code Section 13108.9. This amendment is consistent with the previous requirements contained in the 2001 California Building Code. The amendment does not create a change in regulatory effect.

907.2.3 (305.9.1, 2001 CBC)

SFM is purposing this amendment requiring an automatic fire detection system in addition to the manual fire alarm. This amendment is predicated upon by CA Education Code, Section 117074.50 which requires an automatic fire detection and alarm system. This amendment will provide consistency in fire and life safety requirements for new construction of schools and modernization projects throughout the State of California.

This proposed amendment also requires a fire alarm system in all Group E occupancies having more than one classroom as mandated by CA Education Code, Section 32001 or more than one room used for daycare in accordance with CBC, Section 305.9.1. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.2.3.1 (1006.2.4.1.1, 2001 CFC)

SFM is proposing to bring forth the existing California Fire Code amendment requiring interconnection of all school fire alarm control units. In addition minor editorial changes were made. This amendment is consistent with the previous requirements contained in the 2001 California Building Code. The amendment does not create a change in regulatory effect.

907.2.3.2 (1006.2.4.1.2, 2001 CFC)

SFM is proposing to bring forth the existing California Fire Code amendment requiring fire alarm systems in all

educational occupancies as mandated by the California Education Code Section 17074.50. This amendment is consistent with the previous requirements contained in the 2001 California Building Code. The amendment does not create a change in regulatory effect.

907.2.3.3 (1006.2.4.1.3, 2001 CFC)

SFM is proposing to bring forth the existing California Fire Code amendment requiring fire alarm system notification in all educational occupancies. This amendment is consistent with the previous requirements contained in the 2001 California Building Code. The amendment does not create a change in regulatory effect.

907.2.3.4 (1006.2.4.1.4, 2001 CFC)

SFM is proposing to bring forth the existing California Fire Code amendment regarding the fire alarm system annunciation signal in all educational occupancies. This amendment is consistent with the previous requirements contained in the 2001 California Building Code. The amendment does not create a change in regulatory effect.

907.2.3.5 (1006.2.4.2.2.1.5, 2001 CFC)

SFM is proposing to bring forth the existing California Fire Code amendment mandated by California Education Code, Sections 17074.50 and 17074.52 which requires fire alarm systems that are installed for school modernization projects to be monitored by an approved supervising station. This amendment is consistent with the previous requirements contained in the 2001 California Building Code. The amendment does not create a change in regulatory effect.

907.2.3.6, 907.2.3.6.1 (1006.2.4.2.2.1.5, 2001 CFC)

SFM is proposing to bring forth the existing California Fire Code amendment mandated by California Education Code, Sections 17074.50 and 17074.52 requiring smoke detection in public school projects. This appears only as a heading. This amendment is consistent with the previous requirements contained in the 2001 California Building Code. The amendment does not create a change in regulatory effect.

907.2.3.7, 907.2.3.7.1, 907.2.3.7.2, 907.2.3.8, 907.2.3.8.1, 907.2.3.8.2, 907.2.3.8.3 (1006.2.4.4... 2001 CFC)

SFM is proposing to bring forth the existing SFM amendments mandated by California Education Code, Sections 17074.50 and 17074.52 requiring automatic fire alarm systems in public schools. This amendment does not create change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.2.6

SFM is proposing to remove I-1 and I-2 occupancies from the exception of this section to coordinate with the existing SFM amendments proposed in section 907.2.6.1 and 907.2.6.2. Additionally SFM is proposing to exempt large family day care facilities. This amendment does not create change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 13195 and 17921.

907.2.6.1.1 (310.10.1, 2001 CBC)

SFM is proposing to bring forth the existing SFM amendments for fire alarm system requirements in Group I-1 Occupancies. This amendment is consistent with existing amendments and requirements and does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 13195 and 17921.

907.2.6.2 (308.9, 2001 CBC)

SFM is proposing to bring forth the existing SFM amendments for fire alarm system requirements in Group I-2 and Group I-2.1 Occupancies. This amendment is consistent with existing amendments and requirements and does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 13195 and 17921.

907.2.6.2.1

SFM is proposing to bring forth this amendment to provide smoke detectors in both patient and client sleeping rooms. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 13195 and 17921.

907.2.6.3.3

SFM is proposing to bring forth the existing SFM amendments for allowing other approved smoke detection arrangements in Groups I, Division 3 Occupancies. This amendment is consistent with existing requirements and does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.6.3.4

SFM is proposing to bring forth this existing amendment addressing system annunciation for Group I-3 detention facilities. This amendment is consistent with existing requirements and does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.6.4 (310.15.4, 2001 CBC)

SFM is proposing to bring forth this statutory requirement from the CBC regarding large family day cares regarding manual fire alarm devices. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.7

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.2.8

SFM is proposing to bring forth an existing SFM amendment addressing fire alarm requirements for residential care facilities housing more than 6 ambulatory clients (Group R-4 occupancies). This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.8.4

SFM is proposing to bring forth an existing SFM amendment addressing fire alarm requirements for Group R-4 occupancies. This amendment is consistent with the previous requirements contained in the 2001 California Building and Fire Codes, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.10 (1006.2.9.1.6, 2001 CFC)

SFM is proposing to bring forth this existing SFM amendment. This amendment allows a smoke detection system in lieu of single station smoke alarms to be installed in residential occupancies. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.10.1 1

SFM is proposing the amendment to require smoke alarms to be installed in the enclosed common stairways of Group R-1 occupancies as mandated by Health and Safety Code Section 13113.7. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.10.1.2

SFM is proposing the amendment to require smoke alarms to be installed in the enclosed common stairways of apartment complexes and other multiple-dwelling complexes as mandated by Health and Safety Code Section 13113.7. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.10.1.4 (310.15.2, 2001 CBC)

SFM is proposing to bring forth the existing SFM amendment for the requirement of smoke alarms. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.10.1.5 (1006.2.9.1.7, 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment from the existing CBC regarding smoke detectors for facilities have one bedridden patient. This is a statutory requirement. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.10.2, 907.2.10.3

SFM is proposing to bring forth an amendment addressing smoke alarm power source and interconnection requirements for certain residential care facilities (Group R-3.1 occupancies). This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.10.5 thru 907.2.10.5.3

SFM is proposing to bring forth these existing SFM amendments. SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.12 (403.1.1, 2001 CBC)

SFM is proposing this amendment to delete existing IBC language and substitute the word high-rise. This amendment correlates with the statutory definition of high-rise building also being provided in chapter 2. In addition

SFM is proposing this amendment to change the term International to California. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.15

SFM is proposing to add an amendment adding the term devices to correlate with existing statutory language and amendments. SFM is also proposing to delete heat detection to comply with California Health and Safety Code Section 1569.699, which mandate an automatic smoke detection system throughout the building and not heat detection for activation of special egress control devices. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.15.1 (1006.2.12.5.1, 2001 CFC)

SFM is proposing to bring forth the existing SFM Amendment Section 1006.2.12.5.1 with modifications for correlation with the IBC/IFC Sections 1008.1.8.6. This amendment does not create a change in regulatory effect.

SFM is proposing to repeal the CFC Amendment, Sections 1006.2.12.5 which is addressed in the IFC/IBC and not necessary. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.2.15.2 (1006.2.12.5.2, 2001 CFC)

SFM is proposing to bring forth the existing SFM Amendments Sections 1006.2.12.5.2 with modifications for correlation with the IBC/IFC Sections 1008.1.8.6. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.2.15.3

SFM is proposing to add an amendment for Group R-4 residential care facilities housing elderly clients with Alzheimer's disease or dementia to comply with California Health and Safety Code Section 1569.698, which mandates smoke detection throughout the building and not heat detection for activation of special egress control devices.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.18

SFM is proposing this amendment to change the term International to California

907.2.21

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.2 24, 907.2.24.1, 907.2.24.2, 907.2.24.3 and 907.2.24.4 (Article 40, 2001CFC)

A SFM is purposing to bring forth the existing SFM amendments from California Fire Code addressing motion picture and television production studio sound stages and approved production facilities fire alarm requirements into the CFC/CBC with terminology modifications only. Motion picture production studio sound stages and production facilities are currently not referred to in the IBC. These amendments do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.25 (431A.6.6, 2001 CBC)

SFM is purposing to bring forth the existing SFM amendment from California Building Code addressing Group C, Organized Camps fire alarm requirements into the Fire Code. Camps are currently not referred in the IBC. This amendment does not create a change in regulatory effect.

907.2.25.1 (431A.6.6, 2001 CBC)

SFM is purposing to bring forth the existing amendment from California Building Code, Section 431.6.6 which requires an automatic fire alarm system in Group C Occupancies. Exception #2 is being added to correlate with 2006 California Building Code, Sections 440.4.1 and 404.6 which exempt one story buildings and structures used for sleeping where all lateral dimensions are less than 25 feet. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.25 2 (431A.8), 2001 CBC)

SFM is purposing to carry over the existing SFM amendment from California Building Code, Section 431A.8 which requires every organized camp to have a device suitable for sounding a fire alarm signal throughout the camp premises to be used for fires and emergencies. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.26, 907.2.26.1, 907.2.26.2, 907.2.26.3, 907.2.26.4, 907.2.26.4.1, 907.2.26.4.2, (414A.5.1 – 414A.52.2. 2001 CBC)

A SFM is purposing to bring forth the existing SFM amendments from California Building Code Section 414A.5 addressing fixed guideway transits system fire alarm requirements into the CFC/CBC. Fixed guideway transits systems are currently within the IBC. These amendments do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.2.27 (Article 41, 4108, 2001 CFC)

SFM is purposing to bring forth the existing SFM amendment from the California Fire Code addressing Type 3 Winery Cave fire alarm requirements into the IBC. This amendment requires that a manual fire alarm system be installed in all Type 3 Winery Caves where classified as an assembly occupancy. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.3.1.3

SFM is proposing this amendment to add Group I-2.1 occupancies to this section. Group I-2.1 occupancy is not address by the IFC. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.3.1.3.1

SFM is proposing this amendment to require an auto fire alarm where automatic sprinklers are not installed in Group I-2 occupancy. This amendment does not create a change in regulatory effect

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.3.1.9, 907.3.1.9.1, 907.3.1.9.2 (403.16, 403.25.3, 2001CBC)

SFM is proposing to bring forth this existing amendment requiring an automatic or manual fire alarm system in existing R -1 and R - 2 high-rise buildings, and to correlate with the proposed requirements located in 2006 CBC Section 3411.13.3.1. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.3.1.10

SFM is proposing to bring forth these amendments to address existing high rise buildings. These requirements are statutorily mandated by CA Health and Safety Code. This is a heading only. This amendment does not create a change in regulatory effect.

907.3.1.10.1 (403.16.1, 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment to address existing high rise buildings. These requirements are statutorily mandated by CA Health and Safety Code. This amendment does not create a change in regulatory effect.

907.3.1.10.2 (403.16.2, 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment to address existing high rise buildings. These requirements are statutorily mandated by CA Health and Safety Code. This amendment does not create a change in regulatory effect.

907.3.1.10.3 (403.16.3, 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment to address existing high rise buildings. These requirements are statutorily mandated by CA Health and Safety Code. This amendment does not create a change in regulatory effect.

907.3.1.10.4 (403.16.4, 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment to address existing high rise buildings. These requirements are statutorily mandated by CA Health and Safety Code. This amendment does not create a change in regulatory effect.

907.3.1.10.5 (403.16.5, 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment to address existing high rise buildings. These requirements are statutorily mandated by CA Health and Safety Code. This amendment does not create a change in regulatory effect.

907.3.1.10.6 (403.16.6, 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment to address existing high rise buildings. These requirements are statutorily mandated by CA Health and Safety Code. This amendment does not create a change in regulatory effect.

907.3.1.10.7 (403.17, 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment to address existing high rise buildings. These requirements are statutorily mandated by CA Health and Safety Code. This amendment does not create a change in regulatory effect.

907.3.1.10.8 (403.18, 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment to address existing high rise buildings. These requirements are statutorily mandated by CA Health and Safety Code. This amendment does not create a change in regulatory effect.

907.3.1.10.9 (403.21, 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment to address existing high rise buildings. These requirements are statutorily mandated by CA Health and Safety Code. This amendment does not create a change in regulatory effect.

907.3.1.10.10 (403.22, 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment to address existing high rise buildings. These requirements are statutorily mandated by CA Health and Safety Code. SFM is also proposing to repeal Section 403.16.7 of the California Building Code. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.3.2 (310.16.2 CBC)

SFM is proposing to bring forth this statutory requirement, Health and Safety Code Section 13113.7, of single and multiple station smoke alarms Group I-1 occupancy. This amendment does not create a change in regulatory effect.

907.3.2.1(310.16.2 CBC)

SFM is proposing to bring forth this statutory requirement, Health and Safety Code Section 13113.7, of single and multiple station smoke alarms in Group I-1 occupancy. This amendment is required due to change of occupancy classification in the IFC. This amendment does not create a change in regulatory effect.

907.3.2.2

SFM is proposing to add Groups R-3.1 and I-1 occupancies to require interconnection of smoke alarms. This amendment is required due to change of occupancy classification in the IFC. This amendment does not create a change in regulatory effect.

907.3.2.3 (310.16.2, 2001 CBC)

SFM is proposing to bring forth this amendment to meet statutory requirements of Health and Safety Code 13113.7. This requires construction costing over \$1,000.00 and requiring a permit to upgrade to installing smoke alarms. This amendment does not create a change in regulatory effect.

907.3.2.4 (1006.2.9.1.7, 2001 CFC)

SFM is proposing to bring forth this amendment from the existing CBC regarding smoke detectors for existing Group R-3.1 occupancies having one bedridden patient. This is a statutory requirement. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.4.1 (3505.1, 2001 CBC, 9102.1 2001 CBC)

SFM is purposing to bring forth this existing amendment (Exception), which will limit manual fire alarm boxes to the ground floor only in Group R Occupancies where individual dwellings are served by a single exit stairway. This amendment also is required to correlate with the existing SFM Amendment to NFPA 72. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.4.5

SFM is proposing this amendment to require manual fire alarm boxes to be operable with only one hand. This amendment is to clarify and correlate with existing California requirements 2001 CBC, Section 1133B8.6.1 and Federal Law, 1998 ADAAG, Section 4.4. This amendment is required to correlate with existing state regulations and federal law. Reference 1998 ADAAG, Section 4.27.4 Operation and 2001 CBC, Section 1117B.6 (4) Operation. Ensures that all Manual Signaling Boxes comply with the requirements of 1998 ADAAG, Section 4.30.4 for sight-impaired individuals. This is provided for consistency.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.4.6

SFM is purposing this amendment for clarity and correlation with existing California requirements 2001 CBC, Section 1133B8.6.1 and Federal Law, 1998 ADAAG, Section 4.4.1 concerning protruding objects in corridors, hallways, walks, passageways or aisles. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The

rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.6

SFM is proposing this amendment to change the term International to California

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.7

SFM is proposing this amendment for clarification to the activation of fire alarm notification systems. The amendment requires activation of the installed notification system upon actuation of any automatic, manual or sprinkler water-flow initiating device. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are utilizing commercial cooking systems, and addressed in the 2006 International Fire Code (IFC) and 2006 International Building Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13195, and 13195.5.

907.9 (1006.3.3.7 (1-4) 2001 CFC),

SFM is purposing to bring forth this existing SFM amendment concerning fire alarm zoning requirements for clarification and modified as necessary for correlation with the zoning requirements of the IBC/IFC and NFPA 72 (2002). The amendment also contains editorial terminology changes. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

907.9.1 (1006.3.3.7 (5), 2001 CFC)

SFM is purposing to bring forth this existing SFM amendment concerning the fire alarm annunciation requirements and modified for correlation with the IFC/IBC and NFPA 72 (2002). This amendment does not create a change in regulatory effect.

907.9.2 (1006.3.3.7, 2001 CFC)

SFM is purposing to bring forth this existing SFM amendment concerning the fire alarm annunciator panel requirements. The existing SFM amendment is being modified for clarification and to correlate with the IFC/IBC and NFPA 72 (2002). This amendment does not create a change in regulatory effect.

907.9.3 (403.1.1, 2001 CFC)

SFM is proposing this amendment to delete existing IBC language and substitute the word high-rise. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

907.9.4 (1006.3.3.3.1, 2001 CFC)

SFM is proposing this amendment to clarify what and where fire alarm notification appliance shall operate upon fire alarm system activation.

Exception # 1 which exempts high-rise buildings from notification throughout the building correlates with IBC Section 907.2.12.2 which specifies notification at the fire floor, floor above & floor below.

Exceptions # 2 & 3 exempts medical and detention facilities from notification throughout the building.

Exception # 4 allows fire alarm notification in specific zones where permitted by the enforcing agency where the building is sprinklered throughout and where the zones are separated by 2 hour fire barriers walls and fire-resistance floor assemblies.

Exception #5, allows very large open complexes such as airport terminals and factories to limit the fire alarm notification to specific zones where approved by the enforcing agency, where the building is sprinklered throughout and when complying with the distance requirements. Upon fire alarm initiation the notification appliances would be active in the zone of origin and the adjacent zones on all sides. The fire alarm system would also be required to have the capability to activate all other notification zones by automatic and manual means. The 300 ft specified distance is the maximum length of a single notification zone as required by IFC Section 907.9, so that upon fire alarm initiation, the zone of origin and the zones on all sides would be active. The fire alarm system would also be required to have the capability to activate all other notification zones by automatic and manual means. These exceptions will offer viable options for fire alarm notification zoning to the architects, facility administrators and code officials for the overall building fire and life safety plan without reducing fire safety for the occupants.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.10.1

SFM is proposing this amendment to Exception #1 to specify that remodel and alteration projects of Group I-2 and Group I-2.1 occupancies are not exempt from the visible notification appliance requirements. This amendment is maintaining the fire and life safety policy of the SFM. This amendment does not create a change in regulatory effect.

SFM is proposing this amendment to Exception #2 to specify that only “enclosed exit stairways, exterior exit stairs and exterior exit ramps” are exempt from the requirements for fire alarm visible notification appliances. The definition of “exit” in Section 1002.1 includes exit passageways. Omitting visual appliances from passageways is inappropriate. Exit passageways can be used in the same manner as corridors. The amended text provides clarification, defining where visual alarm appliances are not required in exit and exit discharge areas which is consistent with NFPA 72. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. This amendment does not create a change in regulatory effect.

907.10.1.1

SFM is proposing to bring forth the existing SFM amendment addressing visible notification appliances for the hearing impaired with editorial modifications for clarity. Item # 1, Restrooms has been expanded for clarification to include sanitary facilities, bathrooms and shower rooms. Item # 11 Common Areas which is already addressed in this IBC section is being deleted and replaced with the term Classrooms for clarification. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.10.1.4

SFM is proposing this amendment to delete the reference to ICC A117.1 and replace with a reference to NFPA 72, which is the adopted standard. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.10.1.5 (9102.1, subsection 4.4.5, 2001 CFC)

SFM is proposing to bring forth an existing SFM amendment addressing protective social care facilities. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.10.2 (308.9, 2001 CBC)

SFM is proposing to bring forth these existing SFM requirements that require the fire alarm signal to have a maximum sound level of 110 decibels. These amendments are required for correlation with the existing SFM CFC and NFPA 72 Amendments, existing CALOSHA requirements and the new ADA requirements that allow of a maximum of 110 dBA.

The amendment also includes the existing SFM amendment from CBC Section 308.9 which specifies that audible fire alarm devices placed in patient areas shall be chimes or similar sounding devices only for alerting facility staff. The exception is being modified to specify "patient" areas and not critical areas of Group I-2 occupancies. Critical care areas are not defined in the code. If not clearly defined, what is or is not considered a critical care area is subject to interpretation. Patient areas are clearly understandable and are consistent with current code and similar provisions included in section 907.2.6. The amendment correlates with the requirements of Section 907.2.6.2 and is consistent with the previous requirements contained in the 2001 California Building Code. This amendment does not create a change in regulatory effect

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.10.2.1 (1006.3.3.3.2, 2001 CBC)

A SFM is proposing to bring forth this amendment for clarification and correlation with NFPA 72 (2002), Section 6.8.6.4.1, which requires the audible fire alarm signal for evacuation to be the ANSI S3.41 standard "three pulse temporal patterns. This amendment is consistent with the previous requirements contained in the 2001 California Building Code. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.11

SFM is proposing this amendment for clarification and editorial. The amendment specifies that automatic fire detectors utilized for performing fire safety functions to be connected to the building's fire alarm control unit where a fire alarm system is installed. The amendment also includes modifications to current terminology to correlate with the definition of fire alarm control unit as defined in Chapter 2 and 9 of the IBC/IFC and in NFPA 72 (2002). This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.12

SFM is proposing this amendment to correlate with the current terminology of fire alarm control unit as defined in Chapter 2 and 9 of the IBC/IFC and in NFPA 72 (2002). This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.15 (330A.1, 2001 CBC)

SFM is proposing this amendment to replace International with California. SFM is also proposing to delete the term smoke detector and add a reference to Section 907.2.6.3.4 which addresses fire alarm monitoring requirements in Group I-3 occupancies. Without the amendment, smoke detectors in Group I-3 occupancies would not be monitored by an approved supervising station. This amendment is consistent with the previous requirements contained in the 2001 CFC which will maintain the fire and life safety policy of the SFM. The amendment does not have a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.17

SFM is proposing this amendment for clarity and correlation with the testing requirements contained in NFPA 72 (2002). The requirements contained in this amendment are currently in effect and will not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

907.20.3

SFM is proposing this amendment for clarify and correlation with the testing requirements of smoke detectors contained in NFPA 72 (2002), which requires sensitivity testing for smoke detectors only. The requirements contained in this amendment are currently in effect and will not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

909 SMOKE CONTROL SYSTEMS

909.1

SFM is proposing this amendment to change the term International to California.

909.2

SFM is proposing this amendment to change the term International to California.

909.3

SFM is proposing this amendment to change the term International to California.

909.4.3

SFM is proposing this amendment to change the term International to California.

909.5

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

909.5.2 Opening protection.

SFM is proposing this amendment to clarify intent, simplify compliance and maintain consistency in the requirements for smoke control and related control devices used for smoke control in health care occupancies located in Chapter 7.

This proposal allows the use of both automatic-closing and self-closing doors in smoke barrier walls. The exclusive use of automatic-closing doors at locations such as restrooms, storage rooms and mechanical rooms are costly and impractical.

In addition SFM is proposing this amendment to change the term International to California.

Exception #1 has been amended to require smoke detectors provided for releasing service also activate the fire alarm system. These amendments are necessary to conform with regulatory requirements that health care facilities must meet in order to receive certification for federal funds such as Medicare/Medicaid. These requirements are more restrictive than IBC but must be met as a condition of participation in federal programs. Health facilities cannot meet economic needs without participation in this program.

Exception #2 is provided with clarifying language indicating the airflow method is not acceptable in a Group I-2. These amendments are necessary to conform with regulatory requirements that health care facilities must meet in order to receive certification for federal funds such as Medicare/Medicaid. These requirements are more restrictive than IBC but must be met as a condition of participation in federal programs. Health facilities cannot meet economic needs without participation in this program.

Exception #3 is amended to specify one-hour fire rated doors installed across corridors be provided with positive latching. Such doors when not provided with latching do not provide an effective smoke or fire barrier. Due to air pressure differentials, such doors may not remain closed when latching is not provided.

Exception #6 is added to indicate the scope of a total detection system for this application. Without this amendment, a total detection system installed in accordance with NFPA 72 would require detection in all areas including attics, sub floor spaces and above ceilings. This amendment limits the installation of detection system to locations served by the HVAC system.

The requirements contained in this amendment are currently in effect and will not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

909.5.2.1

SFM is proposing this amendment to change the term International to California.

909.10.2

SFM is proposing this amendment to change the term International to California.

909.10.5

SFM is proposing this amendment to change the term International to California.

909.11

SFM is proposing this amendment to change the term International to California.

909.12.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

909.16.1

SFM is proposing this amendment to address current technologies for status indicators for smoke control systems Existing code limits you to pilot lamps only, and does not address technologies currently available.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

909.16.3

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

911.2

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921

912.3 (329A.4, 2001 CBC)

SFM is proposing to bring forth this existing SFM amendment regarding Fire Department Connections at Group I-3, detention facilities. The amendment does not have a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

912.5

SFM is proposing this amendment to require backflow protection to meet the requirements of Health and Safety Code Section 13114. In addition SFM is proposing this amendment to change the term International to California. The amendment does not have a change in regulatory effect.

912.6

SFM is proposing to add a reference to Title 19, CCR Chapter 5. This is consistent with Health and Safety Code Section 13195. The amendment does not have a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

913.5

SFM is proposing to add a reference to Title 19, CCR Chapter 5. This is consistent with Health and Safety Code Section 13195. The amendment does not have a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

914.1

SFM is proposing this amendment to change the term International to California.

914.2.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

914.3.1 (403.2.1 2001 CBC)

SFM is proposing this existing SFM amendment to provide water-flow alarm initiating devices at each floor. The proposed code does not require the installation of a water-flow device at each floor of a high-rise building. These water-flow devices should be required for the following reasons: 1) Identification of precisely where the fire floor is located. 2) Specific fire floor occupant notification that will lead to more effective and efficient evacuation of the floors intended to be evacuated. 3) Better facilitate the deployment of emergency personnel and equipment to the affected floors. 4) Allows for staged evacuation rather than total evacuation, which may impede or delay responding emergency personnel. In addition SFM is proposing this amendment to change the term International to California. This is consistent with Health and Safety Code Section 13210. The amendment does not have a change in regulatory effect.

914.3.6.1

SFM is proposing to add this amendment to direct the user to the section in the building code regarding smoke control systems. The amendment does not have a change in regulatory effect

914.3.6.2

SFM is proposing to add this amendment to direct the user to the section in the building code regarding smoke control systems. The amendment does not have a change in regulatory effect

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

914.5.3

SFM is proposing this amendment to change the term International to California.

914.10

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

914.11 – 914.11.2 (Article 40, 2001 CFC)

SFM is proposing to bring forth the fire protection requirements for Motion Picture and Television Production Studio, Sound Stages. This is consistent with current regulations. The amendment does not have a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

**CHAPTER 10
MEANS OF EGRESS**

SFM is proposing to adopt entire chapter with amendments.

1001.1

SFM is proposing this amendment to delete reference to the International Residential Code. SFM is not adopting that document.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

1002

[B] PHOTOLUMINESCENT

[B] SELF-LUMINOUS

[B] 1003.1

[B] 1003.2

[B] 1003.3

[B] 1003.3.3.1

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1003.3.4

SFM is proposing this amendment to change the term International to California.

[B] 1003.5

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

SFM is also proposing to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] Table 1005.1

[B] 1006.1

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1006.3

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1007.1

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1007.2

[B] 1007.4

[B] 1007.5

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1007.6.1

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1007.6.2

[B] 1007.8

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1007.9

[B] 1008.1.1

[B] 1008.1.1.1

[B] 1008.1.2

[B] 1008.1.3.3

[B] 1008.1.3.4

[B] 1008.1.3.6

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1008.1.6

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1008.1.8.1

[B] 1008.1.8.6

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1008.1.8.7

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1008.1.9

[B] 1009.1

[B] 1009.4

[B] 1009.10

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1009.11.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1011.1

[B] 1011.3

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1011.4

1011.5.3

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1011.6

[B] 1011.7

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1012.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1012.7

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1013.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1013.3

[B] 1014.2

[B] 1014.2.2

[B] 1014.2.2.1

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1014.4.1

[B] 1015.5

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1015.7

[B] TABLE 1016.1

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments. SFM is also proposing to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life

and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1017.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] TABLE 1017.1

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments. SFM is also proposing to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1017.4

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1017.4.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1017.5

[B] TABLE 1019.2

[B] 1020.1

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is

following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments. SFM is also proposing to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1020.1.1

[B] 1020.1.2

[B] 1020.1.3

[B] 1020.1.4

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1020.1.6.1

[B] 1020.1.6.1.1

[B] 1020.1.6.1.2

[B] 1020.1.6.1.3

[B] 1020.1.6.1.4

[B] 1020.1.6.1.5

[B] 1020.1.6.2

[B] 1020.1.7

[B] 1020.1.7.1

[B] 1020.1.7.2

[B] 1021.2

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

1021.3

1021.4

1021.5

1022.2

1022.3

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1023.2

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

1024.3

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1024.6

[B] 1025.1

[B] 1025.2

[B] 1025.3

[B] 1025.3.1

[B] 1025.6.1

[B] 1025.6.4

[B] 1025.9.1

[B] 1025.10

[B] 1026.1

[B] 1026.4

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] 1027.5

[B] 1027.17

[B] 1027.17.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] Table 1027.17.2

SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 11 – AVIATION FACILITIES

The SFM is proposing to adopt this entire Chapter, without amendments.

CHAPTER 12 – DRY CLEANING

The SFM is proposing to adopt this entire Chapter, without amendments.

1207.1

SFM is proposing this amendment to change the term International to California.

CHAPTER 13 – COMBUSTIBLE DUST-PRODUCING OPERATIONS

The SFM is proposing to adopt this entire Chapter, without amendments.

Tables 1304.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 14 – FIRE SAFETY DURING CONSTRUCTION AND DEMOLITION

The SFM is proposing to adopt this entire Chapter, without amendments.

1403.1

SFM is proposing this amendment to change the term International to California and to delete the reference to the International Fuel Gas Code and replace it with reference to the California Mechanical Code. California is not adopting the International Fuel Gas Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

1403.3

SFM is proposing this amendment to delete reference to the International Fuel Gas Code and reference the California Mechanical Code in it's place. California is not adopting the International Fuel Gas Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

1404.7

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

1414.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 15 – FLAMMABLE FINISHES

The SFM is proposing to adopt this entire Chapter, without amendments.

1502, 1504.3.1, 1504.3.2.6, 1504.3.3, 1505.2

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

1503.2.1, 1503.2.1.1, 1503.2.1.4, 1503.2.5, 1504.2, 1504.6.1.2.2, 1504.9.4

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

1504.7

SFM is proposing this amendment to change the term International to California. In addition, SFM is proposing to delete reference to specific section in the IMC and instead make a general reference to the CMC. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

1504.7.2

SFM is proposing this amendment to change the term International to California. In addition, SFM is proposing to delete reference to specific section in the IMC and instead make a general reference to the CMC. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 16 – FRUIT AND CROP RIPENING

The SFM is proposing to not adopt this entire Chapter.

CHAPTER 17 – FUMIGATION AND THERMAL INSECTICIDAL FOGGING

The SFM is proposing to not adopt this entire Chapter.

CHAPTER 18 – SEMICONDUCTOR FABRICATION FACILITIES

The SFM is proposing to adopt this entire Chapter, without amendments.

1801.1, 1801.4, 1803.10.4, 1803.14, 1803.14.1, 1803.15.1, 1803.2.2, 1803.3.1, 1803.3.2, 1803.3.3, 1803.3.4, 1803.3.8, 1804.3.1, 1805.2.2.1, 1805.2.3.2, 1805.3.1, 1805.3.2, 1805.3.3

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life

and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

1803.7.1, 1803.7.2, 1803.7.3,

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 19 – LUMBER YARDS AND WOODWORKING FACILITIES

The SFM is proposing to adopt this entire Chapter, without amendments.

1903.1, 1903.2, 1903.3

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

1903.4

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 20 – MANUFACTURE OF ORGANIC COATINGS

The SFM is proposing to adopt this entire Chapter, without amendments.

2004.1

SFM is proposing this amendment to change the term ICC to California.

2005.1, 2009.2, 2009.4, 2009.6

SFM is proposing this amendment to change the term International to California.

CHAPTER 21 – INDUSTRIAL OVENS

The SFM is proposing to adopt this entire Chapter, with amendments.

2101.1, 2103.1, 2104.2

SFM is proposing this amendment to delete reference to the International Fuel Gas Code. California is not adopting the International Fuel Gas Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2104.1

SFM is proposing this amendment to delete reference to the International Fuel Gas Code and reference the California Mechanical Code in it's place. SFM is not adopting the International Fuel Gas Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2106.3

SFM is proposing to amend this section to delete reference to NFPA 10. The SFM is not adopting NFPA 10 at this time.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

Health and Safety Code 13160. Regulations and standards; administration. With the advice of the State Fire Advisory Board, the State Fire Marshal shall adopt, in accordance with the provisions of Chapter 3.5 (commencing with Section 11340) of Part 1 of Division 3 of Title 2 of the Government Code, and administer regulations and standards as he or she may deem necessary for the protection and preservation of life and property to control the servicing, including charging, and testing, of all portable fire extinguishers for controlling and extinguishing fires, and for controlling the sale and marketing of all such devices with respect to conformance with standards of their use, capacity, and effectiveness. In adopting the regulations, the State Fire Marshal shall consider the standards of the National Fire Protection Association.

13161. Legislative intention. It is the legislative intention in enacting this chapter that the provisions of this chapter and the regulations and standards adopted by the State Fire Marshal pursuant to this chapter shall apply uniformly throughout the State of California and no county, city, city or county or district shall adopt or enforce any ordinance or rule or regulation regarding portable fire extinguishers which is inconsistent with the provisions of this chapter or the regulations and standards adopted by the State Fire Marshal pursuant to this chapter.

Health and Safety Code 13160 requires regulations be written in accordance with Government Code Section 11340 this section establish the Office of Administrative Law and they establish Title 19 California Code of Regulation, for the State Fire Marshal that is why our regulations must be in Title 19.

CHAPTER 22 – MOTOR FUEL-DISPENSING FACILITIES AND REPAIR GARAGES

The SFM is proposing to adopt this entire Chapter, with amendments.

2201.1, 2201.6,

SFM is proposing this amendment to delete reference to the International Fuel Gas Code. California is not adopting the International Fuel Gas Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2201.4, 2208.3, 2208.3.1, 2209.3.2.6.1, 2209.3.3, 2210.1, 2211.1, 2211.2.3, 2211.3.1, 2211.4.1, 2211.4.3, 2211.7.1, 2211.8.1.2.3

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2201.5, 2205.4, 2208.8.1.2.4, 2209.2.3, 2211.8.1.2.4

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2203.1 and 2203.1.1 (Article 52, 2001 CFC)

SFM is proposing to bring forth a SFM amendment addressing protection of fuel dispensers. This amendment is consistent with the previous requirements contained in the 2001 California Fire Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect. SFM is also proposing to delete "International" and insert "California" where referencing the building code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2209.3.2.3

SFM is proposing this amendment to delete the term "International" and to replace it with "California" as mandated by building standard statute. SFM is also proposing this amendment to delete reference to the International Fuel Gas Code. SFM is not adopting the International Fuel Gas Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2209.3.2.6

SFM is proposing this amendment to delete reference to the International Fuel Gas Code and reference the California Mechanical Code in it's place. SFM is not adopting the International Fuel Gas Code.

2211.3.1

SFM is proposing this amendment to change the term International to California. SFM is also proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 23 – HIGH-PILED COMBUSTIBLE STORAGE

SFM is proposing to adopt this entire Chapter, without amendments.

2301.3, Table 2306.2, 2306.3.1, 2306.3.2.1, 2306.3.2.2, 2306.8, 2307.2, 2308.2

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 24 – TENTS, CANOPIES AND OTHER MEMBRANE STRUCTURES

The SFM is proposing to adopt this entire Chapter, with amendments.

2403.12.6.1, 2403.8.2, 2404.1, 2404.15.7

SFM is proposing this amendment to change the term International to California.

2404.15.1

SFM is proposing this amendment to change the term International to California. SFM is also proposing this amendment to delete reference to the International Fuel Gas Code. SFM is not adopting the International Fuel Gas Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2404.15.2, 2404.16.1

SFM is also proposing this amendment to delete reference to the International Fuel Gas Code. SFM is not adopting the International Fuel Gas Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2402.1

SFM is proposing to amend this section to define canopies. This is necessary to resolve the conflict between definitions in the IBC and the IFC.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2404.23

SFM is proposing to bring forth existing SFM amendments found in CBC Section 3106E.4. The IFC does not address the issue of obstructions in the means of egress in tents, canopies and other membrane structures.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 25 – TIRE REBUILDING AND TIRE STORAGE

The SFM is proposing to not adopt this entire Chapter.

CHAPTER 26 – WELDING AND OTHER HOT WORK

The SFM is proposing to adopt this entire Chapter, without amendments.

2606.4

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 27 – HAZARDOUS MATERIALS – GENERAL PROVISIONS

The SFM is proposing to adopt this entire Chapter, with amendments.

**2703.2.2.2, 2703.2.8, 2703.7.3, 2703.8.1, 2703.8.3.1, 2703.8.4.1, 2703.8.4.2, 2703.8.5.2, 2703.8.6.2, 2703.9.9
2704.13, 2704.2.2.6, 2705.2, 2705.3.9, Table 2703.1.1(1)** (footnotes)

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life

and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2703.8.7.1, 2703.9.4, 2704.7, 2705.1.5,

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2701.5.1 (8001.3.3, 2001 CFC)

SFM is proposing to added this Appendix Section (HMMP – Section 1 thru 4 and HMIS – Section I thru VI), which are being brought forward from the 2001 CFC that are necessary for the SFM's statutory coordination of the "Unified Plan" defined within the Certified Unified Program Agency (CUPA) criteria. The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to insure that the SFM has the statutory responsibility for Section(s) 2701.5.1 and 2705.5.2 of the 2006 International Fire Code (IFC) and published as the 2007 CFC pursuant to Health and Safety Code Section(s) 13143.9 concerning the Hazardous Materials Management Plan (HMMP) and Hazardous Materials Inventory Statement (HMIS). To avoid overlap in responsibilities, CUPA and SFM responsibilities for HMMP and HMIS (Health and Safety Code Section 25404(c)(6)) is to: (1) SFM will coordinate program responsibilities concerning the HMMP and HMIS, (2) The HMMP and HMIS, when required, will comply with Health and Safety Code Section 25500 through 25545 and CCR, Title-19, Division 2, Chapter 4, Section 2620 et. seq., and (3) Each CUPA will ensure full access to and availability of information submitted under Section 2701.5.1 and 2705.5.2, Part 9 of CCR Title-24, to any Chief or any county or city fire department or district with shared responsibility for protection of the public health and safety of the environment. The CUPA will forward the data collected, within 15-days of receipt and conformation, to the county or city fire department district. These amendments do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2701.5.2 (8001.3.3, 2001 CFC)

SFM is proposing to added this Appendix Section (HMMP – Section 1 thru 4 and HMIS – Section I thru VI), which are being brought forward from the 2001 CFC deemed necessary for the SFM's statutory coordination of the "Unified Plan" defined within the Certified Unified Program Agency (CUPA) criteria. The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to insure that the SFM has the statutory responsibility for Section(s) 2701.5.1 and 2705.5.2 of the 2006 International Fire Code (IFC) and published as the 2007 CFC pursuant to Health and Safety Code Section(s) 13143.9 concerning the Hazardous Materials Management Plan (HMMP) and Hazardous Materials Inventory Statement (HMIS). To avoid overlap in responsibilities, CUPA and SFM responsibilities for HMMP and HMIS (Health and Safety Code Section 25404(c)(6)) is to: (1) SFM will coordinate program responsibilities concerning the HMMP and HMIS, (2) The HMMP and HMIS, when required, will comply with Health and Safety Code Section 25500 through 25545 and CCR, Title-19, Division 2, Chapter 4, Section 2620 et. seq., and (3) Each CUPA will ensure full access to and availability of information submitted under Section 2701.5.1 and 2705.5.2, Part 9 of CCR Title-24, to any Chief or any county or city fire department or district with shared responsibility for protection of the public health and safety of the environment. The CUPA will forward the data collected, within 15-days of receipt and conformation, to the county or city fire department district. These amendments do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2704.3.1 (8003.1.4.2, 2001 CFC)

SFM is proposing to bring forth an existing SFM amendment addressing exhaust systems exhausting directly to the exterior. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 28 – AEROSOLS

SFM is proposing to adopt this entire Chapter, without amendments.

2801.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 29 – COMBUSTIBLE FIBERS

SFM is proposing to adopt this entire Chapter, with amendments.

2904.3, 2904.4, 2904.5

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

2903.5

SFM is proposing this amendment to change the term International to California. In addition, SFM is proposing to delete reference to specific section in the IMC and instead make a general reference to the CMC. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 30 – COMPRESSED GASES

SFM is proposing to adopt this entire Chapter, without amendments.

3001.1

SFM is proposing this amendment to delete reference to the International Fuel Gas Code and reference the California Mechanical Code in it's place. California is not adopting the International Fuel Gas Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3003.16.1, 3003.16.2, 3003.16.9, 3005.5, 3006.2.2

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3003.16.11, 3003.16.14, 3003.8

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3003.7.6

SFM is proposing this amendment to change the term International to California. SFM is also proposing this amendment to change the term ICC to California.

CHAPTER 31 – CORROSIVE MATERIALS

The SFM is proposing to adopt this entire Chapter, with amendments.

3104.2.1

SFM is proposing this amendment to provide secondary containment for all above ground storage tanks. This amendment would maintain the current requirement for secondary containment found in the 2001 CFC under Section 8003.1.3.3 and Table 8003.1-A

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and

published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 32 – CRYOGENIC FLUIDS

SFM is proposing to adopt this entire Chapter, without amendments.

3203.1.2, 3203.5.2, 3204.2.1.2, 3204.2.1.3, 3204.2.2.2, 3204.2.2.3, 3204.3.1.1, 3204.4.3, 3205.4.1, 3205.4.1.1
SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3203.7, 3203.7.2

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 33 – EXPLOSIVES AND FIRE WORKS

The SFM is proposing to adopt this entire Chapter, with amendments.

3301.1. (Health and Safety Code 12000-12401)

SFM is proposing this amendment to cite Title 19 CCR. Explosives and fireworks are addressed in Chapters 6 and 10 of Title 19 CCR. This amendment is statutorily mandated. This amendment is consistent with the previous requirements and maintains the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3301.1.1 thru 3307.15 (Health and Safety Code 12000-12401)

SFM is proposing to delete these sections because they are addressed in Chapter 10, Title 19 CCR. This amendment is statutorily mandated. The requirements found in Title 19 CCR are more restrictive than those found in the IFC. This amendment is consistent with the previous requirements and maintains the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and

published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3308.1 (Health and Safety Code 12500-12725)

SFM is proposing this amendment to delete references to NFPA standards and to direct the user to Chapter 6, Title 19 CCR. Fireworks are addressed in Chapter 6, Title 19 CCR. This amendment is statutorily mandated. This amendment is consistent with the previous requirements and maintains the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3308.1.1 (Health and Safety Code 12500-12725)

SFM is proposing this amendment to delineate the scope of the fireworks requirements found in Title 19. This amendment is statutorily mandated. This amendment is consistent with the previous requirements and maintains the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3308.2 thru 3308.11(Health and Safety Code 12500-12725)

SFM is proposing to delete these sections because they are addressed in Chapter 6, Title 19 CCR. This amendment is statutorily mandated. The requirements found in Title 19 CCR are more restrictive than those found in the IFC. This amendment is consistent with the previous requirements and maintains the fire and life safety policy of the SFM. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 34 – FLAMMABLE AND COMBUSTIBLE LIQUIDS

The SFM is proposing to adopt this entire Chapter, with amendments.

3401.3, 3403.6.1, 3404.2.7.7, 3404.2.8.1, 3404.2.8.2, 3404.2.8.9, 3404.2.9.2, 3404.2.9.3, 3404.2.9.5.1, 3404.3.3.5, 3404.3.7.1, 3404.3.8, 3405.3.4, 3405.3.5.3, 3405.3.7.1, 3405.3.7.2, 3405.3.7.3, 3405.3.7.4, 3405.3.7.5.1, 3406.2, 3406.2.3, 3406.2.4.4, 3406.4.1, 3406.4.4

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3403.1, 3403.1.3, 3404.2.8.12, 3404.2.8.17, 3406.2.8,
SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3404.2.1

SFM is proposing this amendment to add an exception to cite an API recommended practice to address changing of tank contents. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3404.2.9.1.2

SFM is proposing this amendment to specify a particular Section (4.8) in NFPA 11. This is to clarify the types of systems identified in NFPA 11. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3406.5.1.11

SFM is proposing this amendment to add an exception to cite an API recommended practice to address changing of tank contents. The amendment does not have change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 35 – FLAMMABLE GASES

The SFM is proposing to adopt this entire Chapter, without amendments.

3501.1, 3503.1.4

SFM is proposing this amendment to delete reference to the International Fuel Gas Code and reference the California Mechanical Code in it's place. California is not adopting the International Fuel Gas Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3503.1.5, 3503.1.5.1

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 36 – FLAMMABLE SOLIDS

The SFM is proposing to adopt this entire Chapter, without amendments.

3503.1.5.1, 3606.2.2, 3606.2.3, 3606.4.2

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3606.5.5, 3606.5.6

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 37 – HIGHLY TOXIC AND TOXIC MATERIALS

The SFM is proposing to adopt this entire Chapter, with amendments.

3703.1.3, 3703.1.4.2, 3703.2.3.2, 3705.3.1, 3705.3.2

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3704.2.2.7

SFM is proposing to amend exception 2 to require that gas detection systems be “listed or approved”.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3704.2.2.8

SFM is proposing this amendment to change the term ICC to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 38 – LIQUEFIED PETROLEUM GASES

The SFM is proposing to adopt this entire Chapter, without amendments.

3803.1, 3803.2.1.7, 3803.3

SFM is proposing this amendment to delete reference to the International Fuel Gas Code and reference the California Mechanical Code in its place. California is not adopting the International Fuel Gas Code.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

3804.2, 3809.11.2

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 39 – ORGANIC PEROXIDES

The SFM is proposing to adopt this entire Chapter, without amendments.

3904.1.2

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 40 – OXIDIZERS

The SFM is proposing to adopt this entire Chapter, without amendments.

4004.1.2

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 41 – PYROPHORIC MATERIALS

The SFM is proposing to adopt this entire Chapter, without amendments.

4104.1.4, 4106.1.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 42 – PYROXYLIN (CELLULOSE NITRATE) PLASTICS

The SFM is proposing to adopt this entire Chapter, without amendments.

CHAPTER 43 – UNSTABLE (REACTIVE) MATERIALS

The SFM is proposing to adopt this entire Chapter, without amendments.

4304.1

SFM is proposing this amendment to change the term International to California.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 44 – WATER-REACTIVE SOLIDS AND LIQUIDS

The SFM is proposing to adopt this entire Chapter, without amendments.

CHAPTER 45 – REFERENCED STANDARDS

The SFM is proposing to adopt this entire Chapter, with amendments.

ASTM Standards

ASTM D2898

SFM is proposing to bring forth these standards from the building code to the fire code. These standards are referenced for Wildland-Urban Interface Fire Areas.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

ASTM D3201

SFM is proposing to bring forth these standards from the building code to the fire code. These standards are referenced for Wildland-Urban Interface Fire Areas.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

ASTM E648 (Appendix Chapter 324A.4, 2001 CBC)

SFM is proposing to bring forth this amendment to include ASTM E648. The IBC references the “Pill Test” for radiant flux, the correct standard for addressing Critical Radiant Flux is ASTM E648. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. This amendment does not create a change in regulatory effect.

ASTM E2010

SFM is proposing to adopt this standard. This standard is referenced for Wildland-Urban Interface Fire Areas.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

ASTM E2074

SFM is proposing to adopt this standard. This standard is referenced for Wildland-Urban Interface Fire Areas.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and

published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

FM Standards

FM 3260 (3504.1.3, 2001 CBC) and FM 3001 (3504.1.3, 2001 CBC)

SFM is proposing to bring forth this amendment to include FM 3260 and 3001. The IBC has not adopted a reference standard to address radiant energy-sensing fire detectors for automatic fire alarm signaling. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

NFPA Standards

NFPA-11, NFPA-12, NFPA-12A, NFPA-32, NFPA-35, NFPA-37, NFPA-52, NFPA-54, NFPA-59A, NFPA-92A, NFPA-99, NFPA-101, NFPA-110, NFPA-111, NFPA-120, NFPA-160, NFPA-241, NFPA-286, NFPA-303, NFPA-409, NFPA-430, NFPA-484, NFPA-495, NFPA-498, NFPA-505, NFPA-654, NFPA-701, NFPA-703, NFPA-1123, NFPA-1124, NFPA-1126 (Relocated from 2001 CFC, Section 9101.1.3)

SFM is proposing to bring forth these amendments to the Standard to address the various provisions associated with these specific standards. These amendments are consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. These amendments do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

NFPA-13 (Relocated from 2001 CFC, Section 9101.1.3)

9.3.5.8.9, 9.3.5.9.4

SFM is proposing to bring forth these amendments to the Standard to address seismic concerns. The 1994 Northridge Earthquake study found the lag screws and powder driven fasteners failed during seismic movement and additional light scheduled sway bracing failed. These amendments are consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. These amendments do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

NFPA-72 (Relocated from 2001 CFC, Section 9101.1.3)

4.4.4.4, 5.12.4, 5.12.8, 6.4.2.2.2, 6.8.5.4.1(2), 6.8.5.4.1(5), 7.4.1.2, 7.4.3.1, 7.4.3.2.1, 11.7.2.1, 11.7.5.7.1

SFM is proposing to bring forth these amendments to NFPA 72. These amendments address various fire alarm issues which are not adequately addressed in the standard and to correlate OSHA regulations. These amendments are consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. These amendments do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and

published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

SFM Standards

SFM 12-3, SFM 12-7-3, SFM 12-8-100, SFM 12-10-1, SFM 12-10-2, SFM 12-10-3, SFM 12-7A-1, SFM 12-7A-2, SFM 12-7A-3, SFM 12-7A-4 (3504.1.1, 2001 CBC)

SFM is proposing to bring forth these SFM Standards. There are no national recognized corresponding standards to address these items. These Standards are consistent with the previous requirements contained in the 2001 California Building Code. These Standards do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

SFM 12-4-1, SFM-12-7-1, SFM 12-7-2, SFM 12-8-1A, SFM 12-8-1B, SFM 12-72-1, SFM 12-72-2, SFM 12-72-3

SFM is proposing to repeal these SFM Standards. Repealing these SFM Standards will eliminate the duplication of national standards. This action does not create a change in regulatory effect

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

UL Standards

UL 13, UL 193, UL 199, UL 228, UL 260, UL 262, UL 268, UL 268A, UL 312, UL 346, UL 464, UL 497B, UL 521, UL 539, UL 632, UL 753, UL 813, UL 884, UL 913, UL 916, UL 924, UL 985, UL 1091, UL 1424, UL 1480, UL 1481, UL 1484, UL 1626, UL 1711, UL 1730, UL 1971, UL 1994, UL 2034, UL 2079 (3504.1.3, 2001 CBC)

SFM is proposing to bring forth these UL Standards. These Standards are consistent with the previous requirements contained in the 2001 California Building Code. These Standards do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

UL 38

14.1.5, Appendix B, Section 4.1.5

SFM is proposing to amend this Standard to address signaling boxes with glass or similar panels. SFM amendments are required to correlate with existing accessibility state regulations and federal law. This is required per 1998 Federal Statue ADAG, Section 4.4.1.SFM amendment required to correlate with existing accessibility state regulations and federal law. Fire alarm signaling boxes with glass or similar panels that must be broken require extra motions to operate and prohibits operation by persons with disabilities (the disabled). Reference 2001 California Building Code (CBC) Section 1117B.6#4 and 1998 American Disabilities and Accessibility Guidelines (ADAAG) Section 4.27.4. Addition of SFM amendment required for correlation with existing accessibility state regulations and federal law. Reference 2001 California Building Code (CBC) Section 1117B.6#4 and 1998 American Disabilities and Accessibility Guidelines (ADAAG) Section 4.27.4.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and

published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

UL 217 (3505.3, 2001 CBC)

34.2.1

SFM is proposing to bring forth this amendment to UL 217 to address alarm silencing. Carry over existing SFM Amendment from 2001 CBC specifying requirements for alarms placed in silence or “hush” mode to alert a distinctive audible trouble signal. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

UL 864-(3505.6, 2001 CBC)

55.1, 55.2.2, 55.2.9, 89.1.10,

SFM is proposing to bring forth this amendment to UL 864 to address alarm verification. This amendment is consistent with the previous requirements contained in the 2001 California Building Code, which will maintain the fire and life safety policy of the SFM. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 46

**MOTION PICTURE AND TELEVISION PRODUCTION STUDIO SOUND STAGES,
APPROVED PRODUCTION FACILITIES, AND PRODUCTION LOCATIONS**

SFM is proposing adoption of this entire Chapter with amendments.

4601 thru 4611.15 (Article 40, 2001 CFC)

SFM is proposing to create a new Chapter and bring forth existing requirements for Motion Picture Production Studio Sound Stages, Approved Production Facilities, and Production Locations. These types of facilities are not adequately addressed in model code. These amendments are consistent with the previous requirements and will maintain the fire and life safety policy of the SFM. These amendments do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

CHAPTER 47

**REQUIREMENTS FOR WILDLAND-URBAN
INTERFACE FIRE AREAS**

SFM is proposing adoption of this entire Chapter with amendments.

4701 thru 4713 (Article 86A & 86B, 2001 CFC)

SFM is proposing to create a new Chapter and bring forth requirements for Wildland-Urban Interface Fire Areas. These areas are not addressed in the IFC. These amendments are consistent with the previous requirements and will maintain the fire and life safety policy of the SFM. These amendments do not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Fire Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

APPENDIX CHAPTER 1 ADMINISTRATION

IBC Chapter 1 Administration relocated here as an Appendix

SFM is proposing to adopt only those Sections in Appendix Chapter 1 listed in the matrix adoption table.

Table 105.6.8

The SFM is proposing to amend this Table by adding the type of gas and amount of gas to conform to the current statutory/regulatory criteria which is used to identify those materials (compressed gases) permitted by current requirements.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in SFM regulated occupancies that are addressed in the 2006 International Fire Code (IFC) and 2006 International Fire Code (IBC) and published as the 200_ CFC and CBC pursuant to Health and Safety Code Section (s) 13108, and 13143.

Table 105.6.20

SFM is proposing to amend this table by amending this table to conform to the current statutory/regulatory criteria which is used to identify those materials (hazardous materials) permitted by current requirements.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in SFM regulated occupancies that are addressed in the 2006 International Fire Code (IFC) and 2006 International Fire Code (IBC) and published as the 2007 CFC and CBC pursuant to Health and Safety Code Section (s) 13108, and 13143.9.

105.6.47

SFM is proposing to bring forth this existing SFM amendment relating to additional permits, production facilities, pyrotechnics and special effects and live audiences. This amendment does not create a change in regulatory effect.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

[B] APPENDIX CHAPTER 4

SPECIAL DETAILED REQUIREMENTS BASED ON USE AND OCCUPANCY

SFM is proposing adoption of this entire Appendix Chapter.

425.1 thru 425.9

SFM is proposing this new appendix for licensed 24-Hour Care Facilities in Group I-1, R-3.1, R-4 Occupancies. SFM is correlating this amendment which is derived from the amendment proposed to the IBC. The promulgation and format of the IFC and IBC necessitate this action. Code sections that have [B] in front of them are considered by the ICC Building Code Development Committee for the IBC and correlated into the IFC where necessary. SFM is following the format of the code in these instances; where the primary code is the IBC and SFM is proposing amendments to the section, those same amendments are correlated into the IFC as amendments.

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to establish minimum requirements for the prevention of fire and for the protection of life and property against fire and panic in occupancies that are addressed in the 2006 International Building Code and published as the 2007 California Building Code pursuant to Health and Safety Code Section 18949.2, 13108, 13113, 13114, 13131.5, 13143 and 17921.

APPENDIX A – BOARD OF APPEALS

The SFM is proposing to not adopt this entire Appendix.

APPENDIX B – FIRE-FLOW REQUIREMENTS FOR BUILDINGS

The SFM is proposing to adopt this entire Appendix, without amendments.

APPENDIX C – FIRE HYDRANT LOCATIONS AND DISTRIBUTION

The SFM is proposing to adopt this entire Appendix, without amendments.

APPENDIX D – FIRE APPARATUS ACCESS ROADS

The SFM is proposing to not adopt this entire Appendix.

APPENDIX E – HAZARD CATEGORIES

The SFM is proposing to not adopt this entire Appendix.

APPENDIX F – HAZARD RANKING

The SFM is proposing to not adopt this entire Appendix.

APPENDIX G – CRYOGENIC FLUIDS – WEIGHT AND VOLUME EQUIVALENTS

The SFM is proposing to not adopt this entire Appendix.

APPENDIX H – HAZARDOUS MATERIALS MANAGEMENT PLANS AND HAZARDOUS MATERIALS INVENTORY STATEMENTS

The SFM is proposing to create a new Appendix to address Hazardous Material Management Plans and Hazardous Materials Inventory Statements.

The SFM is proposing to added this Appendix Section (HMMP – Section 1 thru 4 and HMIS – Section I thru VII), which are being brought forward as a SFM amendment from the 2001 CFC deemed necessary for the SFM's statutory coordination of the "Unified Plan" defined within the Certified Unified Program Agency (CUPA) criteria

The actions described above are reasonably necessary to carry out the purpose for which it is proposed. The rationale for these actions is to insure that the SFM has the statutory responsibility for Section(s) 2701.5.1 and 2705.5.2 of the 2006 International Fire Code (IFC) and published as the 2007 CFC pursuant to Health and Safety Code Section(s) 13143.9 concerning the Hazardous Materials Management Plan (HMMP) and Hazardous Materials Inventory Statement (HMIS). To avoid overlap in responsibilities, CUPA and SFM responsibilities for HMMP and HMIS (Health and Safety Code Section 25404(c)(6) is to: (1) SFM will coordinate program responsibilities concerning the HMMP and HMIS, (2) The HMMP and HMIS, when required, will comply with Health and Safety Code Section 25500 through 25545 and CCR, Title-19, Division 2, Chapter 4, Section 2620 et. seq., and (3) Each CUPA will ensure full access to and availability of information submitted under Section 2701.5.1 and 2705.5.2, Part 9 of CCR Title-24, to any Chief or any county or city fire department or district with shared responsibility for protection of the public health and safety of the environment. The CUPA will forward the data collected, within 15-days of receipt and conformation, to the county or city fire department district.

AN IDENTIFICATION OF EACH TECHNICAL, THEORETICAL, AND EMPIRICAL STUDY, REPORT, OR SIMILAR DOCUMENT UPON WHICH THE AGENCY IS RELYING IN PROPOSING THE ADOPTION, AMENDMENT, OR REPEAL.

The SFM did not rely on any technical, theoretical, and empirical study, report in proposing the amendments to the 2006 IFC.

CONSIDERATION OF REASONABLE ALTERNATIVES

(Government Code Section 11346.2(b)(3)(A))

The SFM has determined that no alternative considered would be more effective in carrying out the purpose for which the regulations are proposed or would be as effective and less burdensome to affected private persons than the proposed adoption by reference with amendments to the 2006 IFC.

REASONABLE ALTERNATIVES THE AGENCY HAS IDENTIFIED THAT WOULD LESSEN ANY ADVERSE IMPACT ON SMALL BUSINESS

(Government Code Section 11346.2(b)(3)(B))

No other alternatives have been identified or have otherwise been identified and brought to the attention of the SFM that would lessen any adverse impact on small business.

FACTS, EVIDENCE, DOCUMENTS, TESTIMONY, OR OTHER EVIDENCE OF NO SIGNIFICANT ADVERSE IMPACT ON BUSINESS

(Government Code Section 11346.2(B)(4))

The SFM has made an initial determination that this proposed action will not have a significant adverse economic impact on business. Therefore, there are no other facts, evidence, documents, testimony, or other evidence on which the SFM relies to support this rulemaking.

The SFM is required under H&SC section 18928 to propose the adoption by reference with amendments the 2006 IFC within one year after it's publication.

DUPLICATION OR CONFLICTS WITH FEDERAL REGULATIONS

The SFM has determined that there is no duplication or conflict with Federal regulations. There are no comparable federal regulations or statutes addressing the fire and life safety requirements of a mechanical code.