

**TITLE 19 PUBLIC SAFETY
DIVISION 1. STATE FIRE MARSHAL
CHAPTER 3 FIRE EXTINGUISHERS**

TEXT OF REGULATIONS

Changes are illustrated by underline for additions to language originally proposed and by ~~strikeout~~ for deletions to language originally proposed.

§ 557.19. "S" Definitions.

- (a) Sell. Offer or expose for sale, barter, trade, deliver, give away, rent, consign, lease, market, distribute or possess with the intent to sell.
- (b) Servicing. Includes one or more of the following:
 - (1) maintenance;
 - (2) recharging;
 - (3) hydrostatic testing.
- (c) Service Pressure. The normal operating pressures as indicated on the gauge or nameplate.
- (d) Service vehicle, a vehicle used for the inspection, maintenance, service, or test of portable fire extinguishers. Service vehicles must be properly registered and licensed by the California Department of Motor Vehicles as commercial vehicles.
- ~~(d)~~ (e) Signature. The written signature of the person as it appears on the Application for Certificate of Registration. A rubber stamp of name or signature is not acceptable.
- ~~(e)~~ (f) S.I. Units. Metric units of measure in accordance with the International System of Units.
- ~~(f)~~ (g) Shall. Indicates a mandatory requirement.
- ~~(g)~~ (h) Should. Indicates a recommendation or that which is advised but not required.
- ~~(h)~~ (i) Stored Pressure Fire Extinguisher. A fire extinguisher in which both the extinguishing material and expellant gas are kept in a single container and that includes a pressure indicator or gauge.

Note: Authority: Section 13160, Health and Safety Code. Reference: Sections 13160, 13162-13164, 13170, 13174-13177 and 13189-13190.2, Health and Safety Code.

§ 560.4. Vehicle Marking.

Every Concern licensed under this chapter shall display the business name, Concern license number, and business phone number on each side of each service vehicle. All letters and numerals shall be permanently affixed to the vehicle, be in contrasting colors from the background, clearly visible and at least 1 1/2 inches high and 3/4 inch wide.

Exception: Display is not required during the first 90 days after the first time commercial vehicle registration fees have been paid.

Note: Authority: Section 13160, Health and Safety Code. Reference: Sections 13160, 13170 and 13190.3, Health and Safety Code.

§560.4 5. Recall of Extinguishers.

When a manufacturer deems it necessary to recall an extinguisher model or series, the manufacturer shall notify the State Fire Marshal. Such notification shall include the reasons for the recall and procedures for replacement and the disposition of recalled extinguishers.

Note: Authority: Section 13160, Health and Safety Code. Reference: Sections 13160, 13162 and 13177, Health and Safety Code.

§ 560.5 6. Condemned Extinguishers.

Note: Authority: Section 13160, Health and Safety Code. Reference: Sections 13160, 13162 and 13177, Health and Safety Code.

§ 560.6 7. Temperature Extremes.

Note: Authority: Section 13160, Health and Safety Code. Reference: Sections 13160 and 13177, Health and Safety Code.