



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	01-07-02	Interpretation #	02-009
Topic	Visual Alarms for Hearing Impaired in Hotel Bathrooms		
Code Section(s)	§1114-B.2.4, California Building Code (1998 ed) Table 11-B3, California Building Code (1998 ed) Table B4, California Building Code (1998 ed) §1007.2.9.1.5, California Fire Code (1998 ed)		
Requested by	Captain Tom Harvey San Francisco Fire Department 689 2nd St. San Francisco, CA 94107		

Are visual warning devices designed to notify the hearing impaired persons required in the bathrooms serving accessible hotel guestrooms?

No.