



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	06-17-02	Interpretation #	02-012
Topic	Spray Booth Heaters		
Code Section(s)	§4502.10.2.2, California Fire Code (1998)		
Requested by	Gary Leinweber, Fire Marshal Mountain View Fire Department 1000 Villa St Mountain View, CA 94041-1295		

1. *Is a portable infrared heater that is moved in and out of a spray booth required to have interlocks?*

No. However, portable infrared drying apparatus must not be used in booths or rooms while spraying operations are in progress.

2. *Does Section 4502.10.2.2.5 only apply to drying apparatus that is integral to the spray booth itself?*

Yes. This section only applies to drying apparatus that is integral to the spray booth or room. Section 4502.2.2.6 addresses requirements for portable infrared apparatus.