



California State Fire Marshal
CODE INTERPRETATION

Date Issued	06-17-02	Interpretation #	02-018
Topic	School Windows and Door Placement		
Code Section(s)	Code Interpretation 00-010		
Requested by	Steve Holtrust, Fire Marshal Ontario Fire Department 414 East B Street Ontario, CA 91764		

In the case of portable classrooms, is there a requirement on where the window is placed? In some cases the window is placed on the same wall as the single exit door. Does this arrangement meet the intent of providing an alternate point of exiting?

No. A window is not considered to be an acceptable exit from a classroom.