



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	12-05-02	Interpretation #	02-041
Topic	Application of a Coiling Fire/Smoke Door System		
Code Section(s)	Section 2007. California Building Code (1998 ed)		
Requested by	Sean P. Smith 2110 March Road Roseville, CA 95747		

***Does an overhead coiling fire/smoke door system above the elevator door opening solely operable by the fire alarm system meet the intent of Section 3007?***

No. In the event the door was to close upon the activation of a fire alarm, the occupants of the elevator need to open the door without requiring special knowledge or effort. Elevator openings into a corridor must be protected in accordance with Section 1004.3.4.5.