



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	02-10-03	Interpretation #	03-012
Topic	Elevator Gurney		
Code Section(s)	§3003.5.1(a), California Building Code (2001 ed)		
Requested by	Mark Latham Santa Cruz Fire Department 230 Walnut Ave Santa Cruz, CA 95060		

*Is it the intent of Section 3003.5.1(a) to accommodate medical gurneys or to only accommodate a 76" x 24" or smaller gurney?*

The intent of the code is to accommodate an adjustable ambulance gurney with a maximum size of 76" x 24".