



## California State Fire Marshal CODE INTERPRETATION

Date Issued	03-18-03	Interpretation #	03-019
Topic	Exiting from R-2.2.1		
Code Section(s)	§1007.6.3.2.2, California Building Code (2001 ed)		
Requested by	John Gifford John Gifford Construction PO Box 2470 Porterville, CA 93258		

- 1. In Group R, Division 2.2.1 occupancy housed in a one-story single-family residence where the entry door is the primary exit, is it the intent of §1007.6.3.2.2 to require direct or semi-direct exit from each client bedroom or does this just apply to those bedrooms which contain non-ambulatory clients?***

No. The exiting requirements of §1007.6.3.2.2 apply to the bedrooms of Group R, Division 2.2.1 occupancies used by non-ambulatory clients only. It is not the intent of this section to apply these requirements to ambulatory clients.

- 2. If all of the clients in a single-story Group R, Division 2.2.1 occupancy are ambulatory, wouldn't the window escape method specified in §310.4 provide the second required exit?***

No. All Group R, Division 2 occupancies must have at least two exits. The second required exit cannot be a window. It must be an exit door.