



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	06-08-04	Interpretation #	04-028
Topic	Rooftop playgrounds		
Code Section(s)	Table 10A, California Building Code (2001)		
Requested by	Brian Heyman Chief Fire and Life Safety Officer Division of the State Architect 311 S Spring St #1301 Los Angeles, CA 90013		

Which occupancy classification, use and occupant load factor should be assigned to school rooftop playgrounds?

Based on the use, this occupancy would most closely resemble an assembly occupancy, less-concentrated use, without fixed seats. The occupant load factor would be 15 square feet per person.