



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	May 16, 2007	Interpretation #	06-071
Topic	Interconnection of School Building Fire Alarm Systems		
Code Section(s)	1006.2.4.1.1 of the CFC.		
Requested by	Dan Pavao Building Official/Fire Marshal 200 E. Main St. El Cajon, CA 92020 (619) 441-1712		

***I have a question concerning section 1006.2.4.1.1 of the CFC. When an additional building is being constructed at a private school site, is the fire alarm required to be interconnected with the existing school fire alarm system when both exceptions are met.***

No. When exceptions 1 and 2 are met the fire alarm control units would not be required to be interconnected for both private and public school campuses.

NOTE: In reviewing CFC 1006.2.4.1.1 Exception 1 and 2, it appears that there is a misprint. The word "and" was left out in between the two exceptions.