



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	May 16, 2007	Interpretation	06-080
Topic	Audible Sprinkler Flow Alarm		
Code Section(s)	CFC Section 1003.3.2, NFPA 72 4-3.4		
Requested by	Gary Hutcheson City-Wide Electronic Systems, Inc. 440 Highland Ave El Cajon, CA 92020 (619) 444-0219 ext. 117		

In a Group R-1 Occupancy where a “single approved audible sprinkler flow alarm” is located in the interior, is this single audible device considered a fire alarm system notification appliance, and required to meet the audibility and installation requirements of Section 4-3-4 NFPA 72 1999 edition?

No.