



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	March 29, 2007	Interpretation	06-099
Topic	Container Capacity		
Code Section(s)	CFC T-8204-A		
Requested by	Chad Gomez 17992 Mitchell South Irvine, CA 92614 (949)221-6237 cgomez@ktgy.com		

CFC Table 8204-A specifies in the top, left heading "CONTAINER CAPACITY." Do the numbers under this heading include aggregate amounts or do they refer to individual container size. If I have four 500 gallon tanks (totaling 2,000 gallons), do they fall under the requirements of "251 to 500 gallons" or do they fall under the requirements of "501 to 2000"?

CFC Table 8204-A , CONTAINER CAPACITY, refers to the aggregate capacity for multiple container installations.

The above installation would be in the "501 to 2000 gallon" container capacity.