



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	9/19/07	Interpretation	07-077
Topic	Smoke detection in elevator hoist-ways		
Code Section(s)	2001 CFC 1006.2.4.2.2.1.1, 2002 NFPA 72 6.15.3.6		
Requested by	Richard Taylor LAUSD, Fire Life Systems Testing Group 2929 Sunrise St. Los Angeles, CA 90023 (323) 980-8447 Richard.taylor@lausd.net		

The California Fire Code requires that new or modernized public school campuses be provided with smoke detection in "every room or area". Does this include elevator hoist-ways that are not provided with fire sprinkler protection or elevator smoke relief equipment as is indicated in the 2002 NFPA 72 6.15.3.6?

No.