



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	9/19/07	Interpretation	07-078
Topic	Residential stoves vs. Type I Hoods		
Code Section(s)	CBC Section 1005		
Requested by	Richard Snyder Sierra Madre Fire Department 242 W. Sierra Madre Blvd. Sierra Madre, CA 91024 (626) 355-5174 <a href="mailto:RSnyder@ci.sierra-madre.ca.us">RSnyder@ci.sierra-madre.ca.us</a>		

Do residential stoves in a kitchen located in the fire station require a Type I hood with suppression system?

***No. A residential stove is not commercial type cooking equipment as identified in 2001 California Mechanical Code Section 509.1, therefore does not require a Type I hood with fire suppression system***