



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	1/22/08	Interpretation	07-144
Topic	Group R, Div 6.2 Location On Property		
Code Section(s)	2001 CBC Section 317A and Table 5A		
Requested by	Steve Bunting Newport Beach Fire Department (949) 355-9090 Cell SBunting@NBFD.net		

Do the exterior wall and opening protection requirements in Table 5A for the Group R, Division 1 occupancy group apply to Group R, Division 6.2 occupancies?

Yes, when the exterior wall is located 3 or more feet from the property line.

Does Section 317A allow the exterior wall of a Group R, Division 6.2 which is located 3 feet or more from the property line to be non-rated and have openings?

2001 CBC Section 317A does not apply to exterior walls of a Group R 6.2 located 3 feet or more from the property line.