



## California State Fire Marshal **CODE INTERPRETATION**

Date Issued	May 9, 2008	Interpretation	08-011
Topic	Does 2001 CFC 1006.3.3.3.1 require the installation of audible and visual notification appliances.		
Code Section(s)	2001 California Fire Code 1006.3.3.3.1		
Requested by	David J. Burkhart, P.E. Principal Code Consultants, Inc. 1804 Borman Circle Drive St. Louis, Missouri 63146-4136		

**If audible and visual notification appliances are NOT required by a different section of the 2001 CFC or the 2001 CBC, is section 1006.3.3.3.1 of the 2001 CFC applicable to the effect of the requiring the installation of audible and visual notification appliances in the building?**

No. 2001 CFC 1006.3.3.3.1 does not require the installation of visual notification devices. Requirements for visual notification devices should be referenced to CFC Section 1006.3.3.3.4.