



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	May 13, 2008	Interpretation	08-025
Topic	Wireless interconnected smoke alarms for Group R occupancies		
Code Section(s)	2007 California Building Code 907.2.10.4		
Requested by	Gregory Lake, Supervising Inspector Code Development and Enforcement Sacramento Metro Fire		

1. Can SFM-listed smoke alarms that are AC hardwired but have radio transmitted interconnection be used to satisfy CBC 907.2.10.3?

Yes. This can be applied to an R3.1

2. Does 907.2.10.4 prohibit their use since testing the interconnecting wires is part of the acceptance test?

No

State Fire Marshal Interpretation Comments

Code Interpretation Committee
Code Interpretation
Date
Summary

Division Chief Review
Code Interpretation
Date
Summary