



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	2/2/2009	Interpretation	08-083
Topic	Corridor ratings in Group I-2 occupancy suites		
Code Section(s)	2007 California Building Code Section 1014.2.2, 1017.1		
Requested by	Gary Dunger Chief Fire & Life Safety Officer Office of Statewide Health Planning & Development 700 N. Alameda Street, Suite 2-500 Los Angeles, CA 90012 (213) 897-3111 (213) 897-1608 fax GDunger@oshpd.ca.gov		

In a Group I-2 occupancy health care suites, are corridors inside the suite required to be 1-hour fire-resistive construction in accordance with Section 1017.1?

No, rated corridors are not required in suites where the design complies with section 1014.2.2.