



California State Fire Marshal **CODE INTERPRETATION**

Date Issued	7/25/2011	Interpretation	10-056
Topic	Fire Alarm System Requirements in a mixed use occupancy containing Group I-2.1 and Group B occupancy		
Code Section(s)	2007 California Building and Fire Codes Sections 907.1.3 and 907.2.6.2		
Requested by	Cesar B. Fortuno, Pyro-Comm Systems, Inc (714) 902-8000 cfortuno@pyrocomm.com		

Where a Group I-2.1 Occupancy (Ambulatory Care Facility) is located within a fully sprinklered Group B Occupancy, is the entire building required to have an approved manual and automatic fire alarm system?

No, only the Group I-2.1 Occupancy portion and the subsequent shared egress would be required to have an approved manual and automatic fire alarm system.