



**California State Fire Marshal  
Information Bulletin**

**ITT WATER TECHNOLOGY INC.  
FIRE SUPPRESSION SYSTEM  
VOLUNTARY RECALL**

ITT Water Technology Inc. has received one report of a pump failing to start during a system test.

ITT has determined that a mechanical part on the pump was not fully tightened, which can lead to the pump failing during use. Although the pump itself does not pose a fire hazard, if the pump sold with fire suppression systems fail, it may increase the risk of fire damage.

The recalled pumps were sold under the Goulds Pumps®, Bell & Gossett®, and Red Jacket Water Products brands. They can be identified by having Model NPE, NPO, MCC, MCS, SM or Series 3530 on their nameplate and were manufactured between December 2005 and July 26, 2006. They have date code M05, A06, B06, C06, D06, E06, F06 or G06. The date code is the first three digits of the serial number on the pump nameplate.



As a result of this condition, ITT Water Technology Inc. will contact installers of fire suppression system to schedule an inspection and replacement.

For detailed information, please visit the following site:

<http://www.cpsc.gov/cpscub/prerel/prhtml06/06244.html>

For more information concerning the State Fire Marshal's Building Materials Listing Program, please contact Supervising Deputy State Fire Marshal James Parsegian by phone at (916) 445-6787 or by Email at: [james.parsegian@fire.ca.gov](mailto:james.parsegian@fire.ca.gov)

See other informational bulletins on our website at: <http://osfm.fire.ca.gov/firehazard.html>