

ISSUED: January 9, 2006

California State Fire Marshal
Informational Bulletin

Unapproved Fire Extinguishers
Sold in California



ARO490010



Chrome

A certain fire extinguisher marketed by Arospeed Racing, 3500 NW 77 Court, Miami, FL, does not meet the approved standard for sale in California.

The model in question is:

- ARO490010

Sales of unapproved fire extinguishers in California constitute a violation of Section 13162 of the Health and Safety Code which states that no person shall market, distribute, or sell any portable fire extinguisher in California unless it has been examined by and bears the label of Underwriters' Laboratories or another testing laboratory approved by the State Fire Marshal.

If you have any questions or require further assistance please contact **James Parsegian** at the California State Fire Marshal's Office, Telephone Number **916-445-8415**

Visit our website at: <http://osfm.fire.ca.gov>