

ISSUED: January 9, 2006

California State Fire Marshal
Informational Bulletin

Unapproved Fire Extinguishers
Sold in California



Model 109110

Chrome

Model 109111

Red

Model 109115 Blk. Chrome

Certain fire extinguishers marketed by American Products Company, 22324 Temescal Canyon Rd., Corona, CA, do not meet the approved standards for sale in California. The models in question are:

- 109110 Chrome
- 109111 Red
- 109112 Blue (not shown)
- 109113 Silver (not shown)
- 109115 Black Chrome

Sales of unapproved fire extinguishers in California constitute a violation of Section 13162 of the Health and Safety Code which states that no person shall market, distribute, or sell any portable fire extinguisher in California unless it has been examined by and bears the label of Underwriters' Laboratories or another testing laboratory approved by the State Fire Marshal.

If you have any questions or require further assistance please contact **James Parsegian** at the California State Fire Marshal's Office, Telephone Number **916-445-8415**

Visit our website at: <http://osfm.fire.ca.gov>