



## California State Fire Marshal Information Bulletin

Issued: July 2, 2007

### **Globe Fire Sprinkler Corp. Recalls Dry Fire Sprinklers Model J Heads Can Fail to Operate During a Fire**

WASHINGTON, D.C. - The U.S. Consumer Product Safety Commission, in cooperation with the firm named below, today announced a voluntary recall of the following consumer product.

**Name of Product:** Globe Model J Series Dry Fire Sprinklers  
**Units:** About 300,000  
**Manufacturer:** Globe Fire Sprinkler Corp., of Standish, Mich.

**Hazard:** The sprinkler heads can deteriorate over time and fail to operate in a fire.

**Incidents/Injuries:** Globe has received five reports of sprinklers that failed to operate as intended during a fire. Globe has received no reports of injuries caused by sprinklers failing to operate.

**Description:** Model J Series dry fire sprinklers come in pendent, upright, and sidewall configurations. The name "Globe," the letter "J" and the year of manufacture (1990 through 1999) are embossed on the frame of each sprinkler. These dry sprinklers were designed to be installed in areas of buildings where the sprinklers or water supply pipes may be subject to freezing, such as unheated attics, freezers and coolers, parking garages, porches and warehouses.

**Sold by:** Fire protection contractors nationwide from January 1990 through December 1999 for between \$27 and \$36 per sprinkler head.

**Manufactured in:** United States

**Remedy:** Contact Globe immediately to arrange to receive replacement sprinkler heads at a reduced cost of \$9 per sprinkler head.

**Consumer Contact:** For additional information, contact Globe at (800) 248-0278 between 8 a.m. and 5 p.m. ET Monday through Friday, or visit the firm's Web site at [www.globesprinkler.com](http://www.globesprinkler.com) and click on the "Recall" link. Consumers can obtain this release and recall information at CPSC's Web site at [www.cpsc.gov](http://www.cpsc.gov).

For more information concerning the State Fire Marshal's Fire Extinguisher Program, please contact Sr. Deputy James Parsegian by phone at (916) 445-8415 or by Email at: [james.parsegian@fire.ca.gov](mailto:james.parsegian@fire.ca.gov)

For more information please visit our website <http://osfm.fire.ca.gov>