



## California State Fire Marshal Information Bulletin

Issued: April 14, 2008

### Fire Alarm Control Panel Recalled By Gamewell FCI Due to Alert Failure

The U.S. Consumer Product Safety Commission in cooperation with Gamewell-FCI, of Northford, Conn. has issued a voluntary recall of about 3,000 Gamewell-FCI 7100 Series Fire Alarm Control Panel. The sounder on the panel's main circuit board can fail to alert when there is a malfunction.

This recall involves Gamewell-FCI 7100 Series fire alarm control panels. The panels provide control, display and annunciation information. The series includes the following model numbers:

Model No.	Description
1100-1312	BK-7100-2D Basic Systems Kit, With DACT, 2 SLC
1100-1314	BK-7100-2D-240V Bas. Sys. Kit, w/DACT, 2 SLC, 240 VAC
1100-1352	7100 Series Basic Systems Module, With DACT, 1 SLC
1100-1237	7100-1 Addressable FACP w/DACT, 1 SLC with cabinet
1100-1311	BK-7100-2 Basic Systems Kit, 2 SLC
1100-1313	BK-7100-2-240V Basic Systems Kit, 2 SLC, 240 VAC
1100-1351	7100 Series Basic Systems Module, 1 SLC
1100-1238	7100-1 Addressable System, 1 SLC with cabinet

The following State Fire Marshal Listings are affected by this recall: 7165-1703-105, 7170-1703-117, 7165-0694-219, and 7170-0694-259.

Sold by: Authorized distributors to commercial end users in facilities such as hotels and office buildings nationwide from May 2007 through November 2007.

Gamewell-FCI is contacting customers directly and is providing a free repair kit. In the event of sounder failure during an alarm, the various other audible and visual indicators will notify occupants of an alarm condition.

Consumer Contact: For additional information, contact Gamewell-FCI at (800) 274-4324 between 8 A.M. and 6 P.M. ET Monday through Friday, or visit the company's Web site at [www.gamewell-fci.com](http://www.gamewell-fci.com)

If you have further questions regarding this bulletin, please contact Division Chief Ben Ho at [ben.ho@fire.ca.gov](mailto:ben.ho@fire.ca.gov) or (916) 445-8312.

For more information please visit our website <http://osfm.fire.ca.gov>