



California State Fire Marshal Information Bulletin

Issued: August 30, 2010

Unapproved Fire Extinguisher Sold in California By “k2 motor Fire Extinguisher”



It has come to our attention that k2 motor, is selling unapproved portable fire extinguishers in California. The fire extinguishers models FE-01S and FE-01GM sold by K2 Motor, do not meet the approved standards for sale in California.

California Health and Safety Code Section 13162 States:

Requirements for sale and distribution;” *No person shall market, distribute, or sell any portable fire extinguisher in this state unless it meets the following requirements:*

(a) It complies with regulations and standards adopted by the State Fire Marshal pursuant to Section 13160.

(b) It has been examined by and bears the label of Underwriters' Laboratories Inc. or another testing laboratory which is approved by the State Fire Marshal as qualified to test portable fire extinguishers. Any testing laboratory approved by the State Fire Marshal shall have facilities, personnel, and operating procedures equivalent to those of the Underwriters' Laboratories Inc.”

The marketing, distribution or sale of this Fire Extinguisher in California is a violation of California State Law.

You may contact k2 motor directly at:

Company Address: 250 Benton Ct., Walnut, CA 91789

Contact Information: 800-959-3915/909-839-2992 FAX: 909-839-2522

If you have questions regarding this Informational Bulletin, please contact Senior Deputy State Fire Marshal, James Parsegian at james.parsegian@fire.ca.gov or (916) 445-8415.

For information regarding the California State Fire Marshal Office please visit our website <http://osfm.fire.ca.gov>