



## California State Fire Marshal Information Bulletin

Issued: August 30, 2010

### Unapproved Fire Extinguisher Sold in California By “AIRBAGIT Fire Extinguisher”



It has come to our attention that AIRBAGIT is selling unapproved portable fire extinguishers in California. The fire extinguisher models Chrome with Flames, Blue, Chrome Plain, Red Plain and Silver Plain sold by AIRBAGIT, do not meet the approved standards for sale in California.

#### **California Health and Safety Code Section 13162 States:**

**Requirements for sale and distribution;**” *No person shall market, distribute, or sell any portable fire extinguisher in this state unless it meets the following requirements:*

*(a) It complies with regulations and standards adopted by the State Fire Marshal pursuant to Section 13160.*

*(b) It has been examined by and bears the label of Underwriters' Laboratories Inc. or another testing laboratory which is approved by the State Fire Marshal as qualified to test portable fire extinguishers. Any testing laboratory approved by the State Fire Marshal shall have facilities, personnel, and operating procedures equivalent to those of the Underwriters' Laboratories Inc.”*

The marketing, distribution or sale of this Fire Extinguisher in California is a violation of California State Law.

You may contact AIRBAGIT directly at:

Company Address: AIRBAGIT (aka Chassis Tech) 260 South Hibbert, Mesa, AZ 85210

Contact Information: 480-668-5448 FAX 480-668-5442

If you have questions regarding this Informational Bulletin, please contact Senior Deputy State Fire Marshal, James Parsegian at [james.parsegian@fire.ca.gov](mailto:james.parsegian@fire.ca.gov) or (916) 445-8415.

For information regarding the California State Fire Marshal Office please visit our website <http://osfm.fire.ca.gov>