



California State Fire Marshal Information Bulletin 12-02

May 14, 2012

Unapproved Fire Extinguisher Sold in California By Fire Service Plus, Inc.



It has come to our attention that Fire Service Plus, Inc. is selling unapproved portable fire extinguishers in California. The Fire Ade 2000 portable Fire Extinguisher sold by Fire Service Plus, Inc., does not meet the approved standards for sale in California.

California Health and Safety Code Section 13162 States: Requirements for sale and distribution;

“No person shall market, distribute, or sell any portable fire extinguisher in this state unless it meets the following requirements:

(a) It complies with regulations and standards adopted by the State Fire Marshal pursuant to Section 13160.

(b) It has been examined by and bears the label of Underwriters' Laboratories Inc. or another testing laboratory which is approved by the State Fire Marshal as qualified to test portable fire extinguishers. Any testing laboratory approved by the State Fire Marshal shall have facilities, personnel, and operating procedures equivalent to those of the Underwriters' Laboratories Inc.”

The marketing, distribution or sale of this fire extinguisher in California is a violation of California State Law.

If you have questions regarding this Informational Bulletin, please contact Deputy State Fire Marshal, Jeff Schwartz at jeffrey.schwartz@fire.ca.gov or (916) 341-4364.

For more information please visit our website <http://osfm.fire.ca.gov>