



## California State Fire Marshal Information Bulletin 18-003

Issued: March 20, 2018

### Errata for California Building Code

#### CBC Table 705.2

The California Building Code Table 705.2 was printed without the fourth row. It should match the International Building Code as shown:

TABLE 705.2  
MINIMUM DISTANCE OF PROJECTION

FIRE SEPARATION DISTANCE (FSD)	MINIMUM DISTANCE FROM LINE USED TO DETERMINE FSD
0 feet to 2 feet	Projections not permitted
Greater than 2 feet to 3 feet	24 inches
Greater than 3 feet to less than 30 feet	24 inches plus 8 inches for every foot of FSD beyond 3 feet or fraction thereof
30 feet or greater	20 feet

#### CBC Table 506.2 for R-2.1

Table 506.2 was printed with errors for the R-2.1 occupancy. It should read as follows:

Table 506.2

OCCUPANCY CLASSIFICATION	SEE FOOTNOTES	TYPE OF CONSTRUCTION								
		TYPE I		TYPE II		TYPE III		TYPE IV	TYPE V	
		A	B	A	B	A	B	HT	A	B
<u>R-2.1<sup>1</sup></u>	<i>NS<sup>d</sup></i>	<i>UL</i>	<i>55,000</i>	<i>19,000</i>	<i>NP</i>	<i>16,500</i>	<i>NP</i>	<i>NP</i>	<i>10,500</i>	<i>NP</i>
	<i>S13R</i>	<i>UL</i>	<i>220,000</i>	<i>76,000</i>	<i>NP</i>	<i>66,000</i>	<i>NP</i>	<i>NP</i>	<i>42,000</i>	<i>NP</i>
	<i>S1</i>	<i>UL</i>	<i>165,000</i>	<i>57,000</i>	<i>NP</i>	<i>49,500</i>	<i>NP</i>	<i>NP</i>	<i>31,500</i>	<i>NP</i>
	<i>SM (without height increase)</i>	<i>UL</i>	<i>165,000</i>	<i>57,000</i>	<i>NP</i>	<i>49,500</i>	<i>NP</i>	<i>NP</i>	<i>31,500</i>	<i>NP</i>
	<i>SM (with height increase)</i>	<i>UL</i>	<i>55,000</i>	<i>19,000</i>	<i>NP</i>	<i>16,500</i>	<i>NP</i>	<i>NP</i>	<i>10,500</i>	<i>NP</i>