



**DEPARTMENT OF FORESTRY AND FIRE PROTECTION
OFFICE OF THE CALIFORNIA STATE FIRE MARSHAL
FIRE ENGINEERING DIVISION
PORTABLE FIRE EXTINGUISHER PROGRAM
SERVICE VEHICLE INSPECTION REPORT**

Company Name: _____

Physical Address: _____

City: _____ Zip: _____

Contact Person: _____ Phone Number: _____

VEHICLE INFORMATION	
Year	
Make	
Model	
Color	
Registered Owner	
License Number	

TOOLS AND EQUIPMENT	
<input type="checkbox"/>	Brushes Non-Ferrous
<input type="checkbox"/>	Continuity Tester (A, B, E)
<input type="checkbox"/>	Rubber Mallet
<input type="checkbox"/>	Hammer
<input type="checkbox"/>	Screwdrivers (assorted)
<input type="checkbox"/>	Wrenches (assorted)
<input type="checkbox"/>	Garden Hose
<input type="checkbox"/>	Cylinder Inspection Light
<input type="checkbox"/>	Pressure Regulators & Calibrated Low Pressure Gauge
<input type="checkbox"/>	Recharge Adapters
<input type="checkbox"/>	Electric Drill and Bits
<input type="checkbox"/>	Cleaning Towels
<input type="checkbox"/>	Clean Bucket
<input type="checkbox"/>	Torque Wrench Set (Type A,E)*
<input type="checkbox"/>	Socket Wrench Set*
<input type="checkbox"/>	Water Pump Pliers with smooth face jaw
<input type="checkbox"/>	Leak Test Solution
<input type="checkbox"/>	Pliers (assorted) needle nose, side cutter
<input type="checkbox"/>	Closed Dry Chemical Recovery System
<input type="checkbox"/>	Loaner Extinguishers (10)
<input type="checkbox"/>	Scale for extinguishers up to 60 lbs. (shall have minimum 4oz graduation, and accurate to +/- 4oz) plus 10 lb. test wt.
<input type="checkbox"/>	Scale for extinguishers more than 61 lbs. (shall have minimum 8oz graduations, and accurate to +/- 8ozs)*
<input type="checkbox"/>	Scale for extinguisher cartridges (shall have minimum graduation not larger than 1/100, and accurate to +/- 1ozs) plus 1 lb. test wt.

SERVICE PARTS	
<input type="checkbox"/>	Gauges (appropriate)
<input type="checkbox"/>	Discharge Nozzles (appropriate)
<input type="checkbox"/>	Discharge Hoses (appropriate)
<input type="checkbox"/>	O Rings (appropriate)
<input type="checkbox"/>	Valve Stems (appropriate)
<input type="checkbox"/>	Valve Handles and Rivets (appropriate)
<input type="checkbox"/>	Valve Springs (appropriate)
<input type="checkbox"/>	Parts list for extinguisher being serviced
<input type="checkbox"/>	Pull Pins
<input type="checkbox"/>	Proper recharge agent for extinguisher being serviced (i.e. ABC, BC, etc.)
<input type="checkbox"/>	CO2 Horns
<input type="checkbox"/>	CO2 Hoses
<input type="checkbox"/>	CO2 Nipples

SERVICE SUPPLIES	
<input type="checkbox"/>	Continuity Test Labels
<input type="checkbox"/>	Valve/O-Ring Lube, manufacturer approved
<input type="checkbox"/>	Teflon Tape
<input type="checkbox"/>	Tamper Seals
<input type="checkbox"/>	Collar Rings (all sizes)
<input type="checkbox"/>	Maintenance Tags
<input type="checkbox"/>	Tape Measure
<input type="checkbox"/>	Manuals*
<input type="checkbox"/>	Laws and Regulations (Current Edition)
<input type="checkbox"/>	Nitrogen/Dry Air Cylinder (secured to vehicle per DOT Requirements)
<input type="checkbox"/>	Wall Brackets
<input type="checkbox"/>	Toggles and Mollies

HYDRO TEST EQUIPMENT	
<input type="checkbox"/>	Hydrostatic Testing Pump (A, C)*
<input type="checkbox"/>	Hydrostatic Test Heads/Adapters (A, C)*
<input type="checkbox"/>	Safety Cage (A, C)*
<input type="checkbox"/>	Cylinder Drying Unit (145 Degrees) (A, C)*
<input type="checkbox"/>	Hydrostatic Labels (A, C, E)
<input type="checkbox"/>	Hydro Test Record Sheets (A, C, E)*

* Indicated items may be located at the shop

Responsible Party _____ Signature _____ Date: _____

DSFM Name _____ Signature _____ Date: _____